


What is the HC MTF ? Organization of the HC MTF. What is traced in the HC MTF ? How is the data organized ? Orders of Magnitude Upload rate 2006-2007. Expected upload rate for 2007-2008. Quality of the Data: Documentation, NCRs, Repeated Steps. Manual & Automatic Upload. Integrating the upload within the test process. Link to the LHC Layout Database. Further requests by users.



What is the HC MTF ?



Database that tracks the Hardware Commissioning of the LHC Systems



Organization of the HC MTF



Radio Frequency
Beam Instrumentation
WorldFip Segment
Machine Protection System
Control
ELQA
DFB
Energy Extraction System
AC Distribution
Beam Dumping System
Beam Injection System
Radiation Monitoring
Warm Circuit
Superconducting Circuit
Control
Quench Protection System
Cooling
Ventilation
Cryogenics
Power Cables
Cooling
Vacuum
Power Converter
Access & Safety
Collimator

HC Team

Blanca Perea
Jacek Szkutnik
Gosia Macuda
Alvaro Marqueta

MTF Team

Sophie Chalard
Sonia Mallon
Marcin Sobieszek
Rafal Lyzwa
Catherine Laverriere

HC
Procedures

Needs of the user
to profile definition
in terms of steps
and properties |
Data Upload
tracking | Data
Upload tools (XML
File Creator, XLS
to XML) | Progress
views

monthly
reports

Profile
Implementation |
Automatic upload
inbox | Modification
of uploaded data |
Step and Property
Reports (by system
and geographical) |
MTF Access rights
management





- MAIN PAGE
- MEETINGS
- TWIKI
- MTF
 - MTF LINKS
 - MTF XML REPORTS CREATOR
 - MTF UPLOAD PROGRESS
- DOCUMENTS
- ELOGBOOK
- HC WORKING GROUP
- POWERING PROCEDURES
- LHC
- TIMBER
- METER
- EDMs
- CDD
- LAYOUT DATABASE
- ELECTRICAL CIRCUITS
- INSTALLATION

INTRO

Go to Sect

HC Arborecence

- ARC01
 - E ARC01 - AC Distribution
 - BP ARC01
 - CT ARC01
 - CT ARC01
 - CBV ARC01
 - Coiling & Ventilation
 - U RR13 - Coiling & Ventilation
 - U UA07 - Coiling & Ventilation
 - U UA07 - Coiling & Ventilation
 - Q ARC01 - Cryogenics
 - DFB
 - DFBA-7L1 - Distribution Feed Box Type A
 - DFBAP-7R0 - Distribution Feed Box Type A
 - Safety
 - Superconducting Circuits
 - Okai Connectors
 - RB AB1 - Main Superconducting Circuits
 - RCBCH0 L1B1
 - RCBCH0 RBE1 - Superconducting 120 A Oib. Connector Circuits
 - RCBCH7 L1B2
 - RCBCH7 RBE2 - Superconducting 120 A Oib. Connector Circuits
 - RCBCH8 L1B1
 - RCBCH8 RBE1 - Superconducting 120 A Oib. Connector Circuits
 - RCBCH9 L1B2
 - RCBCH9 RBE2 - Superconducting 120 A Oib. Connector Circuits
 - RCBCH0 L1B2
 - RCBCH0 RBE2 - Superconducting 120 A Oib. Connector Circuits
 - RCBCHV L1B1
 - RCBCHV RBE1 - Superconducting 120 A Oib. Connector Circuits
 - RCBCH6 L1B2
 - RCBCH6 RBE2 - Superconducting 120 A Oib. Connector Circuits
 - RCBCH5 L1B1

HC Step Report by System

HC Properties Report by System

Custom Report

Created on Thursday, 2007-09-19 for PEREA HVC Slits Step Report

System Name	Step	Start Date	End Date	Duration	Status	Comments
ARC01
...

HC Step Report by Sector

HC Properties Report by Sector

Custom Report


Created on Thursday, 2006-11-9 for PEREA Hardware Commissioning - Circuits

Properties for class 600A Energy Extraction System
...

there is a leak. This leak will be repaired after the EIQA campaign Monday September 3rd.

Sector 78

The consolidation work with the sector at room temperature is a faulty dipole (1055) has been already replaced and it is currently being the different leaks found during the pressure tests are being localized in the region between Q9 and Q11 was repaired this week; the inner (Q1L8), which had to be brought to the surface to fix a spider that during the pressure tests, is already repaired and installed; in order to



Select unit type:

- Power Converter for Cold Circuits
- Power Converter for Warm Circuits Type1 (surface buildings)
- Power Converter for Warm Circuits Type2 (underground areas)
- Power Cables Water Cooled
- Power Cables Non Water Cooled
- Powering Interlock Controller
- Cooling
- Cooling Water Cooled Cables
- Quench Protection
- ELQA
- 600A Energy Extraction System
- 13kA Energy Extraction System
- Beam Instrumentation - VME crates

Select Sector

Sector 34

Select Underground Area (using Control and Shift keys you can select multiple)

completed. Some repaired this week. mber 3rd; this will, the new SSS that warm magnet tests fixed, the last tests still by the end of

HARDWARE COMMISSIONING TEST REPORT WIZARD



What is traced in the HC MTF ?



Slot Identifier: RPTE.UA43.RB.A34
Other Identifier: None
Description: Power Converter for Cold Circuits Slot

Job Id	IR/EI	Status	Res.	Description	Started	Ended
13597524		Done	Ok	10-HCA PCSCT-PT Converter Connected to Grid	2006-09-11	2006-09-11
13597525		Done	Ok	12-HCA PCSCT-PT Fast Power Abort Test	2006-08-16	2006-08-17
13597526		Done	Ok	14-HCA PCSCT-PT Loss of Cooling Water (*)	2006-09-11	2006-09-11
13597527		Done	Ok	16-HCA PCSCT-PT Convert. On/Control Loop Tuned (*)	2006-09-11	2006-09-11
13597533		Done	Ok	18-HCA PCSCT-PT Test of EE with Current	2006-08-29	2006-08-29
13597532		Cancelled	Cancelled	20-HCA PCSCT-PT Check of Current Sensor (*)	2006-08-29	2006-08-29
13597528		Done	Ok	22-HCA PCSCT-PT PC Remote Operation Tests	2006-08-24	2006-08-24
13766154	R	Done	Ok	22-HCA PCSCT-PT PC Remote Operation Tests (*)	2006-08-28	2006-08-28
13597529		Done	Ok	24-HCA PCSCT-PT 8-Hour Heat run	2006-08-24	2006-08-24
13597535		Cancelled	Cancelled	25-HCA PCSCT-PT MQM Squeezing Tests at Warm (*)	2006-08-24	2006-08-24
13597531		Done	Ok	26-HCA PCSCT-HR 24-Hour Heat Run	2006-08-28	2006-08-28
13597530		Done	Ok	28-HCA PCSCT-HR 24-Hour Monit. Air/Water Temp (*)	2006-08-28	2006-08-29

1. Validation of the tests performed to the equipment

2. Report documents, journals, EDMS, etc.

3. External Properties (LDB) + Property Values (test variables) + Parameters (historical tracking)

Doc. page	Description	Size
Doc. page	12-HCA PCSCT-PT Fast Power Abort Test-RPTE.UA43.RB.A34	109 Kb
Doc. page	24-HCA PCSCT-PT 8-Hour Heat run-RPTE.UA43.RB.A34	
Doc. page	RPTE.UA43.RB.A34_8HrsHeatRuns_UA43_09_26_26_suyker.txt (3 kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@V_MEAS@09_26_30_500@0@ (284 Kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@V_REF@09_26_30_500@0@ (260 Kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@I_REF@09_26_30_500@0@ (214 Kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@ST_FAULTS@09_26_30_500@0@ (149 Kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@I_MEAS@09_26_30_500@0@ (282 Kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@STATE_PC@09_26_30_500@0@ (153 Kb)	
sdds	8HrsHeatRuns_UA43_suyker_RPTE.UA43.RB.A34@SUB_51@acquisitionTimestamp@09_26_30_500@0@ (391 Kb)	
Doc. page	26-HCA PCSCT-HR 24-Hour Heat Run-RPTE.UA43.RB.A34	
Doc. page	RPTE.UA43.RB.A34_24HrsHeatRuns_UA43_13_56_27_delphine.txt (3 kb)	
sdds	24HrsHeatRuns_UA43_delphine_RPTE.UA43.RB.A34@SUB_51@V_MEAS@13_56_31_000@0@ (800 Kb)	
sdds	24HrsHeatRuns_UA43_delphine_RPTE.UA43.RB.A34@SUB_51@V_REF@13_56_31_000@0@ (880 Kb)	
sdds	24HrsHeatRuns_UA43_delphine_RPTE.UA43.RB.A34@SUB_51@I_REF@13_56_31_000@0@ (711 Kb)	
sdds	24HrsHeatRuns_UA43_delphine_RPTE.UA43.RB.A34@SUB_51@ST_FAULTS@13_56_31_000@0@ (266 Kb)	

Property	Nominal Value	Value	Unit
Isolation Value		15.8	Gohm
A Breaker IRD		15.8	ms
A Breaker ZVRD		20.2	ms
A Breaker MSW			ms
B Breaker IRD		15.5	ms
B Breaker ZVRD		20.6	ms
B Breaker MSW			ms
Z Breaker IRD		45	ms
Z Breaker ZVRD		49.2	ms
Z Breaker MSW			ms
Time interval-Normal Mode			ms
Time interval - SOF mode			ms
Ura		89.8	mV
Urb		82	mV
Urc		84.7	mV
Uttotal		432.5	mV






How is the data organized ?

Systems (*slots*) are organized in groups (*classes*) sharing the same testing procedures (*profile*): they are commissioned through the same test sequence (*steps*). If parameters are measured they are stored as *properties*.

The data is linked to the systems (slots), which are geographically and functionally distributed within the LHC Ring, organized in Sectors and Regions



SECTOR

HC REGION

EQUIPMENT & EQUIPMENT GROUPS


The population of the systems within the arborescence is now 100% automatic once established the criteria to locate the system, which may be geographical or functional

Class	Nr. of slots in MTF	Nr. of slots in the Tree	Nr. of slots not in the Tree	Nr. of slots not in MTF
CIB	16	16	0	0
CIF	12	12	0	0
CIW	78	63	15	0
Radio Frequency	56	56	0	0
Cryogenics	54	54	0	0
Power Cables	1635	1635	0	0
Cooling	583	579	4	0
Powering Interlock Controller	820	820	0	0
Quench Protection	552	552	0	0
DFB	52	52	0	0
Radiation Monitoring - Standard RP	80	76	4	0
Radiation Monitoring Air, Water, Standalone	75	63	12	0
WorldFip	245	243	2	0
Energy Extraction 600A	202	202	0	0
Energy Extraction 13kA	32	32	0	0
Ventilation	35	35	0	0
Power Converter	1729	1729	0	0
Circuit	1635	1635	0	0
Beam Interlock Controller	16	16	0	0
Fast Magnet Current change Monitor	12	12	0	0
MKI Injection Kickers	8	8	0	0
Collimator	160	160	0	0
BV01	133	88	133	88
BLM	2624	2624	0	0
BPM	1175	1175	0	0
BTV	37	37	0	0
BCTF	10	10	0	0
BCTD	4	4	0	0
BGI	4	4	0	0

Orders of Magnitude




Number of Systems (*slots*)




- ~ 14 000 Systems organized within ~ 70 classes
- Major Systems in terms of slots are (classes): Beam Instrumentation / Power Converters / Circuits / EIQA & Systems directly linked to the circuits

Number of tests per system (*steps*)



- Individual profiles can range from 1 to 100 steps
- The systems that trace in more detail are Circuits, RF, Beam Dumping System, BI and PC


Number of *entries* (*steps* x *slots*)



116 000 entries expected



Number of parameters (*properties*)



- Individual profiles store between 1 (EDMS Procedure) and 60 parameters
- Classes tracking more parameters are: Circuits, Energy Extraction and BI







Upload rate 2006-2007

24% of the entries are filled

Upload evolution since 2006



Time evolution of the HC MTF number of entries - real upload curve




Real Upload Curve

MTF
Review
Campaign




Time evolution of the HC MTF number of entries - theoretical curve



Ideal Upload Curve



Comparison between Ideal and Real Upload Curves



Real vs. **Ideal** Upload Curve


We profit from less intense testing periods to upload data



Expected upload rate 2007-2008




Upload evolution since 2006



EXTRAPOLATION !!



Manual & Automatic Upload



Automatic Upload is used by:

- BLM & BPM
- WorldFip Segments
- Warm Magnet Interlock Control
- ELQA for Warm/Cold Circuits
- Energy Extraction Systems
- AC Distribution (*)
- RAMSES
- Warm Electrical Circuits
- SC Circuits
- Powering Interlock
- Quench Protection
- Cooling
- Power Cables
- Power Converters

Manual Upload is used by:

- DFBs
- BSRT & BTV & BCTD & BCTF
- Injection Kicker
- RAMSES
- Ventilation

- Automatic Upload is made through XML files copied into [\\cern.ch\dfs\Users\h\hardcom\MTF](http://cern.ch/dfs/Users/h/hardcom/MTF) folder and notified to Malgorzata Macuda or copied to the MTF Sequencer folder (only the Sequencer for the Superconducting Circuit tests)

- There are still a number of incidences while uploading data due to inexact syntax of the XML files. **See Gosia's talk**

- HC Team (Jacek) has prepared a number of tools to facilitate the upload, either through XML file creator or by automatically converting XLS files to XML files (in particular for properties). **See Jacek's demo**

XML file creator accessible from <http://hcc.web.cern.ch/hcc/>

The screenshot displays the 'Hardware Commissioning Test Report Wizard' interface. At the top, there's a 'Select test type:' section with various radio button options. Below that, a 'select Sector:' dropdown is set to 'Sector 42'. The 'Civil work: UA63' and 'MTF step: 10-HCAPCSCT-PT Converter Connected to Grid' are selected.

The main part of the interface is a table with the following columns: Nr, Slot name, Start Date, End Date, Status, Result, Executed by, File, and Comments. The table contains several rows of test data, all with a status of 'T-Done' and a result of 'OK'.

Below the table, there's a section titled 'You can edit the file by' which shows a preview of the generated XML file. The XML content includes job details, descriptions, dates, and results for the '10-HCA PCSCT-PT Converter Connected to Grid' test.

At the bottom right, a 'File Download' dialog box is open, asking 'Do you want to open or save this file?'. It shows the file name '...CA_PCSCT-PT_Converter_Connected_to_Grid.xml', its type as 'XML Document', and its source as 'From: hcc.web.cern.ch'. There are 'Open', 'Save', and 'Cancel' buttons.



Integrating data upload within the system tests







Upload times have dramatically decreased for most of the systems, from a few months to a few weeks in most of the cases !

Example could be the comparison between upload and test execution dates for the three profiles of Power Converters

or WorldFip Segments who have reduced to zero their delay to upload the data

YES !!! It looks like the data upload becomes a last step after data analysis!!



NCRs
[249]

Comments
[1.5%]

Quality of the Data


Repeated Steps
[8%]

Documentation
[26%]



10%-30% repeated entries SC Circuits
 16-20 % repeated entries for PC
 5% repeated entries WorldFip, Cooling
 < 5% other classes

The repeated steps may be an indicator of the quality of tracking



The associated documentation is also an indicator of the data quality

Circuits, Energy Extraction Systems, Worldfip and ELQA for Warm Circuits are those linking more documentation to their entries

System	% entries with documents
Quench Protection	3
Cryogenics	3
SYSTEME D'ACCES LHC (S)	5
Powering Interlock	7
BI Synchrotron Radiation Telescope	13
Radiation Monitoring - Standard RP	19
Radiation Monitoring Air, Water, Standalone	25
Power Converter for 60A Orbit Correctors	32
Power Converter for Warm Circuits (T2)	35
Power Converter for Cold Circuits	41
Warm Electrical Circuit Type 2	46
600A Energy Extraction System	48
Warm Electrical Circuit Type 1	50
Inner Triplets Plus Quad. and Dip. Circuit	69
Individually Powered Dipole Circuit	73
Superconducting 600 A Without EE Circuit	74
Superconducting 600 A With Crowbar Circuit	76
Superconducting 120 A Correctors Circuit	79
Superconducting 600 A With EE Circuit	86
13kA Energy Extraction System	86
Main Superconducting Circuit	97
WorldFip Segment	99
ELQA for Warm Circuits	100
Superconducting 60 A Orbit Correctors Circuit	100

Layout & MTF direct link

Address: <http://layout.web.cern.ch/layout/default.aspx?ID=1374039>

LHC FUNCTIONAL LAYOUT DATABASE

Search Mechanical & Optic (MAD) | Search Systems | Search Electrical | Interfaces | Classifications | Utilities | Navigators

FUNCTIONAL POSITIONS LAYOUT HOME - BACK

ID	ELEC. OBJ.	F. P. HIERARCHY	INTERFACES	POSITION OF	DCUM RING START	DCUM RING END	TYPE	OFFICIAL LHC F.P. NAME	MTF EQUIPMENT	EXPERT NAME	OPTIC NAME	AT/ACR NAME	CIVIL WORK	U	V	A	B	C	BEAM	FAMILY	PHASE	STATUS	More	VERSION
1374039	Elec.Obj.	↑ ↓	↑ ↓	MIDDLE	486.0507	486.0507	BLMQI	BLMQI.A12R1		BLMQI.12R1.B2I3_MQ			RH8	0.4990	0	0	0	0			1st LSS Installation	DESIGN	Details	STUDY

1 Entry HOME - BACK

LAYOUT DB
jueves, 09 de noviembre de 2006 12:42:26

Address: https://edms.cern.ch/asbuilt/plsql/mtf_slot.slot_main_top?cookie=5797328&p_rec_type=P&p_rec_id=BLMQI.A12R1

MTF
Equipment Management Folder

User: PEREA

Search: Equipment | Location | Slot | System

Assembly Tree

- ⊖ LQATH.12R1 - Arc SSS
 - ⊖ **BLMQI.A12R1 - BI Beam Loss Monitor**
 - ⊖ BLMQI.B12R1 - BI Beam Loss Monitor
 - ⊖ BLMQI.C12R1 - BI Beam Loss Monitor
 - ⊖ BLMQI.D12R1 - BI Beam Loss Monitor
 - ⊖ BLMQI.E12R1 - BI Beam Loss Monitor
 - ⊖ BLMQI.A13R1 - BI Beam Loss Monitor

Slot Folder: Installation Jobs

Slot Identifier: BLMQI.A12R1
Other Identifier: None
Description: BI Beam Loss Monitor

Actions: [Create Job](#)

Job Id	IR/E	Status	Res.	Description	Show Last Repeated
13832114		Pending		10-BLM Insulation Test	Started Ended INC
13832115		Pending		20-BLM High Tension Test	
13832116		Pending		30-BLM Acquisition Chain Test	
13832117		Pending		40-BLM Acquisition Chain Test via RA Source	

CERN - European Organization for Nuclear Research © CERN - 2006-11-09 12:44:57



Coherence between Layout and MTF systems is continuously checked through an interface prepared by Jacek

Class	Description	Nr. of slots in MTF	Nr. of slots in Layout	Nr. of missing slots	Nr. of false slots
ACN	RF Normal Conducting Cavity	16	16	0	0
ACNCL	RF Coaxial Line for Normal Conducting Cavity Module	0	0	0	0
ACSCA	RF Superconducting Bare Cavity	16	16	0	0
ADT	RF Transverse Damper	8	8	0	0
APWL	RF Instrumentation	12	12	0	0
BCTD	BI DC Beam Current Transformers for the Rings	4	4	0	0
BCTF	BI Fast Beam Current Transformer	10	10	0	0
BGI	BI Ion Profile Monitor	4	4	0	0
BLM	BI Beam Loss Monitor	2624	2624	0	0
BPM	BI Beam Position Monitor	1175	1175	0	0
BQK	BI Stripline Kicker for PLL Measurement	4	4	0	0
BQS	BI Schottky Monitor	4	4	0	0
BRANA	BI TAN Type Luminosity Monitor	4	4	0	0
BRANB	BI Standalone Luminosity Monitor	4	4	0	0
BSRT	BI Synchrotron Radiation Telescope	2	2	0	0
BTV	BI Beam Observation TV Monitor	37	37	0	0
BV01	BI VME Crate	133	133	0	0
BWS	BI Wire Scanner Profile Monitor	2	2	0	0
CI	Machine Protection System	0	0	0	0
CIB	Beam Interlock System	16	16	0	0
CIF	Fast Magnet Current Change Monitor	12	12	0	0
CIW	Warm Magnet Interlock Controller	78	78	0	0
DE01	ELQA for Warm Circuits	63	63	0	0
DQE1	600A Energy Extraction System	202	202	0	0
DQE2	13kA Energy Extraction System	32	32	0	0
E000	AC Distribution	47	47	0	0
MKB	Diluter Dump Kicker	20	20	0	0
MKD	Ejection Dump Kicker	30	30	0	0
MKI	Injection Kicker	8	8	0	0
PM01	Radiation Monitoring - Standard RP	80	80	0	0
PM02	Radiation Monitoring Air, Water, Standalone	75	75	0	0
RC00	Warm Electrical Circuit Type 2	24	24	0	0
RC01	Warm Electrical Circuit Type 1	20	20	0	0
RC02	Main Superconducting Circuit	24	24	0	0
RC03	Superconducting 600 A Without EE Circuit	72	72	0	0
RC04	Superconducting 120 A Correctors Circuit	284	284	0	0
RC05	Superconducting 60 A Orbit Correctors Circuit	752	752	0	0

116 000 entries
[24% filled]

NCRs
[249]

70 classes

Comments
[1.5%]

The system is becoming a **passive structure** to receive data. **Flexibility** to obtain maximum profit from the MTF in profile definition, upload and follow up.

442 properties

7000 documents

Repeated Steps
[8%]

14 000 slots

Documentation
[26%]

Upload Tools





THANKS !!!

Questions from the users to MTF

How is it going to be followed once HC Phase is over ?

Maintenance periods

Automatic upload of Properties (historic)

Dependencies between steps

N/A status

Automatic flag when a new run is going to be performed

Filtering when viewing the profiles

