


Bulding 245 schedule update





LIU Booster Meeting 27-03-2014

Fulvio Boattini & Michel Obrecht


TE-EPC / EN-CV

Building 245 position





Review of cooling and HVAC requirements for Booster MPS




All circuits are aluminium

A 20um mechanical filter is required before entering the converters

Water flow will be adjusted to its nominal value during commissioning by means of dedicated regulation valves

During operation one of the 3 sets of circuits (and/or the spare circuit) could be disconnected. The flow in the other circuits shall remain the same (regulation and on-off valves separated).


	MPS		QPS	Spare
	AFE + Output Filter	DCDC Converter	Quadrupole Converter	Spare Circuit
Number of Units [Nu]	3	3	3	1
Losses in water per Unit [PlossU]	100kW	77kW	25kW	30kW
Water flow per unit [Q]	Q1: 36 m3/h	Q2: 36 m3/h	Q3: 5 m3/h	Qspare: 5m ³ /h
Inlet temperature (Max) [Tin]	30÷35 deg C	30÷35 deg C	30÷35 deg C	30÷35 deg C
Inlet water conductivity [uS/cm] @ Tin	<1.5 uS/cm	<1.5 uS/cm	<1.5 uS/cm	<1.5 uS/cm
Estimated DP @ Q	4.0 bar	4.0 bar	2.5 bar	2 bar
Total Losses in water [PlossH2O] (alu circuit)	500kW			



Review of cooling and HVAC requirements for Booster MPS



	Temperatures [degC]	Losses [kW]	Sun Radiation [W]
Converter Hall	26	160	(*)
Control Room	human range (18deg winter 26 summer)	4	(*)
Capacitor rooms	human range (18deg winter 26 summer)	5 (for each room)	(*)
False Floor	26	15	(*)
EN/EL area	26	10	(*)



Building 245 CV Conceptual Design




Conceptual Design based on :

- Independent cooling station :
- Cost optimised Air conditioning system :
 - No chilled water,
 - Units placed on the roof,

URS inputs


- Cooling power on water: confirmed 470 kW = 2 units at 100% + 30% of the third unit Flow rate, delta T of 2.3 °C,
- Conductivity of the water confirmed, maxi 0,8 micro S/cm at 30 °C,
- Need to run independently : **2 fully independent stations for cooling** located in the new building,
- Requirements for internal temperature revised, 26 °C in summer with maxi of 30 °C during limited periods



Débit-Puissance						
Débit	CA	176.35	[m³/h]			
Puissance		470.0	[kW]			
					Pompe	
Delta T	Cp	Densité	Delta P	Rend.	P	
[K]	[kJ/kg*K]	[kg/m³]	[bar]		[kW]	
2.3	4.18	998	4.0	0.5	39.19	

ACIER INOX											
PN10						PN16					
DN	de	e	di	Vmax	V	DN	de	e	di	Vmax	V
[mm]	[mm]	[mm]	[mm]	[m/s]	[m/s]	[mm]	[mm]	[mm]	[mm]	[m/s]	[m/s]
10	17.2	1.6	14.0		318.21	10	17.2	1.6	14.0		318.21
15	21.3	1.6	18.1		190.38	15	21.3	1.6	18.1		190.38
20	26.9	1.6	23.7		111.04	20	26.9	1.6	23.7		111.04
25	33.7	1.6	30.5		67.05	25	33.7	1.6	30.5		67.05
32	42.4	1.6	39.2		40.59	32	42.4	1.6	39.2		40.59
40	48.3	1.6	45.1		30.66	40	48.3	1.6	45.1		30.66
50	60.3	2.0	56.3	1.2	19.68	50	60.3	2.0	56.3	1.2	19.68
65	76.1	2.0	72.1	1.4	12.00	65	76.1	2.0	72.1	1.4	12.00
80	88.9	2.0	84.9	1.5	8.65	80	88.9	2.0	84.9	1.5	8.65
100	114.3	2.0	110.3	1.7	5.13	100	114.3	2.0	110.3	1.7	5.13
125	139.7	2.0	135.7	1.9	3.39	125	139.7	2.0	135.7	1.9	3.39
150	168.3	2.0	164.3	2.0	2.31	150	168.3	2.3	163.7	2.0	2.33
200	219.1	2.3	214.5		1.36	200	219.1	2.6	213.9		1.36
250	273.0	2.6	267.8		0.87	250	273.0	3.2	266.6		0.88
300	323.9	2.9	318.1		0.62	300	323.9	3.6	316.7		0.62

Normal Jäggi Hybridcooler




- 1 Primary cooling circuit
- 2 Process cooling medium inlet pipe
- 3 Finned tube heat exchanger bundles
- 4 Process cooling medium outlet pipe
- 5 Process heat exchanger
- 6 Cooling circuit pump
- 7 Deluging/wetting water circuit
- 8 Make-up water inlet
- 9 Water collector trough/pond
- 10 Blowdown drain
- 11 Cold inlet air
- 12 Fan
- 13 Fan drive


Annual operating costs (water, power and capital costs)

Calculation example at 4 €/m³ water price

	€	System ① Open evaporative cooling tower	System ② Closed loop evaporative cooler	System ③ Jäggi Hybridcooler
Water costs	€/year	63 080	63 080	13 584
Power costs	€/year	1 613	15 927	5 807
Capital costs	€/year	1 646	3 437	6 981
Annual operating costs	€/year	66 339 (251%)	82 444 (312%)	26 372 (100%)



Operating characteristics of a Jäggi Hybridcooler (example)




Natural convection cooling: A considerable saving in power consumption by switching off the fans for a time.

GEA *Adia-DENCO*®


Caractéristiques techniques

DA100#C	nominale DT10 T _a : 35°C T _s : 25°C		nominale DT12 T _a : 38°C T _s : 26°C		
	Puissance & Efficacité ^o				
Puissance frigorifique totale	kW	88,7	108,6	105,8	131,6
Puissance frigorifique utile	kW	84,5	101,7	101,6	124,7
Melieure efficacite energetique (EER)		10,3	7,9	12,3	9,6
Ratio de chaleur sensible (SHR)		1,0	1,0	1,0	1,0
Ventilateurs debit d'air exterieur					
Temperature ambiante	°C	35,0	35,0	35,0	35,0
Humidite ambiante	%	28,0	28,0	28,0	28,0
Debit d'air	m ³ /h	25.800	32.000	25.800	32.000
Nombre de ventilateurs	Pcs.	3	3	3	3
Puissance absorbee des ventilateurs ext.	kW	3,5	5,9	3,5	5,9
Ventilateurs debit d'air interieur (Salle IT)					
Debit d'air	m ³ /h	25.800	32.000	25.800	32.000
Nombre de ventilateurs	Pcs.	3	3	3	3
Puissance absorbee ventilateur int.	kW	4,2	6,9	4,2	6,9
Adiabatique					
Quantite d'eau en circulation	kg/h	664	664	664	664
Quantite en eau evaporee	kg/h	195	195	260	260
Pression nominale	Bar	10,0	10,0	10,0	10,0
Puissance absorbee pompe	kW	0,88	0,88	0,88	0,88
Donnees acoustiques					
Puissance sonore "caisson"	dB (A)	60	64	60	64
Puissance sonore "entree d'air"	dB (A)	77	80	77	80
Puissance sonore "sortie d'air"	dB (A)	83	86	83	86
Caracteristiques electriques ^o					
Puissance absorbee totale	kW	8,6	13,7	8,6	13,7
Alimentation electrique	V/Ph/Hz	400/3/50	400/3/50	400/3/50	400/3/50
Eau glacee ^o					
Puissance frigorifique totale	kW	138,6	158,1	138,6	158,1
Puissance frigorifique sensible	kW	124,9	143,7	124,9	143,7
Debit d'eau	m ³ /h	21,2	24,3	21,2	24,3
Perte de charge echangeur de chaleur	kPa	58,4	74,1	58,4	74,1
Poids & Dimensions ^o					
Hauteur	mm	2.880	2.880	2.880	2.880
Profondeur	mm	2.640	2.640	2.640	2.640
Longueur	mm	6.480	6.480	6.480	6.480
Longueur (avec unite de refroidissement integree)	mm	6.920	6.920	6.920	6.920
Poids	kg	4.430	4.430	4.430	4.430
Poids (avec unite de refroidissement integree)	kg	4.850	4.851	4.852	4.853


Sous reserve de modifications techniques resultant d'un perfectionnement du produit
^o Air entrant salle IT 35°C DB(2), Air neuf salle IT 25°C, Environnement: Temperature bulbe sec 35°C / bulbe humide 21°C
¹ Filtres propres / sans raccord gaine
² Eau 10 / 16°C / 0% glycol
³ Sans anse (boture / armoire de regulation)




Concept du système *Adia-DENCO*®




CV Integration




CV Integration



CV Integration



CV Integration





B245 Integration Milestones



- Update of the Electrical Power Consumption: 17th March 2014
- Final Decision on Dummy Load by TE/EPC: 17th March 2014
- Decision on number of galleries between b271 and b245: 24th March 2014
- Update of the Electrical Network schematic: 28th March 2014
- Integration of major CV 3D components in the b245 model: 28th March 2014
- Update of integration of EN/EL cabinets: 28th March 2014
- Final Modification of b245 structure: 11th April 2014
- Integration of pipes, cables ladders and others: 25th April 2014

- Update of the Electrical Power Consumption: 17th March 2014

USER	POWER [kW]	COMMENT	REFERECENCE
EN/CV	135	Water cooling and towers b.245	M.Obrecht 08/03/2013
TE/EPC	392	Auxiliaries	F.Boattini 22/11/2013 QTR power converters + all Converters and capacitor rooms aux
TE/EPC	6750	N.3 transformer 2.7 MVA (2@100%, 1@50%)	F.Boattini 22/11/2013
EN/EL	70	Lights, sockets, OH crane - b.245	F.Boattini 22/11/2013
EN/CV	153	HVAC b.245	M.Obrecht 08/03/2013
TE/EPC	15	Auxiliaries which need UPS	F.Boattini 22/11/2013
EN/CV	8	Smoke extraction	M.Obrecht 08/03/2013
EN/EL	25	Emergency light, fire detection	F.Boattini 22/11/2013

P. Converters power: 6750kW

Auxiliaries EPC: 392kW+15kW UPS

Auxiliaries CV: 288kW

B245:103kW




B245 Integration Milestones



- Update of the Electrical Power Consumption: 17th March 2014
- Final Decision on Dummy Load by TE/EPC: 17th March 2014
- Decision on number of galleries between b271 and b245: 24th March 2014
- Update of the Electrical Network schematic: 28th March 2014
- Integration of major CV 3D components in the b245 model: 28th March 2014
- Update of integration of EN/EL cabinets: 28th March 2014
- Final Modification of b245 structure: 11th April 2014
- Integration of pipes, cables ladders and others: 25th April 2014

- Final Decision on Dummy Load by TE/EPC: 17th March 2014

Approved by Serge Deleval





B245 Integration Milestones



- Update of the Electrical Power Consumption: 17th March 2014
- Final Decision on Dummy Load by TE/EPC: 17th March 2014
- Decision on number of galleries between b271 and b245: 24th March 2014
- Update of the Electrical Network schematic: 28th March 2014
- Integration of major CV 3D components in the b245 model: 28th March 2014
- Update of integration of EN/EL cabinets: 28th March 2014
- Final Modification of b245 structure: 11th April 2014
- Integration of pipes, cables ladders and others: 25th April 2014



B245 Integration Milestones



- Decision on number of galleries between b271 and b245: 24th March 2014

1366598_V1_Booster_2GeV_cabling [docx](#) (2 Mb) [pdf](#) (923 Kb)



B245 Integration Milestones




- Update of the Electrical Power Consumption: 17th March 2014
- Final Decision on Dummy Load by TE/EPC: 17th March 2014
- Decision on number of galleries between b271 and b245: 24th March 2014
- Update of the Electrical Network schematic: 28th March 2014
- Integration of major CV 3D components in the b245 model: 28th March 2014
- Update of integration of EN/EL cabinets: 28th March 2014
- Final Modification of b245 structure: 11th April 2014
- Integration of pipes, cables ladders and others: 25th April 2014

DGS-SEE would like to have an UPS for smoke extraction.
 EN-EL replies it is not justified and not “CERN standard”.

- Update of the Electrical Network schematic: 28th March 2014

switches). The full drawing can be viewed on CDD under the reference PS_EB____7003 [11].





B245 Integration Milestones



- Update of the Electrical Power Consumption: 17th March 2014
- Final Decision on Dummy Load by TE/EPC: 17th March 2014
- Decision on number of galleries between b271 and b245: 24th March 2014
- Update of the Electrical Network schematic: 28th March 2014
- Integration of major CV 3D components in the b245 model: 28th March 2014
- Update of integration of EN/EL cabinets: 28th March 2014
- Final Modification of b245 structure: 11th April 2014
- Integration of pipes, cables ladders and others: 25th April 2014



WU baselines



Excel file




Bulding 245 schedule update




THANKS FOR THE ATTENTION

QUESTIONS?


Building 245 layout




Building 245 layout




Building 245 layout (b271 side)




Building 245 layout (Isolde side)




Building 245 layout



Building 245 layout



Building 245 layout



Building 245 layout

