




RadMon Radiation measurement results from CNGS side gallery

Data from 2008

D. Kramer for the RadMon team





Positioning of RadMons in the test area (naming conventions)






Positioning of RadMons in the test area







Access door



- Wall positions used before the installation of electronics
- No electronics tests performed with RMon#6
- RMon#7 wall pos. comparable with PMI407




RMon #8 for 7/10..3.11/08 floor position i.e. from installation of equip. to end of beam





RMon #8 for 7..23/10/08 floor position fitted Hadron fluence vs. Beam intensity





RMon #7 working fine after position change, but...





A power cut in the test station occurred after ~2h of beam








RMon #7 power cut after ~2h of beam

hadrons [cm ⁻²]	Dose MS [Gy]	Dose LS [Gy]	neutrons [cm ⁻²]
3.87E+09	0.34	0.14	5.92E+09

- 1st Beam after placement of electronics started
 - 10:45 on 9 Oct 2008
- Power off for Rmon#7 (caused by PConv rack)
 - 12:58 on 9 Oct 2008
- Integrated beam intensity = $2.01 \cdot 10^{16}$ pot
- Hadron fluence unavailable since due to HW problem







RMon #7 power cut after ~2h of beam





RMon #7 for 23/10..3/11/08 floor position





Combined results for the 5 RadMon positions normalized to 10^{18} protons on target

		VALUES NORMALIZED TO <u>wpot = 1E18 pot</u>		
rad mon	POSITION	DOSE [Gy/wpot]	1MeV eq n^0 [/cm 2 /wpot]	HADRONS>20MeV [/cm 2 /wpot]
3LM06S	wall	0.85	1.4E+10	1.2E+10
3LM07S	wall (TSG45)	6.4	8.7E+10	5.6E+10
3LM07S	floor (TSG45)	26.2	2.7E+11	1.9E+11
3LM08S	wall (TSG46)	1.3	1.6E+10	9.1E+09
3LM08S	floor (TSG46)	2.4	2.4E+10	1.8E+10

rad mon	POSITION	DOSE [Gy/wpot]	1MeV eq n^0 [/cm 2 /wpot]	HADRONS>20MeV [/cm 2 /wpot]
3LM06S	wall	0.85	2.50	2.14
3LM07S	wall (TSG45)	2.62	2.64	1.25
3LM07S	floor (TSG45)	1.23	2.17	0.84
3LM08S	wall (TSG46)	1.62	2.50	1.32
3LM08S	floor (TSG46)	1.67	1.58	0.83

**PRELIMINARY comparison with FLUKA data;
High gradients, geometry details (corners, empty
ducts) and statistics produce uncertainties of factor $\sim 2^{.58}$**

**Generally higher Fluka values than measurements as
seen with PMI comparisons (see talk of A. Ferrari in
SBWG)**







Combined results for the 5 RadMon positions normalized to 10^{18} protons on target

		VALUES NORMALIZED TO <u>wpot</u> = 1E18 pot		
rad mon	POSITION	DOSE [Gy/wpot]	1MeV eq n ⁰ [/cm ² /wpot]	HADRONS>20MeV [/cm ² /wpot]
3LM06S	wall	0.85	1.4E+10	1.2E+10
3LM07S	wall (TSG45)	6.4	8.7E+10	5.6E+10
3LM07S	floor (TSG45)	26.2	2.7E+11	1.9E+11
3LM08S	wall (TSG46)	1.3	1.6E+10	9.1E+09
3LM08S	floor (TSG46)	2.4	2.4E+10	1.8E+10

		Ratios FLUKA SIMULATIONS / MEASUREMENTS		
rad mon	POSITION	DOSE	1MeV eq n ⁰	HADRONS>20MeV
3LM06S	wall	2.59	3.14	1.58
3LM07S	wall (TSG45)	2.62	2.64	1.25
3LM07S	floor (TSG45)	1.46	1.71	0.84
3LM08S	wall (TSG46)	1.62	2.50	1.32
3LM08S	floor (TSG46)	1.67	1.58	0.83



RMon #3 for 7..29/10/08 ventilation room





RadMon #3 location





Values integrated by the RadMons in CNGS from 7 Oct 2008 ($6.43 \cdot 10^{18}$ pot)

Radmon #	location	Hadrons [cm ⁻²]	Dose [Gy]	Neutrons [cm ⁻²]
1	Ventil.	0	0.069	0
2	Ventil.	8.5e5	0.178	0
3	Ventil.	9.3e6	0.078	0
4	Ventil.	8.5e5	0.066	0
5	Ventil.	0	0.084	0
6	CNGS	7.65e10	5.34	9.16e10
7	CNGS	1.24e12	168.5	1.62e12
8	CNGS	1.22e11	16.5	1.51e11

Comparison with the values integrated during 1 year of Nominal LHC operation – alongside arc dipole

- Dose : 10 Gy
- Hadrons > 20 MeV : $4 \cdot 10^{10} \text{ cm}^{-2}$
- 1 MeV eq. Neutrons : $3 \cdot 10^{11} \text{ cm}^{-2}$



TSG45



20.11.2008 RadWG

D.Kramer

TS-LEA-RAD



TSG46

