


Single Event Effects in Warm magnet Interlock Controller (WIC) during Ti8 tests


- Principle of the Warm magnet Interlock Controller (WIC)
- The Remote I/Os (composition & location)
- The Radiations tests made at CERN in 2002/2003
- The additional Radiations tests at PSI-Villingen
- The Event during Ti8 tests

- Principle of the Warm magnet Interlock Controller (WIC)
- The Remote I/Os (composition & location)
- The Radiations tests made at CERN in 2002/2003
- The additional Radiations tests at PSI-Villingen
- The Event during Ti8 tests



Remote I/Os collect the information coming from the magnets and are connected to the WIC through **Profibus**.


WIC is installed in LHC, Transfer Lines (TL) SPS – LHC, LEIR & LINAC3



- Principle of the Warm magnet Interlock Controller (WIC)
- The Remote I/Os (composition & location)
- The Radiations tests made at CERN in 2002/2003
- The additional Radiations tests at PSI-Villingen
- The Event during Ti8 tests

The Remote I/Os crates consist of:

- **24V** Power Supply - (from **EXISTA**)
- **SIEMENS** Modules:
 - PROFIBUS INTERFACE IM 153-1 - ET200M
6ES7 153-1AA03-0XB0
 - 32 DIGITAL INPUT SM 321
6ES7 321-1BL00-0AA0
 - RS485 REPEATER
6ES7 972-0AA01-0XA0





Location of the Remote I/Os crates

The Remote I/Os are installed under Dipoles or the vacuum pipe but far from the quadrupoles



Number of Remote I/Os crates used in the TL

- 18 Remote I/Os for TI2 controlling 300 magnets
- 20 Remote I/Os for TI8 controlling 403 magnets
- 6 Remote I/Os for TT41 (CNGS) controlling 145 magnets

- Principle of the Warm magnet Interlock Controller (WIC)
- The Remote I/Os (composition & location)
- The Radiations tests made at CERN in 2002/2003
- The additional Radiations tests at PSI-Villingen
- The Event during Ti8 tests



Tests Installation in TCC2



Additional tests performed in TT60

➔ beginning of the Ti2 line

TCC2 Tests Results

| Module | Type | Serial N° | Dose (Gray) | SEE (n/cm ² x10 ¹²) | Duration (weeks/days) |
|-----------------------|---------------------|--------------|-------------|---|-----------------------|
| ET 200 M | 6ES7 153-1AA03-0XB0 | S C-NNE79333 | 277 | 1,87 | 6 w |
| ET 200 M | 6ES7 153-1AA03-0XB0 | S C-P3F0623 | 280 | 1,96 | 5 w |
| ET 200 M | 6ES7 153-1AA03-0XB0 | S C-P3F41194 | 210 | 1,57 | 4 w |
| SM 321 16DI (ET 200M) | 6ES7 321-1BH02-0AA0 | S C-NNF16364 | 136 | 0,97 | 4 w |
| SM 321 32DI (ET 200M) | 6ES7321-1BL00-0AA0 | S C-P3F64025 | 500 | 3,69 | 9 w |
| PS ACT 50 | ACT50 | 4000,1270 | 942 | 8,02 | 17 w |
| Profibus Repeater | 6ES7 972-0AA01-0XA0 | S C-P5C65251 | 268 | 2,05 | 5 w |

TT60 Tests Results

| Module | Type | Serial N° | Dose (Gray) | SEE (n/cm ² x10 ¹²) | Duration (weeks) |
|-----------------------|---------------------|--------------|-------------|---|------------------|
| ET 200 M | 6ES7 153-1AA03-0XB0 | | 22 | 5,82 | 17 |
| SM 321 32DI (ET 200M) | 6ES7321-1BL00-0AA0 | | 22 | 5,82 | 17 |
| PS 307 2A | 6ES7 307-1BA00-0AA0 | | 22 | 5,82 | 17 |
| PS ACT 50 | | | 22 | 5,82 | 17 |
| PS Syko | | | 22 | 5,82 | 17 |
| PS Sitop 5A | 6EP1333-1AL11 | | 22 | 5,82 | 17 |
| Profibus Repeater | 6ES7 972-0AA01-0XA0 | S C-P5C65550 | 8,1 | 4,68 | 5 |

Siemens I/Os modules + Power-supplies + Repeaters


Radiation tests in TCC2 - Run 2003

| Module | Type | Serial N° | Indice | Dose in 2002 (Gray) | Dose in 2003 (Gray) | Total Dose |
|--------------|---------------------|--------------|--------|---------------------|---------------------|------------|
| ET 200 M | 6ES7 153-1AA03-0XB0 | S C-R2D89243 | 6 | | 100 Gy | 100 Gy |
| | | S C-R2D90385 | 6 | | 129 Gy | 129 Gy |
| SM 321 32 DI | 6ES7 321-1BL00-0AA0 | S C-P9B51289 | 4 | | 129 Gy | 129 Gy |
| | | S C-R1G72304 | 4 | | 129 Gy | 129 Gy |
| Repeteur | 6ES7 972-0AA01-0XA0 | S C-P5C65251 | 4 | 268 Gy | 32 Gy | 300 Gy |
| | | S C-NND98373 | 3 | | 57 Gy | 57 Gy |
| | | S C-R2B29941 | 4 | | 38 Gy | 38 Gy |

| <u>Module</u> | <u>Type</u> | <u>No de serie</u> | <u>Indice</u> | <u>Radiation</u> recu en 2002 | <u>Radiation</u> recu en 2003 | <u>Radiation</u> total recu |
|--|---------------------|--------------------|---------------|----------------------------------|----------------------------------|--------------------------------|
| Alim. Siemens PS307 2A Modifie | 6ES7 307-1BA00-0AA0 | S Q6P4386490 | 3 | | 38 Gy | 38 Gy |
| <i>(Alim. modifiee par Siemens: Mofset V7 changed to 25K1358/ Toshiba 900V/9A)</i> | | | | | | |
| Alim. Siemens Sitop 5A | 6EP 1333 - 1AL11 | S Q6P4388995 | 3 | | 68 Gy | 68 Gy |
| Alimentations ACT50 1x24V | ?? | TCC2 | | | 129 Gy | 129 Gy |
| Alimentations ACT50 2x24V | ACT50 | 4000, 1270 (TCC2) | | 942 Gy | 129 Gy | 1071 Gy |
| Alimentations Syko 2x24V | 7.55.233.001.0 | 2.06007 (TCC2) | | 550 Gy | 129 Gy | 679 Gy |
| | | 2.06006 (TCC2) | | 942 Gy | 129 Gy | 1071 Gy |

- Principle of the Warm magnet Interlock Controller (WIC)
- The Remote I/Os (composition & location)
- The Radiations tests made at CERN in 2002/2003
- The additional Radiations tests at PSI-Villingen in 2003 & 2009
- The Event during Ti8 tests

In order to have a better precision



| Material tested | Type | Indice | Maximal dose (Gray) | Comments |
|---------------------------------|---------------------|--------|---------------------|---|
| Slave Module ET 200 M (Siemens) | 6ES7 153-1AA03-0XB0 | 7 | 280 | * During irradiation several voluntary power supply "on/off" without problem. *After 70 grays of irradiation - module down but comes "ok" without any action |
| Digital Module 32 DI (Siemens) | 6ES7 321-1BL00-0AA0 | 4 | 190 | * During irradiation several voluntary power supply "on/off" without problem. |
| Répéteur Profibus (Siemens) | 6ES7 972-0AA01-0XA0 | 6 | 89 | 30mm collimator on DRASIC -ST 03333 KU 002 circuit |
| | | 6 | 110 | no collimator - irradiation on the power circuits |
| Switching Power supply (Exista) | ASC 50 24 V | | 370 | Starting voltage = 24,598 V - current = 246,33mA End voltage = 25,51 V - current = 247,158mA |

140 Gy = $1 \cdot 10^{11}$ protons à 60 MEV

Nb de protons: $450 / (140 \cdot 10^{11}) = 3.21429 \text{ E}+11$


Durée d'exposition: $(3.21429 \text{ E}+11 / 1 \cdot 10^{E+8}) / 60 = 54 \text{ minutes}$


| Material tested | Type | Indice | Maximal dose (Gray) | Comments |
|--|---------------------|--------|---------------------|---|
| Digital Module 24 DI Safety (Siemens) | 6ES7 326-1BK01-0AB0 | 2 | 20 | We had to perform a reset during each irradiation (11 in total) |
| | | 2 | 19.5 | |
| Slave Interface ET200M (Siemens) | 6ES7 153-1AA03-0XB0 | 16 | 226 | During irradiation the Profibus address was several times corrupted after a new Profibus cycle or reset module was OK |
| | | 16 | 200 | |
| Digital Output Module DOx8 AC230V/5A Relay (Siemens) | 6ES7 322-1HF10-0AA0 | 2 | 500 | Irradiation was stopped after 500Gy only the output LEDS were broken |

- Principle of the Warm magnet Interlock Controller (WIC)
- The Remote I/Os (composition & location)
- The Radiations tests made at CERN in 2002/2003
- The additional Radiations tests at PSI-Villingen
- The Event during Ti8 tests

TCDIH 87441: Collimator

CIWRA 87544: WIC Deported I/O:
collect the magnet information from
MQI 87500 to MSIA A6R8 → about
25 m downstream from the collimator





What happened before/during the incident:

- When closing the collimator jaws, this has generated a shower of particles which (most likely) corrupted the ET 200M memory
- The remote IO module lost its Profibus address and the Power-Converters which supply the magnets connected to this crate were cut off (expected fail-safe behaviour !)
- After a reset of this crate (24V Power Supply ON/OFF – remotely) the module in question was again operational

Conclusion:

- Incident most likely linked to (accidental) particle shower generated by upstream collimator
- The ET 200M module has reacted as foreseen (ie fail-safe switched off converters)
- Remote reset sufficient to make the system again operational
- This kind of problem was never observed during previous operation of the TL with beam, even for (higher intensity) CNGS beam in TT40
- The preliminary design of this TL (at which locations of remote IOs had to be defined) did not include collimators at this location
- Initial radiation estimates of these TL predicted (very) low doses for the remote IO locations

Possible Solutions which could help to limit future impact:

If such collimator adjustments have to be done :

- If sufficient, add additional shielding for this remote I/O crate?
- Move the I/O crate in question 40 m upstream, but this implies a cost and an extended intervention
- Move only the inputs for the main dipole magnets to the upstream I/O crate, thus avoiding to perturb CNGS operation (less cabling, but reconfiguration and re-testing needed)

