



CNGS electronics tests

status in October 2009

Last access for slot 6 was on 7 October 2009.

End of beam foreseen for
24 November 2009 (W48)

D.Kramer



Changes during last access

- ◆ Photos available at \\cern.ch\dfs\Users\g\gspiezia\Public\cnqs_access7oct
- ◆ CRYO terminated the tests (equipment in temporary Radioactive storage)
- ◆ Survey moved from TSG46 to 45 (BPM S2 calibration to be used in the tool)
- ◆ New equipment from TE/EPC installed and one FGC generic replaced (with upgraded analog card)
- ◆ Activation foils removed (Au)
- ◆ FipDiag reinstalled for the Station 4 (?)
- ◆ Bug for QPS S2 position corrected in the tool



Summary table of the ongoing and finished tunnel electronics tests in CNGS

	1MeV n eq. [cm ⁻²]	Dose [Gy(SiO ₂)]	Short comment
BLM	7.1e12	300	Tunnel card still OK (1 reset needed), all PS down
CRYO	4.2e12?	130?	Tunnel cards OK Test finished
HTS CL	4.2e10	3.6	1 out of 4 modules down Reset yet to be done
Survey	1.6e11	9.0	OK, but data to be analyzed
BIC/PIC	3.0e12	125	1CPLD 5V died so far
WFip	4.4e11	21	New repeater for slot 5 and 6 - OK
BPM	2.1e12	123	Tunnel Card OK Test finished
TE/EPC	4.4e11 7.4e10	18 3.0	3xSEL for FGC COD (1xSEL for FGC generic)
QPS			

FGC Generic Power converter status (Sylvie Dubettier)

- ◆ **6071** SEUs counted on FGC COD memories, all 100% corrected (EDAC)
 - ◆ EDAC and memory corruption detection works.
- ◆ Results from Memory corruption deduced fluence by FGC and RadMon values are close.
 - ◆ Louvain Results \approx CNGS Results.
- ◆ **42** SEU on register C32, HC16 and WFIP counted (could crash software if critical register). Most of corruption are on the WFIP registers.
 - ◆ Software Update with corruption detection feature will be developed on 2009.
- ◆ 18 Gy on FGC Generic, and no influence seen on components (Louvain showed that critical limit was below 120 Gy).
- ◆ High Precision Digital filter corrupted many times. Would impact on the high precision current level (operation & calcul. phase corrupted)
 - ◆ Software Update with digital filter corruption detection feature for 2009 or new card (SD360, in test at CNGS – SO FAR OK).
- ◆ **1** crash not explained but manual-recovering using hardware Power Cycle implemented feature each time.

FGC COD Power converter status (Sylvie Dubettier)

- ◆ **1592..** SEUs counted on FGC COD memories, all 100% corrected (EDAC)
 - ◆ EDAC and memory corruption detection works.
- ◆ Results from Memory corruption deduced fluence by FGC and RadMon values are close.
 - ◆ Louvain Results \approx CNGS Results.
- ◆ **49** SEU on register C32, HC16 and WFIP counted (could crash software if critical register). Most of corruption are on the WFIP registers.
 - ◆ Software Update with corruption detection feature will be developed on 2009.
- ◆ 18 Gy on FGC Generic, and no influence seen on components (Louvain showed that critical limit was below 120 Gy).
- ◆ **3** crashes not explained but manual-recovering using hardware Power Cycle implemented feature each time.
 - ◆ A Run log has been created. it can give some information about these events. To be interpreted.