RadWG May 18th 2010

Feedback from RadWG Members

- Many of you replied -> Thank You!
- Quite some common feedback:
 - Standardized reporting
 - Intensified connection with PH/ESE
 - Prioritization of radiation tests
 - Development of Test-Guidelines
 - Collected information (website, simplified database)
 - Radiation Policy
 - **—** ...
- We wait until the next meeting and then prepare a final proposal

RadWG Slot

doodle poll resulted in:

Thursday afternoon: 15
Tuesday morning: 14

for those having a preference we did another check:

Who	Tuesday Morning	Thursday Afternoon
S. Grau E. Calvo E. v.d. Bij G. Burdet	'0' '0' 'A'	'A' • Prior to workshop: <u>every two weeks</u>
R. Chery P. Dahlen H. Jena J. Palluel	'A'	• Later: <u>each third weeks</u>
G. Penacoba S. Roesler Y. Thurel	'A' 'A'	'A' +on demand

thus current count:

Thursday afternoon: 15
Tuesday morning: 17

Some News

- R2E Workshop Agenda in 'refinement' with session chairs (last version available <u>here</u>)
- Mitigation Options 'prepared' for the June-Workshop:
 - Shielding:
 - UJ14/16/56 (final design)
 - RRs at P1/5 (what options)
 - UJ23/87 (reinforcement + 'plug')
 - UW85 (to be verified if enough in the long-term)
 - Relocation (critical and sensitive equipment, other can and should remain):
 - UJ76: remaining work
 - US85: full relocation
 - UJ14/16: full relocation into US15 and UIs (in study)
 - UJ56: full relocation

Organization:

- Ideas/Concepts discussed/developed in R2E, status communicated in RadWG
- Integration iteration discussed and followed through ICL
- Proposal iterated in R2E workshop
- Final proposals submitted (after common approval) to management and approved by LMC
- a.o.b.,?

Next RadWG Agenda (Suggestion!)

Date: Tuesday June 1st, 10:30h, 864-1C-02

- Fire/ODH Relocation Needs/Constraints/Costs/Options (S. Grau)
- What Equipment can remain and what has to be relocated (G. Spiezia)
- Radiation Tests of Power-Converters Where are we? (Y. Thurel)
- COTS Equipment & Failure Rates (CNRAD 2010)
 Final Table
 (M. Brugger)
- RadWG Mandate and Objectives (M. Brugger)
- a.o.b.,

Failure Rate Estimate (first draft)

LHC	LHC 2011 Nomin		Manainal	2010/11 Nominal Equipment				Failure Rate (year-1)			
Point	Area(s)	2011 (integrated)	Nominal (integrated)	x 10 ⁷	x 10 ⁷	Type	=qu #	Sensitivity	Comments	2011	Nominal
Folile	11.14.4	(integrated)	(integrated)	X 10	X 10	туре	#	Sensitivity		2011	Nonnia
Point 1	UJ14 UJ16	2.5E+07	5.0E+09	2.5	500.0	PLCs:	50	1.00E+07	first guess	125	25000
	RR13 RR17	5.0E+06	1.0E+09	0.5	100.0		25	1.00E+07	first guess	12	2500
	UPS14 UPS16	5.0E+06	1.0E+09	0.5	100.0	alignm.	10	1.00E+09	hardness even higher?	0	10
Point 3	UJ33	6.3E+04	1.3E+06	0.0	0.1		50	1.00E+07	first guess	0	6
	UJ/RE32	8.4E+05	1.7E+08	0.1	16.7		50	1.00E+07	first guess	4	836
Point 5	UJ56	2.5E+07	5.0E+09	2.5	500.0		50	1.00E+0 <mark>7</mark>	first guess	125	25000
	RR53 RR57	5.0E+06	1.0E+09	0 .5	100.0		25	1.00E+07	first guess	12	2500
	UPS54 UPS46	5.0E+06	1.0E+09	0.5	100.0		10	1.00E+09	hardness even higher?	0	10
Point 6	UA63 UA67	2.5E+06	5.0E+07	0.3	5.0		10	1.00E+07	Ducts can be sealed	2	50
Point 7	UJ76	1.0E+08	2.0E+09	10.0	200.0		50	1.00E+07	first guess	500	10000
	RR73 RR77	1.0E+07	2.0E+08	1.0	20.0		25	1.00E+07	first guess	25	500
Point 8	UX85b	1.0E+09	2.0E+09	100.0	200.0		0		nothing left?	0	0
	US85	2.5E+08	5.0E+08	25.0	50.0		50		first guess	1250	2500
	UW85	5.0E+07	1.0E+08	5.0	10.0		15	1.00E+07	first guess	75	150
TI2	UJ23	6.9E+06	6.9E+07	0.7	6.9		4	1.00E+07	shielding 2010/11 most likely possible	3	28
TI8	UJ87	6.9E+06	6.9E+07	0.7	6.9		4	1.00E+07	shielding 2010/11 most likely possible	3	28
Average Failure Rate (day ⁻¹)								2011:	11		
Average Failure Rate (day)									Nominal:	346	