


**CERN  
ITN**




# **Radiation protection and radiation safety issues for HIE-ISOLDE. FLUKA calculations**

**Y. Romanets**

*ISOLDE Workshop and Users meeting 2010*



**CERN, 8 December 2010**



# Summary


- Geometry
  - ✓ Installation
  - ✓ Targets' areas
    - ❑ *HRS (High Resolution Separator)*
    - ❑ *GPS (General Purpose Separator)*
  - ✓ Targets configuration
- Dose rate simulations (FLUKA)
  - ✓ Parking area
  - ✓ Gas storage
- On-going work
- Conclusions


# ISOLDE facility, geometry



**Ta (Tantalum) target**  
Density 16.654 g/cm<sup>3</sup>


**UC<sub>x</sub> (Uranium Carbide)**  
Density 3.25 g/cm<sup>3</sup>





# Simulation


- Bias
  - ✓ ON/OFF
  - ✓ Selected bias direction
  
- Proton beam characteristics
  - ✓ Energy: 1.4 GeV and 2 GeV
  - ✓ Normalization to 1  $\mu\text{A}$  (6.24e12 protons/second)




# Simulations, HRS

## Tungsten convertor + Tantalum target



### Neutron flux, plane z ( -10cm : +10cm )






# Simulations, HRS

## Tungsten convertor + Tantalum target









# Dose rate, HRS


*Parking area*





# Dose rate, HRS


*Parking area*



**Parking area**


**2 GeV proton beam  
Dose-EQ ( $\mu\text{Sv/h}/\mu\text{A}$ )**






# Dose rate, GPS

*Gas storage*







# Dose rate, GPS


*Gas storage*


**1.4 GeV proton beam**  
**Dose-EQ ( $\mu\text{Sv/h}/\mu\text{A}$ ), Plane Z**






# Neutron production rate, GPS






# On-going work

- ❑ Comparison of simulation results with measurements
- ❑ Simulation of the critical parts of the installation.  
Evaluation of possible impact of upgrade on existing shielding
- ❑ Activation calculation of the shielding-soil and air inside installation.




# Conclusions


- The GPS area needs more attention from the radiation protection point of view taking into account upcoming upgrade of the installation. The dose rate of the adjunctive and supply areas depends on the type(material) of the target in use.
- HRS area represent sufficient beam dump shielding which is adequate to support increasing power of the beam due upgrade.
- Some part of the installation (shielding between active zone and experimental area) need to be revised with more precision due possible radiation leaks



Thank you







# Proton flux, GPS

