


Alarm statistics w38-39

G. Rigoletti



EP-DT
Detector Technologies

Alarms statistics



EP-DT
Detector Technologies

Alarms and warnings (from 24/09/2021 17:30):

ALICE

TRD: Mixer module not in Run -> Xe finished, Chilo informed and replaced bottle

MTR: Column A not in run -> No Ar/H2. No gas arriving to the rack -> to check with LPh asap

ATLAS

TGC: Work done after exhaust on rack restarting

Experiment	System	Email timestamp	Alarm name	Alarm status	Alarm text
ALICE	ALIMTR	2021-09-25 14:41:29	ALIMTR_P1_CAnotCyclDA	Bad	Column A is offline.
	ALIMTR	2021-09-25 15:04:00	ALIMTR_P1_CAnotCyclDA	Bad (Ack)	Column A is offline.
	ALITRD	2021-09-26 00:03:09	ALITRD_Mx_FlowInjAL	Ok	Mixer flow injection too long - check for potential leak
	ALITRD	2021-09-27 00:54:45	ALITRD_Gs_MxNotInRunDA	Bad	Mixer module not in Run.
	ALITRD	2021-09-27 01:02:51	ALITRD_Gs_MxNotInRunDA	Ok	Mixer module not in Run.
	ALITRD	2021-09-27 02:49:07	ALITRD_Gs_MxNotInRunDA	Bad	Mixer module not in Run.
	ALITRD	2021-09-27 21:07:44	ALITRD_Gs_MxNotInRunDA	Ok	Mixer module not in Run.
ATLAS	ATLTGC	2021-09-28 18:26:27	ATLTGC_Di_RNotInRunAI	Bad	At least one relevant rack is not in Run.
CMSMIXERS	RPC904	2021-09-27 03:18:36	RPC904_MoRatioAA	LL	ppm The moisture measurement is not reliable (out of range)

