

SPS availability considerations -2021

V. Kain for the SPS team

SPS 2021 - not a good year for availability



Many faults because of broken systems:

- → Vacuum system issues due to corrosion
- → Dump kicker MKDV1: weak high voltage behaviour due to broken insulating ceramic spacer
- → arcing in transmission lines for 2 RF cavities

<u>Design issues:</u>

→ SEU for access system crates


All of these will be addressed during the YETS.

Still many faults due to "operation" or "downtime to be updated": will have to be fine-tuned in 2022. Requires more stable operation...

Fault distribution 2021




2623 faults, total fault duration 885.3 h Average availability 73.4 %




Weekly Availability





Faults Timeline by System





2022: Upgrades to fault tracking in the SPS




Big Sister will track faults also according to destination.

Prototype out to track not only downtime, but also which system caused it AUTOMATICALLY. Thanks, Eric...

Should cover 60 % of all faults out of the box.

Will commission and fine-tune it during the early commissioning HWC and BC

Eric's Interlocking Super Agent (ISA) based on SIS, virtual parameter publication and subscription by BigSisters



ISA...



SIS Exporter in SIS


Exporters

- •One exporter for each permit
- •Permits defined for each destination or beam
- •List for AFT fault system defined in SIS

```
| Comparison | Sps ring | Contents | Sps ring | Sps rin
```


ISA...















BigSister, logbook and AFT

In case SIS OKno beam from injectors

•No SIS Exporter received

- "Downtime, to be updated"
- •SIS Exporter "is in the list"
- •SIS Exporter "is not in the list"
- "Downtime, to be updated"

