



HSE

Occupational Health & Safety
and Environmental Protection unit



CARE

Cable Ageing Research project

HSE Seminar

19th May 2022


J. Gascon

on behalf of CARE project team



Introduction

Historical perspective (until 1997)



The image shows the cover of a CERN report and a diagram of the process from 1997-2002.

CERN 89-12
Technical Inspection and Safety Commission
 31 December 1989

ORGANISATION EUROPÉENNE POUR LA RECHERCHE NUCLÉAIRE
CERN EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH

COMPILATION OF RADIATION DAMAGE TEST DATA

PART I, 2nd EDITION:
 Halogen-free cable-insulating materials

INDEX DES RÉSULTATS D'ESSAIS DE RADIORÉSISTANCE

1^{re} PARTIE, 2^e ÉDITION:
 Matériaux d'isolation de câbles exempts d'halogène

H. Schönbacher and M. Tavlet

1997-2002


The diagram shows the **CERN store (GS)** (blue box) providing **Small orders** (blue arrow) to **EN-EL** and **PH (Experiments)**.

EN-EL and **PH (Experiments)** are part of the **Installation** phase.


PH (Experiments) leads to **Users**.

Structuring of material section
 massive reduction of resources

Historical perspective (after 2002)



Historical perspective (Today: 2015)



History

CARE Working Group 2016-2019

- Mandated by S. Baird
- **Leader:** F. Szoncsó
- **Members:** T. Wijnands, I. Petrova, D. Ternova, R. Kerschner

CARE Project 2019-

- Mandated by D. Forkel-Wirth – Endorsed by B. Delille
- **Leader:** J. Gascon
- **Team members:**



**Artem
DANYLIUK**

Chemical Eng.
Senior fellow



**Berta
RUIZ PALENZUELA**

Materials Eng.
PJAS



**Federica
BORTOLETTO**

Materials Eng.
Junior fellow



**Dr. Marija
KRANJCEVIC**



PhD in CS
Senior fellow

Basics

Cable design

Cable applications at CERN

- HV power
- LV power
- DC power (*Power converters & magnets*)
- Instrumentation & Control
- Speciality (*RF, experimental areas, others*)
- Safety (*lighting, monitoring, safety systems*)
- IT & office (*IEC/EU compliant*)
- *Grounding*



Cable design

Cable Stressors

- **Temperature**
- Humidity
- **Chemicals** (oxygen, ozone, lubricants,...)
- **Ionising radiation** (*UV included*)
- **Electrical** (*ohmic heating*)
- **Mechanical** (*bending, squeezing, vibration*)

Cable degradation is a combination of stressors effects !!!!

Cable design

Cable main components

- **Conductors** (electrical): *copper, aluminium*
- **Insulation** (electrical): *polymers (XLPE, XLPO, EPR,...)*
- **Shielding** (electrical): *foil (Al) or braided (Cu, Al)*
- **Jacket** (mechanical, chemical, fire): *polymers (PP, PUR, PE,...)*

Structural components

- **Fillers, binder or bedding:** *mechanical stability*
- **Tapes or semiconductors:** *electrical, mechanical, fire or identification*
- **Armouring:** *mechanical protection*

Medium-voltage submarine cable, XLPE insulated

Typical design of a medium-voltage submarine cable with a maximum voltage up to 36 kV

Type: 2XS2YRAA

1. Conductor: copper, circular stranded compacted, longitudinal water-tight by filling with a sealing compound (optional)
2. Conductor screening: extruded semi-conductive compound
3. Insulation: XLPE
4. Insulation screening: extruded semi-conductive compound
5. Screen: copper tapes
6. Separator: plastic foil
7. Sheath: PE
8. Fillers: polypropylene strings
9. Binder tapes

10. Bedding: polypropylene strings
11. Armour: galvanized round steel wires
12. Serving: hessian tapes, bituminous compound, polypropylene strings, lime wash



Cable design

Polymer types used in cable manufacturing

(halogen free)

- Ethylene vinyl acetate (EVA)
- Cross-linked polyethylene/polyolefin (XLPE / XLPO)
- Low and High density polyethylene (LDPE / HDPE)
- Ethylene propylene based elastomers (EPR / EPDM)
- Polypropylene (PP)
- Polyphenylene oxide (PPO)
- Polyphenylene ether (PPE)
- Butyl rubber (BR)
- Polyimide (Kapton®)
- Silicone rubber (SiR)
- Polyether ether ketone (PEEK)
- Polyurethane rubber (PUR)


Additives (*antioxidants, flame retardants, stabilizers*): **know-how of cable manufacturers !!!**

Cable manufacturing

Typical cable formulation recipe

	Insulation		Sheath	
Polymers	PE type	Melting point 140 to 170°C	EVA type	Melting point 120 to 150°C
Fillers	ATH	Decomposition at 190°C	ATH	Decomposition at 190°C
Fillers	MDH	Decomposition at 235°C	MDH	Decomposition at 235°C
Additifs	Ao + ACu		Ao (Acu)	
Catalyst	S2000	1 to 2 %	S2000	1 to 2%
Self XI Masterbatch	No		MBatch Viba	+ - 0.9%
Color masterbatch	Base PE		Base EVA or PE	

ATH: Alumina Trihydrate
MDH: Magnesium Hydroxide



* Source: **NEXANS Cables**

Radiation effects

Ionizing radiation effects on Polymers

- **Formation of free radicals:** chemical structure, crystallinity, dose rate, solvent content, additives, plasticizer, stabilizers, temperature, oxygen levels, humidity.
- **Formation of hydrogen & light hydrocarbon**
- **Formation of C-C bonds between molecules (crosslinking)**
- **Rupture of C-C bond (chain scission)**
- **Increase in unsaturation**
- **Breakdown of crystalline structure**
- **Discoloration**
- **Oxidation**

Not irradiated




5×10^6 Gy



10^7 Gy




In the SPS tunnel:



Synergistic effect

Collective stressors effects higher than stressors effects separately (e.g. temperature + radiation)

Testing techniques on cable ageing



CARE Project

What is CARE

- ❑ Long-lead Research programme on cable ageing
- ❑ Oriented to Rad-Hard cables
- ❑ Focussing mainly on new cables procurement
- ❑ Predictive maintenance oriented to reduce cable replacements
- ❑ Enhancing decision making process in terms of expected cables lifetime

Main Objective: extend cable lifetime procuring the most appropriate cables for CERN operations

- Determining cable “weathering” conditions (*cable stressors*)
- Defining appropriate technical requirements and tests procedures
- Providing Quality control & acceptance criteria
- Assessing cable degradation during beam operation i.e. condition monitoring
- Tracking logbook during all cable lifecycle i.e. complete cable life data over years
- Establishing lifetime models for cable from cable life data analysis

CARE Structure

□ WP1 Project Management

- **Project management documentation**
 - ✓ Minutes, presentations, collaboration
 - ✓ Management reports, deliverables

□ WP2 Cable procurement

- **Technical requirements for cable procurement**
 - ✓ Tests procedures
 - ✓ Qualification criteria
 - ✓ Acceptance criteria

□ WP3 Data management

- **Database documentation**
 - ✓ Cable samples and specimen codification
 - ✓ Managing Tests records, data sheets, TS, etc
 - ✓ Information storage & tracking in CERN tools
- **Data analysis**
 - ✓ Correlations, statistics
 - ✓ lifetime models

□ WP4 Condition monitoring

- **Radiation calculations**
 - ✓ FLUKA simulations
 - ✓ Interactions R2E
- **Artificial irradiation**
 - ✓ Technical specifications, R2M interactions
 - ✓ Preparation of samples
- **Natural irradiation**
 - ✓ Management of samples in tunnels
 - ✓ Preparation of samples

□ WP5 Testing

- **Tests activities**
 - ✓ Sample conditioning
 - ✓ Testing: TT, DSC, FTIR, Thermal ageing, etc
 - ✓ Test records in database
- **Tests techniques**
 - ✓ Exploring new techniques
 - ✓ Developing Procedures for procurement

CARE Stakeholders

- **EN-MME:** expertise in mechanical tests;
 - **TE-VSC:** expertise in chemical tests;
 - **EN-EL:** cable procurer (machine);
 - **BE-EA:** cable procurer (experiments);
 - **TE-ABT:** special cable user;
 - **SCE-SCC:** cable procurer (CERN stores);
 - **SY-STI:** Radiation machine (R2E, R2M);
 - **ATS-DO:** CERN Projects (HL-LHC);
 - **HSE-RP:** radioactive waste management
- **Steering committee** [EDMS 2594070](#)
 - **B. Delille**, head of the HSE unit (chair);
 - **D. Ricci**, representing all cable users;
 - **S. Sgobba**, mechanical expert EN-MME;
 - **M. Taborelli**, chemical expert TE-VSC;
 - **C. Garino**, CERN stores SCE-SCC;
 - **J. Borburgh**, electrical testing expert SY-ABT;
 - **R. Garcia**, electrical testing expert SY-STI;
 - **J. Gascon**, CARE project leader;
 - **A. Danyliuk**, CARE member (sci. secretary);
 - **Y. Donjoux**, DPO HSE Unit

CARE Activities

□ Fields of work

- **Qualification process for cable procurement within HL-LHC project** (High priority)
 - ✓ Preparing detailed test procedures
 - ✓ Establishing qualification criteria and acceptance criteria for cables on ageing (radiation)
 - ✓ Preparation of MS for Rad-hard cable (new 3.5MGy cable category)
- **CERN Standardisation Technical Sub-Committee for cables & connectors**
 - ✓ Part of the subcommittee
 - ✓ Contribution on technical requirements for radiation hardness & quality assurance
- **Support on Cable Quality control**
 - ✓ Supporting SCE-SSC on quality control for cables delivered at CERN (on best effort approach)
 - ✓ Some cables delivered from India manufacturer within framework contract signed by CERN to be tested (1st CPR Class Cca)
 - ✓ Technical advice to SCE-SSC on tests to be outsourced (external labs)
- **Cable assessment**
 - ✓ Expertise on requests from CERN users tests on old cables installed in high radiation areas
 - ✓ Cable Assessment Request (CAR) is prepared including technical report and tests results performed.
 - ✓ Started in 2020, we have already dealt with 10 requests.

CARE for HL-LHC Project

CARE for HL-LHC Project

□ HL-LHC project discussions

• Benchmarking in similar labs ([EDMS 2520530](#))

- ✓ ESS, ESRF, DESY (XFEL), ITER were contacted
- ✓ Labs are not same radiation requirements (radiation levels, availability & accessibility)
- ✓ Qualification cables samples seems to be appropriate for qualification purposes
- ✓ Use of cables from Vendor's catalogue best option

• New radiation resistant cable category

- ✓ SSI establishes 500kGy (100kGy operation) & 10MGy (2MGy operation) categories
- ✓ After R2E simulations few cables will be irradiated beyond 700kGy
- ✓ Create cable radiation category around 3.5MGy (700kGy operation) following benchmarking

• Cable Procurement strategy

- ✓ Pre-survey among cable manufacturers on price factor for 3.5MGy & 10MGy cables
- ✓ Endorsed by CERN management and project management
- ✓ MS by June 2022 to qualify cable manufacturer according turnover, production capabilities, radiation resistant experience
- ✓ Before tendering, manufacturers (reduced number) to provide cable samples for radiation qualification (November 2022)
- ✓ 16 weeks for ageing (radiation) qualification by July 2022
- ✓ Cables for general purposes (500kGy) not scoped to be qualified

Cables in Radiation Environment Air (standard atmosphere)



Some typical numbers from suppliers:

Lapp-Kabel (PU)	0.5 MGy
Lapp-Kabel (EPR)	1 MGy
Helukabel (PU, HM2, TM7)	1 MGy
Huber+Suhner RADOX® (RX125-XLPolyolefin Copolymer) 1 - 3	3 MGy
Marmon (XLPE + CSPE, certified to Class 1E, IEEE-323)	2 MGy
Habiatron (XLPolyolefin, certified IEEE-323 + 383)	2.3 MGy
Axon (Poliax®-PEI)	3 MGy
Huber+Suhner RADOX® (TPU)	5 MGy
Axon (Neutrax®-PEEK)	5 MGy
Axon (Kapton®-Polyimide)	10 - 20 MGy

Source: ESS

CARE vs HL-LHC Project

□ CARE plan schedule in September 2021

CARE Schedule delayed of 3 months by 2nd irradiation campaign

HL-LHC delayed on MS expected in June 2022


HL-LHC cables needs in LS3 (delayed)

- **Samples expected for qualification from manufacturers by November 2022**
- **CARE Qualification by June 2023 (IT)**



CARE for HL-LHC Project

□ CARE Qualification process



CARE for HL-LHC Project

☐ Qualification readiness

- **Team experience on tests at CERN**

- ✓ Performed around 3000 Tensile Tests (TT)
- ✓ Performed around 200 Differential Scanning Calorimetry tests
- ✓ Microscopy on defectives samples (MME lab)
- ✓ Thermal ageing (BE-EA & HSE-ENV oven)
- ✓ FTIR on old artificial irradiated cable and tunnels (TS1+ & TDC2)

- **Tests externally**

- ✓ Thermal ageing & TT in PIEP (Portugal collaboration) to converge on tests procedure & results
- ✓ Swelling tests in University of Brescia ([EDMS no 2310744](#))

- **Test Facilities**





- ✓ MME lab: TT, Microscopy
- ✓ VSC lab: DSC, TGA
- ✓ ENV lab: FTIR & oven
- ✓ PIEP (till 2023): TT, DSC, TGA , FTIR

CARE for HL-LHC Project

□ Qualification readiness

- **Artificial irradiation campaigns with cable bundles**

- ✓ R2M framework contract used for 2 campaigns
- ✓ Facility for 1st campaign Germany
- ✓ Facility for 2nd campaign France
- ✓ Difficulties due to COVID (facilities overbooked for medical)
- ✓ 1st campaign sent out in May 2021- Cable bundles received in September 2021
- ✓ 2nd campaign sent out in October 2021- Cable bundles received in May 2022
- ✓ Finalising technical report on 1st campaign
- ✓ Starting sample preparation for tests on 2nd campaign

 CERN CH1211 Geneva 23 Switzerland	EDMS NO. 2560544	REV. 0.4	VALIDITY FINAL	 CERN CH1211 Geneva 23 Switzerland	EDMS NO. 2632455	REV. 2.0	VALIDITY FINAL																																																
	REFERENCE 20-08				REFERENCE 21-02																																																		
																																																							
<table border="1"> <tr> <th colspan="3">Technical Requirements Irradiation test</th> </tr> <tr> <td colspan="3" style="text-align: center;">20-08</td> </tr> <tr> <td colspan="3" style="text-align: center;">Cable irradiation test to derive Cable Ageing</td> </tr> <tr> <th colspan="3">Abstract</th> </tr> <tr> <td colspan="3"> This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables will be irradiated by ⁶⁰Co source with 5 gamma dose steps in range between 0.1 MGy and 2 MGy. </td> </tr> <tr> <td colspan="3" style="text-align: center;"> KEYWORDS #gamma #2MGy #cables </td> </tr> <tr> <th>DOCUMENT PREPARED BY:</th> <th>DOCUMENT CHECKED BY:</th> <th>DOCUMENT APPROVED BY:</th> </tr> <tr> <td>David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]</td> <td>Jose Gascon [HSE-OHS-IB]</td> <td>Matteo Ferrari [SY-STI-TCD]</td> </tr> </table>				Technical Requirements Irradiation test			20-08			Cable irradiation test to derive Cable Ageing			Abstract			This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables will be irradiated by ⁶⁰ Co source with 5 gamma dose steps in range between 0.1 MGy and 2 MGy.			KEYWORDS #gamma #2MGy #cables			DOCUMENT PREPARED BY:	DOCUMENT CHECKED BY:	DOCUMENT APPROVED BY:	David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]	Jose Gascon [HSE-OHS-IB]	Matteo Ferrari [SY-STI-TCD]	<table border="1"> <tr> <th colspan="3">Technical Requirements Irradiation test</th> </tr> <tr> <td colspan="3" style="text-align: center;">21-02</td> </tr> <tr> <td colspan="3" style="text-align: center;">Cable irradiation test to derive Cable Ageing: second test at lower dose rate</td> </tr> <tr> <th colspan="3">Abstract</th> </tr> <tr> <td colspan="3"> This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables and materials for cable manufacturing will be irradiated using ⁶⁰Co gamma source with 5 dose steps in range between 0.1 MGy and 2 MGy, at a dose rate of 1 kGy/h. This test follows a previous campaign performed at a dose rate of 3.6-5 kGy/h (irradiation test 20-08) and aims at assessing dose rate effects in cable samples. </td> </tr> <tr> <td colspan="3" style="text-align: center;"> KEYWORDS #gamma #2MGy #cables #HL #LHC #dose rate #1kGy/h </td> </tr> <tr> <th>DOCUMENT PREPARED BY:</th> <th>DOCUMENT CHECKED BY:</th> <th>DOCUMENT APPROVED BY:</th> </tr> <tr> <td>David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]</td> <td>Jose Gascon [HSE-OHS-IB]</td> <td>Matteo Ferrari [SY-STI-TCD]</td> </tr> </table>				Technical Requirements Irradiation test			21-02			Cable irradiation test to derive Cable Ageing: second test at lower dose rate			Abstract			This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables and materials for cable manufacturing will be irradiated using ⁶⁰ Co gamma source with 5 dose steps in range between 0.1 MGy and 2 MGy, at a dose rate of 1 kGy/h. This test follows a previous campaign performed at a dose rate of 3.6-5 kGy/h (irradiation test 20-08) and aims at assessing dose rate effects in cable samples.			KEYWORDS #gamma #2MGy #cables #HL #LHC #dose rate #1kGy/h			DOCUMENT PREPARED BY:	DOCUMENT CHECKED BY:	DOCUMENT APPROVED BY:	David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]	Jose Gascon [HSE-OHS-IB]	Matteo Ferrari [SY-STI-TCD]
Technical Requirements Irradiation test																																																							
20-08																																																							
Cable irradiation test to derive Cable Ageing																																																							
Abstract																																																							
This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables will be irradiated by ⁶⁰ Co source with 5 gamma dose steps in range between 0.1 MGy and 2 MGy.																																																							
KEYWORDS #gamma #2MGy #cables																																																							
DOCUMENT PREPARED BY:	DOCUMENT CHECKED BY:	DOCUMENT APPROVED BY:																																																					
David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]	Jose Gascon [HSE-OHS-IB]	Matteo Ferrari [SY-STI-TCD]																																																					
Technical Requirements Irradiation test																																																							
21-02																																																							
Cable irradiation test to derive Cable Ageing: second test at lower dose rate																																																							
Abstract																																																							
This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables and materials for cable manufacturing will be irradiated using ⁶⁰ Co gamma source with 5 dose steps in range between 0.1 MGy and 2 MGy, at a dose rate of 1 kGy/h. This test follows a previous campaign performed at a dose rate of 3.6-5 kGy/h (irradiation test 20-08) and aims at assessing dose rate effects in cable samples.																																																							
KEYWORDS #gamma #2MGy #cables #HL #LHC #dose rate #1kGy/h																																																							
DOCUMENT PREPARED BY:	DOCUMENT CHECKED BY:	DOCUMENT APPROVED BY:																																																					
David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]	Jose Gascon [HSE-OHS-IB]	Matteo Ferrari [SY-STI-TCD]																																																					

CARE for HL-LHC Project

□ 1st Irradiation campaign objectives *(bundles received in September 2021)*

• Type of cables & manufacturers

- ✓ NE8 & NE48 types selected as most used type in HL-LHC project *(source EN-EL Group)* & cables available in CERN stores
- ✓ NE48 type includes 2 different manufacturers to assess influence of manufacturer
- ✓ PH3SJ type from Polycab manufacturer (contract signed by CERN stores) to assess radiation hardness
- ✓ CGN50 type produced with popular Megolon S304 (radiation resistant)

• Dose rate influence 1Gy/s (*~3.6kGy/h*)

- ✓ 5 Dose steps 0.1 - 0.2 - 0.5 - 1 - 2 MGy increase data
- ✓ Confirm degradation trend of each cable type & manufacturer
- ✓ Confirm cable degradation around 500kGy

• Ageing methods

- ✓ 3 Combinations: Radiation only , Thermal ageing & radiation later, Radiation & thermal ageing later
- ✓ Thermal ageing 168h as requested in IEC-60502
- ✓ Assess influence of cable stressors and combination of them

• Pilot campaign

- ✓ Bundles dosimetry (3 dosimeters per bundle) & dose from facility
- ✓ Get experience for cable qualification campaign in future



CARE for HL-LHC Project

□ 2nd irradiation campaign objectives *(bundles received in May 2022)*

• Type of cables & manufacturers

- ✓ NE8 & NE48 types from same batch than 1st campaign
- ✓ NF12, SVA3 & TFA3 type included as samples irradiated naturally in TS1+ & TDC2 tunnels

• Dose rate lower ~1kGy/h

- ✓ Same dose steps 0.1 - 0.2 - 0.5 - 1 - 2 MGy
- ✓ Confirm cable degradation around 500kGy is independently of dose rate

• ageing methods


- ✓ Same as 1st campaign

• Dosimetry

- ✓ 2 extra RPL dosimeters per bundle + 2 RPLs for facility measurement

• Pilot campaign 2

- ✓ Dose rate effect
- ✓ Fix parameters to be retained for HL-LHC qualification
- ✓ Confirm shielding effect and dosimetry
- ✓ Correlate all results with 1st campaign ones




CARE for HL-LHC Project

□ Tensile Tests (TT)

• Procedure

- ✓ CARE procedure ([EDMS no 2705496](#)) for specimens preparation and test
- ✓ Dumbbell specimens type 5A & 5B from jackets




Dumbbell 5A



Dumbbell 5B

- ✓ 50 mm tubes from insulation (L0=10 mm)



50 mm Tubes




Figure A.2 — Type 5A and 5B test specimens

Specimen type	5A	5B
l_3 Overall length	≥ 75	≥ 35
b_2 Width at ends	$12,5 \pm 1$	$6 \pm 0,5$
l_1 Length of narrow parallel-sided portion	25 ± 1	$12 \pm 0,5$
b_1 Width at narrow portion	$4 \pm 0,1$	$2 \pm 0,1$
r_1 Small radius	$8 \pm 0,5$	$3 \pm 0,1$
r_2 Large radius	$12,5 \pm 1$	$3 \pm 0,1$
L Initial distance between grips	50 ± 2	20 ± 2
L_0 Gauge length	$20 \pm 0,5$	$10 \pm 0,2$
h Thickness	$2 \pm 0,2$	$1 \pm 0,1$



OCCUPATIONAL HEALTH & SAFETY AND ENVIRONMENTAL PROTECTION UNIT

Choose an item.

PROCEDURE

Testing procedure for the tensile testing of polymeric components of the cables

Prepared by:	Checked by:	Approved by:
Artem Danyliuk	Berta Ruiz Palenzuela Federica Bortoletto Marija Kranjcevic	Jose Gascon

Distribution to

Click or tap here to enter text.


CARE for HL-LHC Project

□ Tensile Tests (TT)

• Equipment (MME lab)

- ✓ Machine Zwick/Roell Z010
- ✓ Grips 8106 500N
- ✓ 2 different jaws
- ✓ Limmes video-extensometer

• Tests







Jaws for jackets



Jaws for insulations

CARE for HL-LHC Project

□ Illustration tests related



CARE for HL-LHC Project

□ Testing methods & acceptance criteria [EDMS 2447411](#)


	ageing Method	Source ageing method	Acceptance criteria	International standards		
Reference Stage			<ul style="list-style-type: none"> EaB \geq 200% (jacket) EaB \geq 300 % (insulation) Tensile strength \geq 8MPa 	According to IEC 60502 <table border="1"> <tr> <td> jacket LSZH <ul style="list-style-type: none"> EaB \geq 125% Tensile strength \geq 9MPa </td> <td> insulation XLPE <ul style="list-style-type: none"> EaB \geq 200% Tensile strength \geq 12MPa </td> </tr> </table>	jacket LSZH <ul style="list-style-type: none"> EaB \geq 125% Tensile strength \geq 9MPa 	insulation XLPE <ul style="list-style-type: none"> EaB \geq 200% Tensile strength \geq 12MPa
jacket LSZH <ul style="list-style-type: none"> EaB \geq 125% Tensile strength \geq 9MPa 	insulation XLPE <ul style="list-style-type: none"> EaB \geq 200% Tensile strength \geq 12MPa 					
Thermal Ageing Stage	Thermal ageing 42 days at 100°C	Temperature, time and oven requirements are taken from IEC 60811-408	<ul style="list-style-type: none"> Residual EaB \geq 70% OIT > 2 minutes 	According to IEC 60811-408 Applicable for wires, materials to be rolled into coils, no cracks to be obtained after the thermal ageing		
Radiation Resistance Stage	Gamma Irradiation Dose 500 kGy (dose rate >1Gy/s)	Values from SSI-FS-2-1	<ul style="list-style-type: none"> EaB \geq 100 % (jacket) Residual EaB \geq 50% (insulation) Residual Tensile strength \geq 50% Jacket 	According to IEC 60544-2 <ul style="list-style-type: none"> Residual EaB \geq 50% Residual Tensile strength \geq 50% 		

CARE for HL-LHC Project


□ Tensile tests performed on 1st irradiation samples

Cable Type	Manufacturer	Number of tested specimens					
		Jackets			Insulation		
		Total	Valid	Share of valid [%]	Total	Valid	Share of valid [%]
NE8	NOVACAVI	275	184	67	22	15	68
NE48	DRAKA	463	337	73	114	67	59
NE48	2M KABLO	492	408	83	341	225	66
CGN50	RFS	37	32	86	-	-	-
HCA78	RFS	36	33	92	-	-	-
PH3SJ	POLYCAB	41	38	93	112	65	58

Most used cable types (33%) in HL-LHC Project




□ Results trend on cable degradation



CARE for HL-LHC Project

Results comparison per manufacturer


Comparison Tensile properties of the NE48 Insulation from Draka and 2M Kablo




CARE for HL-LHC Project

□ Dosimetry issue on 1st irradiation campaign

Facility dose Measurement



CERN measurement (RPL)



Target Dose [kGy]	Dose Facility [kGy] ⁴	R2E		
		Dosimeter	Dose [kGy] ⁵	Error
100	107	D1-0.1	78	27 %
		D2-0.1	89	17 %
		D3-0.1	88	18 %
200	216	D1-0.2	171	21 %
		D2-0.2	181	16 %
		D3-0.2	176	19 %
500	512	D1-0.5	270	47 %
		D2-0.5	359	30 %
		D3-0.5	359	30 %
1000	1093	D1-1	681	38 %
		D2-1	711	35 %
		D3-1	641	41 %
2000	2112	D1-2	754	64 %
		D2-2	826	61 %
		D3-2	730	65 %

(4) Dose calculated by facility via 2 alanine dosimeters (2 positions)

(5) Measured by R2E at CERN after an ultrasonic bath

CARE for HL-LHC Project



EDMS 2720997	Vers. 0.1	Status See EDMS
-----------------	--------------	--------------------

Visibility: SENSITIVE

Results applying acceptance criteria

Cable	Cable component	500kGy Facility	500kGy CERN
NE8 NV	jacket	do not pass*	do not pass
NE48 DR	jacket	pass	pass
NE48 DR	insulation	pass	do not pass
NE48 2M	jacket	pass	pass
NE48 2M	insulation	pass	pass
PH3SJ Polycab	jacket	pass	n/a
PH3SJ Polycab	insulation	do not pass	n/a

* Production defect discovered in the cable jacket

OCCUPATIONAL HEALTH & SAFETY AND ENVIRONMENTAL PROTECTION UNIT
Occupational Health and Safety



REPORT
NOVACAVI defective cable batch

In this document, tensile test results and digital microscopy images of NE8 cable jacket supplied by NOVACAVI are reported. The study revealed that the material is defective and does not meet CERN requirements with regard to mechanical properties.

Prepared by: F. Bortoletto (HSE-OHS) M. Kranjčević (HSE-OHS) B. Ruiz Palenzuela (HSE-OHS)	Checked by: A. Danyliuk (HSE-OHS) S. Flateraaker (SCE-SSC) C. Garino (SCE-SSC) S. Sgobba (EN-MME)	Approved by: J. Gascon (HSE-OHS)
--	---	-------------------------------------

Distribution to



B. Delille, Y. Loertscher, S. Roesler – HSE management
M. Capeans, C. Garino – SCE management
K. Foraz, M. Nonis – EN management
A. Unnervik, S. Guerri Dall'Oro – IPT-PI





CARE for HL-LHC Project

□ Calculations

- Working closely with R2E group on dosimetry & FLUKA for artificial irradiation



- Math analysis: statistics, data correlation, models



CARE for HL-LHC Project

❑ Database fully operational in CERN environment

- Created with the guidance of the HL-LHC quality control group
- Tracking CARE elements
 - ✓ Cables and cable components (jacket & insulation)
 - ✓ Cable bundles
 - ✓ Dosimeters
 - ✓ Raw Materials
- EDMS Node
 - ✓ Items & assets (cables, materials, etc.)
 - ✓ Documents (specifications, test reports, etc.)
 - ✓ Projects (campaigns, documentation, etc.)
- Infor, MTF, EAM Light
 - ✓ Asset properties
 - ✓ Steps
- EAM store representing the physical storage space
- Labels with a QR code



Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Actions: Edit | History

External Links: No external data link exists

Property Values

Property	Nominal Value	Value	Unit
Campaign		20-08	Cable irradiation test
Origin		BE-EA	
SCEM Code		N/A	
Drum Number CERN		N/A	
Drum Number Supplier		50671	
Production Date		2020/W07	
Color		Black	
Diameter [mm]		28	
Length [m]		1	

Equipment Identifier: HCPPCAC001-N4000100
Other Identifier: 00-NE8-N-drum
Description: NE8 Cable

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Actions: Back to list | Edit | Repeat step

Step Generic Data

Step ID	Description	Traceability	Other name	Status	Result	Completed on	Provided by	Responsible	Open in EAM Light	Executed by
10	Traceability			Done	Ok	2021-02-23			29432331	ADANYLIU

Comments

Step Documents

EDMS DOCUMENTS

ID	Title	Status
> 2578312 v.1	CERN specification matrix	In Work
> 2593189 v.1	Novacavi - NE8 - Test Report	In Work

Per page: 5 | 1-2 of 2

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Actions: Add extra step

Workflow Diagram: No workflow diagram is defined for this equipment

Workflow Steps

Step ID	IR/E	Other name	Description	Status	Result	Last Repeated	INC
5	()		Traceability	Done	Ok		
10	()		Ageing: irradiation in tunnels (*)	Cancelled	Cancelled		
20	()		Artificial ageing: irradiation (*)	Cancelled	Cancelled		
30	()		Artificial ageing: thermal ageing (*)	Cancelled	Cancelled		
40	()		Specimen preparation	Done	Ok		
50	()		Tensile test (TT) (*)	Done	Ok		
60	()		Oxidation induction time (OIT) test (*)	Cancelled	Cancelled		

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

- Campaigns
 - [A1] AD HORN CABLE assessment request
 - HCPPCAC000-CR000006 - AD HORN CABLE
 - HCPPCAC000-CR000007 - AD HORN CABLE
 - HCPPCAC000-CR000001 - AD HORN CABLE Jacket
 - 2611977 (v.1) Tensile Test Report AD HORN CABLE Jacket Reference
 - HCPPCAC000-CR000002 - AD HORN CABLE Insulation
 - HCPPCAC000-CR000003 - AD HORN CABLE Jacket
 - HCPPCAC000-CR000004 - AD HORN CABLE Insulation
 - HCPPCAC000-CR000008 - AD HORN CABLE
 - HCPPCAC000-CR000005 - AD HORN CABLE Jacket
 - HCPPCAC000-CR000006 - AD HORN CABLE Insulation
 - 2609505 (v.1) AD Horn cable assessment request
 - [A2] CLP25 development
 - [A3] Cable assessment MPPE
 - [A4] Cable assessment PVC Cable East Area
 - [C1] TK-NC-working-grp
 - [P1] PIEP TT procedure harmonization
 - [R1] 20-08 Cable irradiation test to derive cable ageing
 - Macrobundles
 - Bundles
 - Cables
 - 2M Kablo - NE48
 - Draka - NE48
 - Novacavi - NE8
 - HCPPCAC003-RF000001 - HCA78-50JFN Cable
 - 2593098 (v.1) RFS - HCA78-50JFN - TDS
 - HCPPCAC005-PY000001 - PH3SJ Cable
 - HCPPCAC005-PY000002 - PH3SJ Cable
 - HCPPCAC004-RF000001 - CGN50 Cable
 - Cable Components
 - 2599880 (v.1) Other ID for 20-08
 - [R2] 21-02 Cable irradiation test to derive cable ageing
 - [S1] TT with more specimens
 - [T1] TDC2 campaign
 - Stored

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Actions: Edit | History

External Links: No external data link exists

Property Values

Property	Nominal Value	Value	Unit
Campaign		20-08	Cable irradiation test
Origin		BE-EA	
SCEM Code		N/A	
Drum Number CERN		N/A	
Drum Number Supplier		50671	
Production Date		2020/W07	
Color		Black	
Diameter [mm]		28	
Length [m]		1	

Equipment Identifier: HCPPCAC001-N4000100
Other Identifier: 00-NE8-N-drum
Description: NE8 Cable

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Actions: Back to list | Edit | Repeat step

Step Generic Data

Step ID	Description	Traceability	Other name	Status	Result	Completed on	Provided by	Responsible	Open in EAM Light	Executed by
10	Traceability			Done	Ok	2021-02-23			29432331	ADANYLIU

Comments

Step Documents

EDMS DOCUMENTS

ID	Title	Status
> 2578312 v.1	CERN specification matrix	In Work
> 2593189 v.1	Novacavi - NE8 - Test Report	In Work

Per page: 5 | 1-2 of 2

Navigation: Main, Made of, Equipment data, Manufacturing, Operation, Documents, History, Map

Actions: Add extra step

Workflow Diagram: No workflow diagram is defined for this equipment

Workflow Steps

Step ID	IR/E	Other name	Description	Status	Result	Last Repeated	INC
5	()		Traceability	Done	Ok		
10	()		Ageing: irradiation in tunnels (*)	Cancelled	Cancelled		
20	()		Artificial ageing: irradiation (*)	Cancelled	Cancelled		
30	()		Artificial ageing: thermal ageing (*)	Cancelled	Cancelled		
40	()		Specimen preparation	Done	Ok		
50	()		Tensile test (TT) (*)	Done	Ok		
60	()		Oxidation induction time (OIT) test (*)	Cancelled	Cancelled		

Conclusions

CARE roadmap

□ Deliverables *short term*

- ✓ Technical report on 1st irradiation campaign
- ✓ Tensile Tests & Technical reports on 2nd irradiation campaign
- ✓ Correlation and technical analyses from results obtained in both campaigns
- ✓ Technical report with cable requirements, tests methods and qualification acceptance criteria applicable for HL-LHC project (to be agreed)
- ✓ Prepare qualification campaign from HL-LHC selected manufacturers

□ Deliverables *long term*

- ✓ Prepare natural irradiation campaign in CERN facilities with similar doses as HL-LHC simulations
- ✓ Extract and test placed samples from RIAC in SPS (TS1+ & TDC2 tunnels)
- ✓ Research on the factor 5 used historically for artificial & natural irradiation
- ✓ Establish first lifetime models from all data & experience obtained from irradiation campaigns and qualification processes
- ✓ Prepare condition monitoring for HL-LHC operation

CARE Benefits

- ✓ **Extending cable lifetime**
 - Reduction on cable consumption (*material & procurement*)
 - Decreasing works required for removal & installation
 - Lowering personnel stay in High Radiation Areas during works (*Personnel Dose*)
 - Optimizing resources (*material, manpower & duration*) required in LS & TS schedules
 - Reduction of radioactive waste (*treatment of activated cables*)
- ✓ **Improvement in cable quality assurance**
- ✓ **Expertise on cable ageing testing techniques & ageing mechanisms**
- ✓ **Knowledge on polymers & additives behavior under radiation**
- ✓ **Experience on Qualification procedures**
- ✓ **Reference database for studied cables**
 - TS, data sheet, tests records, FAT, SAT, control monitoring

CARE challenges

□ Technical topics

• CPR cables (Cca-s2,d1,a2)

- ✓ Higher amount of flame retardants and solids in polymers (ATH, M...s) impacting other cable properties
- ✓ Polymers qualified for radiation environment (Yellow Book) m...e to pass CPR
- ✓ CPR certified cables lower performance in terms of mer...ues and/or radiation resistance

• Artificial irradiation

- ✓ Improve monitoring radiation on bundles in ext...
- ✓ Improve shipping conditions (shipment dur...ing, time after radiation)

• Tensile Tests improvements

- ✓ Pneumatic grips, hair pins techn...xtensometer, etc
- ✓ Specimen insulation prepar...

□ Scientific topics

• Develop other test...es on cable ageing

- ✓ Indentation...rometry, FTIR, TGA,...
- ✓ For cor...ng, non destructible

• Radiati...

- ✓ Accu...simeters for high radiation doses above 1MGy
- ✓ Research on applied safety factor 5 among artificial vs natural radiation
- ✓ Natural and Artificial irradiation at CERN

All ideas/suggestions welcome!!!

Acknowledgement

CARE team

S. Sgobba & EN-MME lab team

M. Tabourelli & TE- VSC lab team

HSE ENV lab team,

R. Garcia & G. Lerner, Y. Aguiar (R2E),

M. Ferrari (R2M)

THANK YOU
FOR YOUR ATTENTION