



# Cable Irradiation Activity

J. Gascon for CARE project

Special thanks to I. Aviles Santillana, M. Ferrari, H. Garcia Gavela, R. Garcia Alia, C. Garino, G. Lerner, S. Sgobba, M. Taborelli & CARE team





12th HL-LHC Collaboration meeting, Uppsala, 19-22 September 2022


# Introduction



## Historical perspective (until 1997)




## 2002-2002)




structuring of material section  
essive reduction of resources

## Historical perspective (after 2002)



## Historical perspective (2010-2015)



# History

## ➤ CARE Working Group 2016-2019

- Activity taken by HSE unit
- Followed recommendation proposed by RIACWG

## ➤ CARE Project 2019-

- **Leader:** J. Gascon
- **Team members:**



**Berta**  
**RUIZ PALENZUELA**  
Materials Eng.



**Federica**  
**BORTOLETTO**  
Materials Eng.



**Dr. Marija**  
**KRANJCEVIC**  
PhD in Computing

# Cable Ageing Research (CARE) Project

- ❑ Long-lead Research programme on cable ageing
- ❑ Focussed to Rad-Hard cables
- ❑ Oriented mainly on new cables procurement
- ❑ Seeking predictive maintenance oriented to reduce cable replacements
- ❑ Enhancing decision making process in terms of expected cables lifetime

**Main Objective: extend cable lifetime procuring the most appropriate cables for CERN operations**

- Determining cable “weathering” installation & operation conditions (*cable stressors*)
- Defining appropriate technical requirements and tests procedures in cable procurement bids
- Providing Quality control & acceptance criteria on cable procurement
- Assessing cable degradation during beam operation (condition monitoring)
- Tracing logbook during all cable lifecycle (complete cable life data over years)
- Establishing lifetime models for cables from cable life data analysis

# Cable design considerations







# Cable Design

## ➤ Cable applications at CERN

- HV power
- LV power
- DC power (*Power converters & magnets*)
- Instrumentation & Control
- Speciality (*RF, experimental areas, others*)
- Safety (*lighting, monitoring, safety systems*)
- *IT & office (commercial products)*
- *Grounding*

## ➤ Cable Stressors

- **Temperature**
- Humidity
- **Chemicals** (oxygen, ozone, lubricants,...)
- **Ionising radiation** (*UV included*)
- **Electrical** (*ohmic heating, voltage insulation stress*)
- **Mechanical** (*bending, squeezing, vibration*)





# Cable Design

## ➤ Cable main components

- Conductors (electrical): *copper, aluminium*
- Insulation (electrical): *polymers*
- Shielding (electrical): *foil and/or braided wires (Al, Cu)*
- Jacket (mechanical, chemical, fire): *polymers*

## ➤ Additional components


- Fillers, binder or bedding: *mechanical stability*
- Tapes, semiconductors: *electrical, mechanical or fire*
- Armouring: *mechanical protection*

## ➤ Typical Polymers cable Industry

(halogen free)

- Ethylene vinyl acetate (EVA)
- Cross-linked polyethylene/polyolefin (XLPE / XLPO)
- Low and High density polyethylene (LDPE / HDPE)
- Ethylene propylene based elastomers (EPR / EPDM)
- Polypropylene (PP)
- Polyphenylene oxide (PPO)
- Polyphenylene ether (PPE)
- Butyl rubber (BR)
- Polyimide (Kapton®)
- Silicone rubber (SiR)
- Polyether ether ketone (PEEK)
- Polyurethane rubber (PUR)

## ➤ Additives (antioxidants, flame retardant, stabilizers)



# Radiation effects

## ➤ Ionizing radiation effects on Polymers

- **Formation of free radicals:** depending on chemical structure, crystallinity, dose rate, solvent content, additives, plasticizer, stabilizers, temperature, oxygen levels, humidity.
- **Formation of hydrogen & light hydrocarbon**
- **Formation of C-C bonds between molecules (crosslinking)**
- **Rupture of C-C bond (chain scission)**
- **Increase in unsaturation**
- **Breakdown of crystalline structure**
- **Discoloration**
- **Oxidation**

## ➤ Synergistic effect

- Simultaneous stressors damage higher than sequential equivalent stressor damage separately:  
*Temperature & radiation more damage than temperature and after radiation for same quantities*

Not irradiated



5x10<sup>6</sup> Gy



10<sup>7</sup> Gy



In the SPS tunnel:



# CARE activities for HL-LHC Project



# Performed activities

## ➤ Preparation of cable qualification process for HL-LHC cables procurement

### • Strategy

- ✓ Inputs from R2E for cable radiation levels expected in HL-LHC areas
- ✓ Preparation of Procurement documents for Rad-tolerant cables (new 3.5MGy cable category)
- ✓ Establishing qualification criteria and acceptance criteria for cables on ageing (radiation)

### • Tests procedures

- ✓ Tests techniques for cable assessment reviewed
- ✓ Test techniques fully defined particularly on test parameters not defined by standards
- ✓ Ageing radiation methods definition according to expected cable radiation levels in HL-LHC areas

### • Tests execution

- ✓ Ageing samples at CERN & in external facilities
- ✓ Specimen preparation for testing after ageing
- ✓ Testing in CERN labs
- ✓ Tracking data results in database
- ✓ Qualification practice campaigns on available cables at CERN

### • Analysis



- ✓ Technical report from test results
- ✓ Statistical studies improving reliability of tests

# R2E inputs for HL-LHC cables



## ➤ R2E WG FLUKA simulations

(June 2021)

### IR1



### IR5



Courtesy of G. Lerner, SY-STI

# Qualification Criteria

## ➤ Testing methods & acceptance criteria



	<b>ageing Method</b>	<b>Source ageing method</b>	<b>Acceptance criteria</b>	<b>International standards</b>				
<b>Reference Stage</b>		IEC 60502	<ul style="list-style-type: none"> <li>EaB <math>\geq</math> 125% (sheath)</li> <li>EaB <math>\geq</math> 200 % (insulation)</li> <li>Tensile strength <math>\geq</math> 9MPa</li> </ul>	According to IEC 60502 <table border="1"> <tr> <td><b>sheath LSZH</b></td> <td><b>insulation XLPE</b></td> </tr> <tr> <td> <ul style="list-style-type: none"> <li>EaB <math>\geq</math> 125%</li> <li>Tensile strength <math>\geq</math> 9MPa</li> </ul> </td> <td> <ul style="list-style-type: none"> <li>EaB <math>\geq</math> 200%</li> <li>Tensile strength <math>\geq</math> 12MPa</li> </ul> </td> </tr> </table>	<b>sheath LSZH</b>	<b>insulation XLPE</b>	<ul style="list-style-type: none"> <li>EaB <math>\geq</math> 125%</li> <li>Tensile strength <math>\geq</math> 9MPa</li> </ul>	<ul style="list-style-type: none"> <li>EaB <math>\geq</math> 200%</li> <li>Tensile strength <math>\geq</math> 12MPa</li> </ul>
<b>sheath LSZH</b>	<b>insulation XLPE</b>							
<ul style="list-style-type: none"> <li>EaB <math>\geq</math> 125%</li> <li>Tensile strength <math>\geq</math> 9MPa</li> </ul>	<ul style="list-style-type: none"> <li>EaB <math>\geq</math> 200%</li> <li>Tensile strength <math>\geq</math> 12MPa</li> </ul>							
<b>Thermal Ageing Stage</b>	Thermal ageing 42 days at 100°C	Temperature, time and oven requirements are taken from IEC 60811-408	<ul style="list-style-type: none"> <li>Residual EaB <math>\geq</math> 70%</li> <li>OIT &gt; 2 minutes</li> </ul>	According to IEC 60811-408 Applicable for wires, materials to be rolled into coils, no cracks to be obtained after the thermal ageing				
<b>Radiation Resistance Stage</b>	Gamma Irradiation Dose 3.5 MGy (dose rate 1Gy/s)	IEC 60544-2	<ul style="list-style-type: none"> <li>EaB <math>\geq</math> 100 % (sheath)</li> <li>Residual EaB <math>\geq</math> 50% (insulation)</li> <li>Residual Tensile strength <math>\geq</math> 50%</li> </ul>	According to IEC 60544-2 <ul style="list-style-type: none"> <li>Residual EaB <math>\geq</math> 50%</li> <li>Residual Tensile strength <math>\geq</math> 50%</li> </ul>				

# Irradiation ageing experience

## ➤ Artificial irradiation with cable bundles



- ✓ R2M framework contract used for 2 campaigns
- ✓ Facility for 1<sup>st</sup> campaign Germany
- ✓ Facility for 2<sup>nd</sup> campaign France
- ✓ Difficulties due to COVID (facilities overbooked for medical)
- ✓ 1<sup>st</sup> campaign sent out in May 2021- Cable bundles received in September 2021
- ✓ 2<sup>nd</sup> campaign sent out in October 2021- Cable bundles received in May 2022
- ✓ Technical report on 1<sup>st</sup> campaign released
- ✓ Tests on 2<sup>nd</sup> campaign ongoing

FORM NO.	REV.	VALIDITY
2560544	0.4	FINAL
REFERENCE 20-08		

 CERN CH1211 Geneva 23 Switzerland  


Technical Requirements		
Irradiation test		
<b>20-08</b>		
<b>Cable irradiation test to derive Cable Ageing</b>		
Abstract		
This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables will be irradiated by <sup>60</sup> Co source with 5 gamma dose steps in range between 0.1 MGy and 2 MGy.		
<b>KEYWORDS</b> #gamma #2MGy #cables		
DOCUMENT PREPARED BY: David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]	DOCUMENT CHECKED BY: Jose Gascon [HSE-OHS-IB]	DOCUMENT APPROVED BY: Matteo Ferrari [SY-STI-TCD]

FORM NO.	REV.	VALIDITY
2632455	2.0	FINAL
REFERENCE 21-02		

 CERN CH1211 Geneva 23 Switzerland  


Technical Requirements		
Irradiation test		
<b>21-02</b>		
<b>Cable irradiation test to derive Cable Ageing: second test at lower dose rate</b>		
Abstract		
This document describes the cable irradiation campaign targeting the qualification procedure related to the radiation resistance of 3 cable types from 5 different suppliers and explain the radiation requirements listed in IS23. Cables and materials for cable manufacturing will be irradiated using <sup>60</sup> Co gamma source with 5 dose steps in range between 0.1 MGy and 2 MGy, at a dose rate of 1 kGy/h. This test follows a previous campaign performed at a dose rate of 3.6-5 kGy/h (irradiation test 20-08) and aims at assessing dose rate effects in cable samples.		
<b>KEYWORDS</b> #gamma #2MGy #cables #HL #LHC #doserate #1kGy/h		
DOCUMENT PREPARED BY: David Vázquez [HSE-OHS-IB] Artem Danyliuk [HSE-OHS-IB]	DOCUMENT CHECKED BY: Jose Gascon [HSE-OHS-IB]	DOCUMENT APPROVED BY: Matteo Ferrari [SY-STI-TCD]



# Irradiation ageing experience #1

## ➤ 1<sup>st</sup> Irradiation campaign objectives *(bundles received in September 2021)*

### • Type of cables & manufacturers

- ✓ NE8 & NE48 types selected as most used type in HL-LHC project *(source EN-EL Group)* & cables available in CERN stores
- ✓ NE48 type includes 2 different manufacturers to assess influence of manufacturer
- ✓ PH3SJ type from Polycab manufacturer (contract signed by CERN stores) to assess radiation hardness
- ✓ CGN50 type produced with popular Megolon S304 (radiation resistant)

### • Dose rate influence 1Gy/s (~3.6kGy/h)

- ✓ 5 Dose steps 0.1 - 0.2 - 0.5 - 1 - 2 MGy increase data
- ✓ Confirm degradation trend of each cable type & manufacturer
- ✓ Confirm cable degradation around 500kGy

### • Ageing methods

- ✓ 3 Combinations: Radiation only , Thermal ageing & radiation later, Radiation & thermal ageing later
- ✓ Thermal ageing 168h as requested in IEC-60502
- ✓ Assess influence of cable stressors and combination of them

### • Pilot campaign #1

- ✓ Bundles dosimetry (3 dosimeters per bundle) & dose from facility
- ✓ Get experience from irradiation facility for cable qualification



# Testing

## ➤ Tensile Tests (TT)

### • Procedure

- ✓ CARE procedure ([EDMS no 2705496](#)) for specimens preparation and test
- ✓ Dumbbell specimens type 5A & 5B from jackets






Figure A.2 — Type 5A and 5B test specimens

Specimen type	5A	5B
$l_3$ Overall length	$\geq 75$	$\geq 35$
$b_2$ Width at ends	$12.5 \pm 1$	$6 \pm 0.5$
$l_1$ Length of narrow parallel-sided portion	$25 \pm 1$	$12 \pm 0.5$
$h_1$ Width at narrow portion	$4 \pm 0.1$	$2 \pm 0.1$
$r_1$ Small radius	$8 \pm 0.5$	$3 \pm 0.1$
$r_2$ Large radius	$12.5 \pm 1$	$3 \pm 0.1$
$L$ Initial distance between grips	$50 \pm 2$	$20 \pm 2$
$L_0$ Gauge length	$20 \pm 0.5$	$10 \pm 0.2$
$h$ Thickness	$2 \pm 0.2$	$1 \pm 0.1$

- ✓ 50 mm tubes from insulation (L0=10 mm)



### OCCUPATIONAL HEALTH & SAFETY AND ENVIRONMENTAL PROTECTION UNIT

Choose an item.

### PROCEDURE

Testing procedure for the tensile testing of polymeric components of the cables

Prepared by:

Checked by:

Approved by:

Artem Danyliuk

Berta Ruiz Palenzuela  
Federica Bortoletto  
Marija Kranjcevic

Jose Gascon

Distribution to

Click or tap here to enter text.



# Testing

## ➤ Tensile Tests (TT)

### • Equipment (MME lab)

- ✓ Machine Zwick/Roell Z010
- ✓ Grips 8106 500N
- ✓ 2 different jaws
- ✓ Limmes video-extensometer

### • Test



Grips 8106 500N







Jaws for jackets



Jaws for insulations

# Testing

## ➤ Other performed test techniques



# Tests results

## ➤ Tensile tests performed on 1<sup>st</sup> irradiation samples

Cable Type	Manufacturer	Number of tested specimens					
		Jackets			Insulation		
		Total	Valid	Share of valid [%]	Total	Valid	Share of valid [%]
NE8	NOVACAVI	275	184	67	22	15	68
NE48	DRAKA	463	337	73	114	67	59
NE48	2M KABLO	492	408	83	341	225	66
CGN50	RFS	37	32	86	-	-	-
HCA78	RFS	36	33	92	-	-	-
PH3SJ	POLYCAB	41	38	93	112	65	58

Most expected cable types (33%) in HL-LHC Project



EDMS 2720276	Ver. 1.0	Status See EDMS
-----------------	-------------	--------------------

Visibility: SENSITIVE

**OCCUPATIONAL HEALTH & SAFETY AND ENVIRONMENTAL PROTECTION UNIT**  
Occupational Health and Safety

**TECHNICAL REPORT**  
**20-08 Cable irradiation test to derive cable ageing**


This document details all the findings, results and issues related to the pilot campaign aimed at advancing the knowledge on degradation of polymeric cable components. Artificial irradiation and thermal ageing of cables were performed under controlled conditions and monitoring of materials degradation was performed via tensile testing.

Prepared by: F. Bortoletto (HSE-OHS) A. Danyliuk (HSE-OHS) M. Kranjčević (HSE-OHS) B. Ruiz Palenzuela (HSE-OHS)	Checked by: R. Garcia Alia (SY-STI) M. Ferrari (SY-STI) Y. Aguiar (SY-STI) G. Lerner (SY-STI) S. Sgobba (EN-MME)	Approved by:  J. Gascon (HSE-OHS)
Distribution to B. Deille - HSE management		




# Tests results


## ➤ Results trend on cable degradation




(a) Draka NE48 jacket.




(b) Draka NE48 insulation.




(c) 2M Kablo NE48 jacket.




(d) 2M Kablo NE48 insulations.




(a) Draka NE48 jacket.




(b) Draka NE48 insulation.




(c) 2M Kablo NE48 jacket.



(d) 2M Kablo NE48 insulation.



(e) Novacavi NES jacket.




(f) Novacavi NES insulation.

# Tests results

## ➤ Results comparison per manufacturer

Comparison Tensile properties of the NE48 Insulation from Draka and 2M Kablo








# Tests results

## ➤ Acceptance criteria results

Cable	Cable component	500kGy Facility
NE8 NV	sheath	do not pass*
NE48 DR	sheath	pass
NE48 DR	insulation	pass
NE48 2M	sheath	pass
NE48 2M	insulation	pass
PH3SJ Polycab	sheath	pass
PH3SJ Polycab	insulation	do not pass



### Production defect discovered in NV cable sheath



EDMS 2720997	Vers. 0.1	Status See EDMS
-----------------	--------------	--------------------

Visibility: SENSITIVE

OCCUPATIONAL HEALTH & SAFETY AND  
ENVIRONMENTAL PROTECTION UNIT  
Occupational Health and Safety

#### REPORT

#### NOVACAVI defective cable batch

In this document, tensile test results and digital microscopy images of NE8 cable jacket supplied by NOVACAVI are reported. The study revealed that the material is defective and does not meet CERN requirements with regard to mechanical properties.

Prepared by: F. Bortoletto (HSE-OHS) M. Kranjčević (HSE-OHS) B. Ruiz Palenzuela (HSE-OHS)	Checked by: A. Danyliuk (HSE-OHS) S. Flateraaker (SCE-SSC) C. Garino (SCE-SSC) S. Sgobba (EN-MME)	Approved by: J. Gascon (HSE-OHS)
--	---	-------------------------------------


#### Distribution to

B. Delille, Y. Loertscher, S. Roesler – HSE management  
M. Capeans, C. Garino – SCE management  
K. Foraz, M. Nonis – EN management  
A. Unnervik, S. Guerri Dall'Oro – IPT-PI


# Tests results

## ➤ Dosimetry findings

Facility dose Measurement



CERN measurement (RPL)



Target Dose [kGy]	Dose Facility [kGy] <sup>4</sup>	R2E		
		Dosimeter	Dose [kGy] <sup>5</sup>	Error
100	107	D1-0.1	78	27 %
		D2-0.1	89	17 %
		D3-0.1	88	18 %
200	216	D1-0.2	171	21 %
		D2-0.2	181	16 %
		D3-0.2	176	19 %
500	512	D1-0.5	270	47 %
		D2-0.5	359	30 %
		D3-0.5	359	30 %
1000	1093	D1-1	681	38 %
		D2-1	711	35 %
		D3-1	641	41 %
2000	2112	D1-2	754	64 %
		D2-2	826	61 %
		D3-2	730	65 %



<sup>(4)</sup> Dose calculated by facility via 2 alanine dosimeters (2 positions)

<sup>(5)</sup> Measured by R2E at CERN after an ultrasonic bath



# Tests results

## ➤ Other analysis performed

- Working closely with R2E group on dosimetry & FLUKA for artificial irradiation



- Math analysis: statistics, data correlation, models



# Tests results

## ➤ Results tracked in CARE Database

- Created with the guidance of the HL-LHC quality control group
- Tracking CARE elements
  - ✓ Cables and cable components (jacket & insulation)
  - ✓ Cable bundles
  - ✓ Dosimeters
  - ✓ Raw Materials
- EDMS Node
  - ✓ Items & assets (cables, materials, etc.)
  - ✓ Documents (specifications, test reports, etc.)
  - ✓ Projects (campaigns, documentation, etc.)
- Infor, MTF, EAM Light
  - ✓ Asset properties
  - ✓ Steps
- EAM store representing the physical storage space
- Labels with a QR code



**Campaigns**

- ▶ [A1] AD HORN CABLE assessment request
  - ▶ HCPPCAC000-CR000006 - AD HORN CABLE
  - ▶ HCPPCAC000-CR000007 - AD HORN CABLE
  - ▶ HCPPCAC000-CR000001 - AD HORN CABLE Jacket
    - ▶ 2611977 (v.1) Tensile Test Report AD HORN CABLE Jacket Reference
  - ▶ HCPPCAC000-CR000002 - AD HORN CABLE Insulation
  - ▶ HCPPCAC000-CR000003 - AD HORN CABLE Jacket
  - ▶ HCPPCAC000-CR000004 - AD HORN CABLE Insulation
  - ▶ HCPPCAC000-CR000005 - AD HORN CABLE
  - ▶ HCPPCAC000-CR000005 - AD HORN CABLE Jacket
  - ▶ HCPPCAC000-CR000006 - AD HORN CABLE Insulation
  - ▶ 2609505 (v.1) AD Horn cable assessment request
- ▶ [A2] CLP25 development
- ▶ [A3] Cable assessment MPPE
- ▶ [A4] Cable assessment PVC Cable East Area
- ▶ [C1] TK-NC-working-grp
- ▶ [P1] PIEP TT procedure harmonization
- ▶ [R1] 20-08 Cable irradiation test to derive cable ageing
  - ▶ Macrobundles
  - ▶ Bundles
  - ▶ Cables
    - ▶ 2M Kablo - NE48
    - ▶ Draka - NE48
    - ▶ Novacavi - NE8
    - ▶ HCPPCAC003-RF000001 - HCA78-50JFN Cable
    - ▶ 2593098 (v.1) RFS - HCA78-50JFN - TDS
    - ▶ HCPPCAC005-PY000001 - PH3SJ Cable
    - ▶ HCPPCAC005-PY000002 - PH3SJ Cable
    - ▶ HCPPCAC004-RF000001 - CGN50 Cable
  - ▶ Cable Components
    - ▶ 2598880 (v.1) Other ID for 20-08
  - ▶ [R2] 21-02 Cable irradiation test to derive cable ageing
  - ▶ [S1] TT with more specimens
  - ▶ [T1] TDC2 campaign
- ▶ Stored

Equipment data | Manufacturing | Operation | Documents | History | Map

Actions: Edit | History

External Links: No external data link exists

Property Values	Nominal Value	Value	Unit
Property			
Campaign		20-08 Cable irradiation test	
Origin		BE-EA	
SCEM Code		N/A	
Drum Number		N/A	
Drum Number Supplier		50671	
Production Date		2020/W07	
Color		Black	
Diameter [mm]		28	
Length [m]		1	

**Equipment Identifier: HCPPCAC001-N4000100**  
**Other Identifier: 00-NE8-N-drum**  
**Description: NE8 Cable**

Equipment data | Manufacturing | Operation | Documents | History | Map

Actions: Back to list | Edit | Repeat step

Step Generic Data

Step ID	Description	Traceability	Other name	Status	Result	Ok
10	Done			Completed on	2021-02-23	
	Provided by		Open in EAM Light	25432331		
	Responsible		Executed by	ADANYLIU		

Comments

Step Documents

EDMS DOCUMENTS

ID	Title	Status
> 2578312 v.1	CERN specification matrix	In Work
> 2593189 v.1	Novacavi - NE8 - Test Report	In Work

Per page 5 1-2 of 2

Equipment data | Manufacturing | Operation | Documents | History | Map

Actions: Add extra step

Workflow Diagram: No workflow diagram is defined for this equipment

Workflow Steps

Step ID	R/E	Other name	Description	Status	Result	Last Repeated	INC
5	0		Traceability	Done	Ok		
10	0		Ageing: irradiation in tunnels (*)	Cancelled	Cancelled		
20	0		Artificial ageing: irradiation (*)	Cancelled	Cancelled		
30	0		Artificial ageing: thermal ageing (*)	Cancelled	Cancelled		
40	0		Specimen preparation	Done	Ok		
50	0		Tensile test (TT) (*)	Done	Ok		
60	0		Oxidation induction time (OIT) test (*)	Cancelled	Cancelled		

# 1<sup>st</sup> irradiation experience summary

- **Irradiation facility** (R2M framework contract)

- ✓ Shipping going and back should be improved (samples stacked, packing inadequate, time delays, weathering)
- ✓ Packing from CERN to be improved in terms of dimensions
- ✓ Difficulties to obtain clear information from facility (subcontractor)
- ✓ Samples irradiation monitoring to be improved

- **Dosimetry**

- ✓ Mismatching between dosimeters measurements and facility dose calculation
- ✓ Bundles arrangement to be optimised to reduce shielding effect during irradiation
- ✓ Expected shielding effect on bundles mismatching with dosimeters measurements

- **Testing**

- ✓ Extremely difficult to prepare tubes for small cable insulations
- ✓ Slipping prepared insulation tubes in TT machine grips
- ✓ Number of Tensile test should be 10 valid ones per component to obtain reasonable standard deviation in results (<10%)
- ✓ DSC tests on cable insulation were not performed due to machine breakdown

- **Qualification exercise**

- ✓ 2 manufacturers will pass qualification (facility dose measurement)
- ✓ Qualification process allowed detect defective cable batch
- ✓ Applicable CPR class Cca fire requirement might disqualify cables in terms of radiation (Polycab manufacturer)

# Radiation ageing experience #2

## ➤ 2<sup>nd</sup> irradiation campaign objectives *(bundles received in May 2022)*

- **Type of cables & manufacturers**

- ✓ NE8 & NE48 types from same batch than 1<sup>st</sup> campaign
- ✓ NF12, SVA3 & TFA3 type included as samples irradiated naturally in TS1+ & TDC2 tunnels

- **Dose rate lower ~1kGy/h**

- ✓ Same dose steps 0.1 - 0.2 - 0.5 - 1 - 2 MGy
- ✓ Confirm cable degradation around 500kGy is independently of dose rate

- **Ageing methods**


- ✓ Same as 1<sup>st</sup> campaign

- **Dosimetry**

- ✓ 2 extra RPL dosimeters per bundle + 2 RPLs for facility measurement

- **Pilot campaign #2**

- ✓ Dose rate effect
- ✓ Fix parameters to be retained for HL-LHC qualification
- ✓ Confirm shielding effect and dosimetry
- ✓ Correlate all results with 1<sup>st</sup> campaign ones



# 2<sup>nd</sup> Irradiation experience situation

- **Irradiation facility** (R2M framework contract)
  - ✓ Packing was improved delays shorter
  - ✓ Detailed information about radiation but partially clear information from facility (subcontractor)
  - ✓ Maintenance stop cut irradiation during around 10 days
- **Dosimetry**
  - ✓ Confirmed mismatching between dosimeters measurements and facility dose calculation
  - ✓ R2E is looking for an appropriate solution for future
- **Testing**
  - ✓ Tensile tests for cable sheath performed
  - ✓ Insulation cable specimen tubes are prepared awaiting new upgrade of Tensile Test machine
  - ✓ DSC machine repaired tests for 1<sup>st</sup> and 2<sup>nd</sup> on cable insulation are ongoing at this time
- **Reporting**
  - ✓ Analysing tests results from cable sheath on 2<sup>nd</sup> campaign
  - ✓ Correlation with 1<sup>st</sup> campaign ongoing
  - ✓ Drafting report



# CARE Roadmap

## ➤ Complete 2<sup>nd</sup> campaign

- ✓ DSC & TTs on cable insulation by January 23
- ✓ Correlation between both campaign by February 23
- ✓ Technical report by March 23

## ➤ Prepare 3<sup>rd</sup> campaign

- ✓ More Cables & compounds sent to facility by December 22
- ✓ Ageing & Testing by May 23
- ✓ Analyses & report by July 23

## ➤ HL-LHC cable procurement

- ✓ Market Survey by October 22
- ✓ Qualification process from manufacturers starting June 23
- ✓ Irradiation ageing by November 23
- ✓ Testing & qualification process by January 24
- ✓ Technical specification by June 24

# Summary

- Radiation tolerant cables aim reduce cable replacement campaigns
- Qualification process will identify best cable manufacturers
- Work started on preparing qualification for HL-LHC
  - ✓ Development of qualification procedures
  - ✓ Defining acceptance criteria
  - ✓ Getting experience with pilots campaigns on existing cables at CERN
- Short term objectives
  - ✓ Supporting HL-LHC cable procurement
  - ✓ Technical exchange with cable manufacturers
  - ✓ Research on testing and ageing methods
  - ✓ More accurate thresholds based on tests results and correlations



***Thank you for your attention!***

