



*Technical
Infrastructure*

Wed 23/11/22 10:46

Fire alarm on the central SFDIN00513 sextant3+ nothing to see on site, no real alarms. Only the central is in alarm, no detectors. After a little while the alarm could be reset.

Fri 25/11/22 11:01

Several ventilations in East Area, CHARM, IRRAD + and others, stopped for no obvious reason. Only reason found was a signal from the "Fire fighter" that was active for 45 seconds only.

Sun 27/11/22 17:47

Water leak in BA6, caused the cooling station to stop. The magnet was isolated and the cooling station could be started again. See [major Event](#)

Energy consumption

Link to access live 400kV consumption: <https://energy-grafana.app.cern.ch/d/ZHF85zSVz/power?from=now-24h&to=now&orgId=1&kiosk>

Link to see all energy by machine / site: <https://energy.app.cern.ch/charts>

