



## How to plug FCC?

Preliminary study for electricity grid connexion of the FCC project FCC WEEK 2023, London (UK)

Copyright RTE – 2021. Ce document est la propriété de RTE. Toute communication, reproduction, publication même partielle est interdite sauf autorisation écrite du Gestionnaire du Réseau de Transport d'Électricité (RTE)





Vallée de la Chimie – impact étude de zone / raccordement – 10/02/2022

## **European interconnected grid in figures**

Following ENTSOE-E Statistical Factsheet 2021

Total Net Generation Capacity : **1 155 920 MW** FCC supply will represent 0.03 percent (400 MW) Only France : 130 560 MW

Total Net Consumption : **3 186.5 TWh** FCC consumption will represent 0.04 percent (1,2 TWh per year)

Only France : 465.8 TWh









EE 22-1022 – CERN - Projet FCC-ee – 24/11/2022

## FCC electricity demand

••••••

*Power grid connexions* 



## **CERN/LHC : present electricity supply**

#### LHC and other devices are connected to French public grid by 2 lines from BOIS-TOLLOT 400 kV substation

Installed transformation power : 600 MW,

Max authorised power : 290 MW

Reel max consumed : 200MW.

#### 2 points of connexion :

- Main : <u>CERN 400 kV</u>
- Complementary : <u>BOIS-DE-SERVES 400 kV</u>

At each point of LHC installation :

- <u>External back-up supply</u>, delivered in HTA voltage, by 8 links connected to the French distribution grid
- Internal back-up supply, delivered by 8 power groups

Another back-up supply come from Swiss 225 kV substation of VERBOIS (**60 MW**) associated to a global power limit in case of unavailability of Bois-Tollot-Genissiat 400 kV line



## FCC electricity demand : main figures

#### Building

Electricity supply in HTA voltage :

**8 points of connection** of max. 14 MW each for drilling (currently in study by distribution operators)

#### Operating

Global operating supply of 400 MW delivered in HTB :
2 main points of connexion (PH, PL)
+ 1 point for redondancy (PD) with intern mutual back-up

Also to be considered : up to 90 MW demand at historical point of connexion from Bois-Tollot substation.

#### Other solution in study

<u>One unique point of connexion</u> for both FCC (PL) and historical devices from BOIS-TOLLOT substation



## **Existing power grid and points of connexion forecasted**

For each point of connexion, RTE studies <u>at a first step</u> :

- **The available capacity** for power demand (transmission limit of existing infrastructure)
- **The electric infrastucture** to be built to connect the point to the grid (grid extension)



## Grid connexion prestudy results

## Connexion of PD (220 MW) - Nangy (74)

Client -->+- RTE

The 220 MW demand can be delivered by CORNIER substation in **225 kV** voltage.

The forecasted grid extension to be built :

- ✓ 11 km underground line between CORNIER 225 kV substation and PD (design : Al 2000 mm<sup>2</sup>).
- ✓ 1 new circuit breaker cell in CORNIER substation

The studies & civil works will have to deal with some technical crossings like A40 highway and the Arve river.





#### Connexion of PH (220 MW) - Cercier (74)



The 220 MW demand can be delivered from CORNIER-GENISSIAT or CORNIER-MONTAGNY overhead line in **400 kV** voltage.

The forecasted grid extension to be built :

- ✓ 1.6 km double-circuit overhead line between CORNIER-GENISSIAT 400 kV existing line and PH.
- ✓ 1 new 400 kV substation at PH in costumer site



## Connexion of PL (200 MW) - Challex (01)

The 200 MW demand can be delivered from BOIS-TOLLOT-GENISSIAT overhead line in **400 kV** voltage, but will <u>reduce Swiss-France interconnexion capacity</u> (equal to present, if HLC demand will reduce to 90 MW max. at BOIS-TOLLOT historical point of connexion)

The forecasted grid extension to be built :

- ✓ 1.5 km double-circuit overhead line between BOIS-TOLLOT-GENISSIAT 400 kV existing line and PL.
- ✓ 1 new 400 kV substation at PH in costumer site





To BOIS-TOLLOT 400 kV substation

For environnemental purposes (mostly : landscape perception), **underground technology** could be preferred for connexion of points H and L, but :

- It supposed to localise the new 400 kV substation <u>under the</u> <u>existing OHL</u>
- This strategy leads to approximately <u>50% additionnal costs</u>

**A 2-km underground line** between existing 400 kV OHL and costumer site has to be build.



#### **Forecasted costs and delays**

Point of connexion	Voltage	Total grid extension costs	FCC participation	Delay from firm command
PD	225 kV	25 M€	70% or 100% (*)	5 years
PH	400 kV	19 M€	70%	8 years
PL	400 kV	18 M€	70%	8 years
Global		62 M€	43-55 M€	
Option : Underground 400 kV		+ 18 M€	+ 13 M€	

#### Be aware :

Rie

The costs do not include HTB costumer infrastructure (HTB circuit breaker, transformers, etc.) but only public grid extension.

The final costs could vary by +/- 30 percents from the forecast.

These costs are for 400 kV overhead line technology.

(\*) in case of redundancy

EE 22-1022 – CERN - Projet FCC-ee – 24/11/2022

# To go further

Vallée de la Chimie – impact étude de zone / raccordement – 10/02/2022

## **Grid connexion : a regulatory process**





#### **Complementary studies to be led**

#### **Further electrical studies (TFP)**

- Voltage drop (reactive power)
- Short-circuit power capacity
- Protection and safety (overload, short-circuit...)



Study of electrical phenomena such as potential Torsional Interaction against Devices (TI-D)

 Power pulse can damage the turbine shafts of the generators in the electric « neighboroud » (the CIGRE classifies it among the Subsynchronous Oscillations)

To anticipate in reason of studies delay and potential influence on FCC design or grid equipment (capacitors)

Engineering design of infrastructures to buid & legal autorisations (after TFP acceptance)



# Thank you for your attention

Rte Vallée de la Chimie – impact étude de zone / raccordement – 10/02/2022