



Contribution ID: 72

Type: Poster

The End-of-Substructure (EoS) card for the ATLAS Strip Tracker Upgrade –from Design to Production

Thursday 5 October 2023 18:40 (20 minutes)

The ATLAS Strip Tracker for HL-LHC consists of individual modules that host silicon sensors and front-end electronics. The modules are then mounted on carbon-fiber substructures hosting up to 14 modules per side. An End-of-Substructure (EoS) card connects up to 28 data lines to the lpGBT and VL+ ASICs that provide data serialization and 10 GBit/s optical data transmission to the off-detector systems respectively. The EoS is powered by a dedicated Dual-Stage DC-DC converter. With the EoS now moving into production we report on first experiences from production and also give a few lessons learned during the project duration.

Summary (500 words)

The silicon tracker of the ATLAS experiment will be upgraded for the upcoming High-Luminosity Upgrade of the LHC (HL-LHC). The main building blocks of the new strip tracker are modules that consist of silicon sensors and hybrid PCBs hosting the read-out ASICs. The modules are mounted on rigid carbon-fiber substructures, known as staves in the central barrel region and petals in the end-cap regions, that provide common services to all the modules. At the end of each staff or petal side, a so-called End-of-Substructure (EoS) card facilitates the transfer of data, power, and control signals between the modules and the off-detector systems. The module front-end electronics transfer data to the EoS card on 640 MBit/s differential lines. The EoS connects up to 28 data lines to one or two lpGBT chips that provide data serialization and uses a 10 GBit/s versatile optical link (VL+) to transmit signals to the off-detector systems. The lpGBT also recovers the LHC clock on the downlink and generates clock and control signals for the modules. To meet the tight integration requirements in the detector, several different EoS card designs are needed. Custom-made holders and clamps are produced to guide cables and optical fibers as well as to shield the sensors from the opto-electric system. The power to the EoS is provided by a dedicated dual-stage DC-DC package providing 2.5 and 1.2 V to the EoS cards. As the EoS card and its DC-DC-Stage have recently moved towards production, we will report on the first production experiences, results from the large-scale QC (quality control) and some design validation (QA) results. We will also report on the “lessons learned” during the duration of this project.

Authors: PALMELUND, Anders (University of Copenhagen (DK)); BOEBEL, Artur Lorenz (Deutsches Elektronen-Synchrotron (DE)); GARVEY, Cameron Michael (University of Cape Town (ZA)); CESLIK, Harald (Deutsches Elektronen-Synchrotron (DE)); GREGOR, Ingrid-Maria (DESY & Bonn University); KEAVENEY, James Michael (University of Cape Town (ZA)); STROM, Lars Rickard (Deutsches Elektronen-Synchrotron (DE)); STANITZKI, Marcel (Deutsches Elektronen-Synchrotron (DE)); VAN DER MERWE, Max Nikoi; DAM, Mogens (University of Copenhagen (DK)); GOETTLICHER, Peter (Deutsches Elektronen-Synchrotron (DE)); GOTFREDSEN, René Stenow (University of Copenhagen (DK)); RUIZ DAZA, Sara (Deutsches Elektronen-Synchrotron (DE)); DIEZ CORNELL, Sergio (Deutsches Elektronen-Synchrotron (DESY)); SCHMITT, Stefan (Deutsches Elektronen-Synchrotron (DE))

Presenter: RUIZ DAZA, Sara (Deutsches Elektronen-Synchrotron (DE))

Session Classification: Thursday posters session

Track Classification: Production, Testing and Reliability