

Technical Infrastructure (TI)					
Facility Coordinator last week		Jesper Nielsen			
Facility Coordinator this week		Ronan Ledru			
Statistics					
Alarms	3956				
Phone calls	526	Incoming	317	Outgoing	209
ODMs	102				
Facility Status					
Summary	Less calls but a lot of events				
Issues	<p>Mon 10/04/23 - 16:46 Stop of Isolde ventilation due to an issue on the SITOP (batterie of the PLC) This ventilation has interlocked the beam - see event</p>				
	<p>Tue 11/04/23 - 12:26 Trip of the 18kV breaker EMH104/A2 (BA2) due to issue on the measurement cable Cable has been fixed and breaker switched on - see event</p>				
	<p>Wed 12/04/23 - 22:35 Fire alarms in US15 (4 sensors), evacuation and DSS triggered. The faulty rack Y-09-05-S2 has been found - see event</p>				
	<p>Wed 12/04/23 - 11:32 Hydrocarbons alarm on the WMS-102 (Meyrin), real alarm. Fire brigade sent on site to put a boom</p>				
	<p>Wed 12/04/23 - 20:28 Glitch on the 400kV line between Genissiat and Vieil Moulin 2</p>				
	<p>Thu 13/04/23 - 14:54 Fire alarm in TS54 (SPS) Fire brigade on site, nothing has been found- see event</p>				
Plans					
Intervention Request					
Yes / No	Duration		Preferred date/time		
Reason					
Impact					