



RADIOLOGICAL STUDIES FOR FCCee

Giacomo Lavezzari, Markus Widorski, Pavol Vojtyla, Yousef Husein - CERN HSE-RP

FCC Week 2024, San Francisco

Introduction



Radiological hazards overview

1. Prompt radiation levels in accessible areas:

- Experimental cavern <-> Service cavern
- Experimental cavern <-> Surface building
- RF straight section <-> Klystron galleries
- Injector complex <-> Surface/klystron building
- Accelerator tunnel <-> RF straight section
- Accelerator tunnel <-> Service cavern

2. Residual radiation levels :

- Arcs
- Main beam dumps
- Beamstrahlung dumps
- Positron source
- Collimators
- Injector complex
- Experiments

3. Activation:

- Rock/earth layer
- Tunnel infrastructure (cables, pipes, ducts..)
- Accelerator materials:
 - Arc
 - Collimation systems
 - Dispersion suppressors
 - Masks/collimators
- Equipment inside alcoves
- Water (arc)
- Air :
 - Arc
 - Beam dumps
 - Beamstrahlung dumps
 - RF section
 - Experiments
 - Injector complex
- Cryogenics

Radiological hazards overview

1. Prompt radiation levels in accessible areas:

- Experimental cavern <-> Service cavern
- Experimental cavern <-> Surface building
- RF straight section <-> Klystron galleries
- Injector complex <-> Surface/klystron building
- Accelerator tunnel <-> RF straight section
- Accelerator tunnel <-> Service cavern

2. Residual radiation levels :


- Arcs
- Main beam dumps
- Beamstrahlung dumps
- Positron source
- Collimators
- Injector complex
- Experiments

3. Activation:


- Rock/earth layer
- Tunnel infrastructure (cables, pipes, ducts..)
- Accelerator materials:
 - Arc
 - Collimation systems
 - Dispersion suppressors
 - Masks/collimators
- Equipment inside alcoves
- Water (arc)
- Air:
 - Arc
 - Beam dumps
 - Beamstrahlung dumps
 - RF section
 - Experiments
 - Injector complex
- Cryogenics

Operational objective

(Area accessibility, layout/design for FCCee and FCChh)



Environmental objective



Tasks planned out within the feasibility study

Tasks scheduled for after the feasibility study

Radiological hazards overview

1. Prompt radiation levels in accessible areas:

- Experimental cavern <-> Service cavern
- Experimental cavern <-> Surface building
- RF straight section <-> Klystron galleries
- Injector complex <-> Surface/klystron building
- Accelerator tunnel <-> RF straight section
- Accelerator tunnel <-> Service cavern

2. Residual radiation levels :


- Arcs
- Main beam dumps
- Beamstrahlung dumps
- Positron source
- Collimators
- Injector complex
- Experiments

3. Activation:


- Rock/earth layer
- Tunnel infrastructure (cables, pipes, ducts..)
- Accelerator materials:
 - Arc
 - Collimation systems
 - Dispersion suppressors
 - Masks/collimators
- Equipment inside alcoves
- Water (arc)
- Air:
 - Arc
 - Beam dumps
 - Beamstrahlung dumps
 - RF section
 - Experiments
 - Injector complex
- Cryogenics

Operational objective

(Area accessibility, layout/design for FCCee and FCChh)




Environmental objective




Prompt radiation studies

Prompt radiation levels in accessible areas

Experimental cavern > Surface building (FCChh)



Dose rate within the FCChh service cavern (Averaging done on a 1 m slice 1 m slice)





- Study for ion collisions due to the higher radiation levels compared to e⁻e⁺.
- Chicanes with shielded doors must be implemented to allow access to the service cavern.

The design shall ensure access to the service cavern during beam operation in FCCee+hh.

Prompt radiation levels in accessible areas

Experimental cavern <-> Surface building

(FCChh)




- Study for hadron collisions due to the higher radiation levels compared to e^-e^+ .
- Chicanes and shielded doors must be implemented to allow access to the service cavern.

The design shall ensure access to the service cavern during beam operation in FCCee+hh.

Prompt radiation levels in accessible areas

Experimental cavern <-> Surface building (FCChh)



➤ Prompt radiation from the experimental cavern can reach the surface via the shaft.



- (1) Shielding to be improved at the machine-detector-interface
- (2) Installation of 1m concrete shielding at the top of the shaft

Prompt radiation levels in accessible areas

RF straight section Klystron galleries (Point H and Point L)

- ❖ Simulation aimed to evaluate the accessibility of the prompt radiation
- Operational scenario: beam-gas interaction Cavity X-ray emissions.

- Operational scenario: Complete beam loss under the RF ducts.
- A chicane in the dipole ensures accessibility to the klystron gallery during beam or RF operation.
- The staircase configuration provides a compatible interaction point.




Prompt radiation levels in accessible areas

RF straight section <-> Klystron galleries (Point H and Point L)

- Simulations aimed to evaluate the accessibility of the klystron galleries:
 - **Operational scenario:**
 - Beam-gas interaction
 - Cavity X-ray emissions.
 - **Incidental scenario:**
 - Complete beam loss under the RF ducts.


A chicane in the RF duct ensures accessibility to the klystron gallery during beam or RF operation.

The staircase configuration provides allows a compatible integration design.



Prompt radiation levels in accessible areas

Pre-injector complex position source <-> Surface/klystron building



Positron source - Prompt ambient dose equivalent rate





- Objectively defined radiation areas at the surface of the accessible areas of the accelerator installation.
- Operational and accidental scenarios were evaluated.

Minimum required shielding of 50 cm of concrete and 6.3 m of soil

Prompt radiation levels in accessible areas

Pre-injector complex/Positron source <-> Surface/klystron building






- Objective: non-radiation areas at the surface outside the accelerator installation.
- Operational and incidental scenarios were both evaluated.

Minimum required shielding of 50 cm of concrete and 6.3 m of soil

Residual radiation studies

Residual dose rate

In the arcs






- 10 to 20 uSv/h after a one-hour cool-down period, following one year of ttbar operation.
- No lead shielding against synchrotron radiation is considered in this version.

➤ Possible access to the arcs is provided by additional alcoves located around the photon absorbers.

Residual dose rate

In the arcs



- 10 to 20 $\mu\text{Sv/h}$ after a one-hour cool-down period, following one year of ttbar operation .
- No lead shielding against synchrotron radiation yet considered in this version.

Possible access constraints will be mitigated by additional lead shielding around the photon absorbers.


Activation studies

Air activation *(Preliminary radiological environmental impact assessment for FCCee)*

- **Quantity:** Annual effective dose to the Representative Person from the public.
- **Input:** Activity releases through air from the FCCee arc in ttbar operation (highest releases, no recycling, no filtration).
- **Expected annual effective doses for a generic exposure configuration:**
 - 2.3 TBq/y of ^{41}Ar : **0.1 $\mu\text{Sv/y}$**
 - 60 kBq/y of ^{32}P : **$5.8 \times 10^{-6} \mu\text{Sv/y}$**
- 0.1 $\mu\text{Sv/y}$ is 100 times below the threshold value of 10 $\mu\text{Sv/y}$, below which further optimization is not required.


No relevant environmental impact expected from air releases from FCCee arcs.

Water activation



- Four water circuits pass through the arcs:
 - **Demineralized water & Chilled water**
closed circuits; potential activation
 - **Drain water & Raw water**
open circuits; low activation as the pipes are placed under the floor


RAW WATER SUPPLY



- **Raw water** provided at points PA, PD, and PJ and transported to the surface of all other locations via the arc tunnel for use by surface facilities.

Water activation

- The raw water is used as makeup water.
- **Objective:**
 - Determine the amount of activity released into the environment per year through evaporation.
- **Conservative assumptions:**
 - All nuclides released via water vapour.
 - Activation considered as if the pipe was not under the floor but next to the line (such as the demineralized water circuit)




Activity releases by raw water evaporation would be significantly lower than those from air activation in the arc.

Accelerator material activation

High volume accelerator materials


- Excessive costs for elimination for the high-volume components, when activation is above limits.
- Preliminary studies indicate potentially relevant activation during $t\bar{t}$ operation (from synchrotron radiation).
- Further detailed studies in progress on:
 - CuCrZr (used for the photon absorber)
 - CuOFE (vacuum chamber material),
 - Lead shielding (for photon absorbers) of different material quality.



Accelerator material activation


High volume accelerator materials

- Excessive costs for elimination for the high-volume components, when activation is above limits.
- Preliminary studies indicate potentially relevant activation during ttbar operation (from synchrotron radiation).
- Further detailed studies in progress on:
 - CuCrZr (used for the photon absorber)
 - CuOFE (vacuum chamber material),
 - Lead shielding (for photon absorbers) of different material quality.



Select materials that can be considered as non-radioactive after a “short” decay time.

Conclusions





THANK YOU FOR YOUR
ATTENTION!



BACK UP SLIDES

Dose (rate) limits and reference levels



| Location | On site | | | | | |
|--------------------------------------------------------------------------------|-------------------------------------|--------------------------------------------------------|-----------------------------------------|-----------------------------------------|-----------------------------------------|----------------|
| Population | Non-classified workers | Radiation workers | | | | - |
| Area classification | Non-designated | Supervised | Simple | Limited Stay | High Radiation | Exclusion Zone |
| Effective dose from direct radiation, air and water (total), nominal operation | 100 μ Sv/a [1] (1 mSv/a [1]) | 6 mSv [1] in 12 months | 20 mSv [1] in 12 months | 20 mSv [1] in 12 months | 20 mSv [1] in 12 months | 20 mSv |
| Effective dose per incident event (event probability < 0.01 per year) | 100 μ Sv [1] (1d mSv/a) | 6 mSv [1] | 6 mSv (20 mSv [1]) | 6 mSv (20 mSv [1]) | 6 mSv (20 mSv [1]) | 20 mSv |
| Effective dose from airborne radioactivity (inhalation/immersion) | 1 mSv/a [2] (or 0.05 CA) | 1 μ Sv in 1 h 3 μ Sv in 1 h | 1 μ Sv in 1 h 10 μ Sv in 1 h | 1 μ Sv in 1 h 10 μ Sv in 1 h | 1 μ Sv in 1 h 10 μ Sv in 1 h | - |
| Ambient dose equivalent rate, nominal operation, permanent stay area | 0.5 μ Sv/h [3] (1 mSv/a [1]) | 3 μ Sv/h [3] (6 mSv/a [1]) | 10 μ Sv/h [3] (20 mSv/a [1]) | - | - | 10 μ Sv/h |
| Ambient dose, nominal operation, equivalent rate low occupancy area | 2.5 μ Sv/h [3] | 15 μ Sv/h [3] | 50 μ Sv/h [3] | 2 mSv/h [3] | 100 mSv/h [3] | 50 μ Sv/h |
| Intervention related maximum individual personal dose equivalent | - | 2 mSv (per intervention) 3 mSv (per shutdown) | - | - | - | - |
| Area related upper limit for surface contamination | < 1 CS | < 1 CS | < 1 CS | < 1 CS | < 1 CS | - |

Dose (rate) limits and reference levels

| Location | Off-site | On-site | |
|--------------------------------------------------------------------------------|-------------------------------------------------------|--------------------------|---------------------------|
| Population | General public (8670 h/a) | Public visit (1h) | Prof. visit (8h) |
| Area classification | Non-designated | - | - |
| Effective dose from direct radiation, air and water (total), nominal operation | 10 $\mu\text{Sv/a}$ [1] (300 $\mu\text{Sv/a}$ [1]) | 10 μSv [4] | 100 μSv [4] |
| Effective dose per incident event (event probability < 0.01 per year) | 1 mSv | 10 μSv [4] | 100 μSv [4] |
| Effective dose from airborne radioactivity (inhalation and immersion) | - | - | - |
| Ambient dose equivalent rate nominal operation, permanent stay area | - | - | - |
| Ambient dose equivalent rate, nominal operation, low occupancy area | - | 2.5 $\mu\text{Sv/h}$ [3] | 2.5b $\mu\text{Sv/h}$ [3] |
| Intervention related maximum individual personal dose equivalent | - | - | - |
| Area related upper limit for surface contamination | - | < 1 CS | < 1 CS |


Experimental cavern

Ambient dose equivalent rate scoring in the *service tunnel 1*




- ❑ The results depicted in the left plot illustrate **the ambient dose equivalent rate** resulting from pp collision, and at the top depicts the 1D profile of the mean values along x-axis, calculated within the volume enclosed by the dashed lines, which is the most likely occupied space during access: from the floor at a height of 3 m, and along the z-axis deviating 3 meter from the center of the tunnel.
- ❑ The plot on the right depicts the ambient dose equivalent rate for the same scenario, but plotted on the z-x plane.
- ❑ The results indicate that 1 meter of shielded doors is sufficient to ensure values lower than $0.5 \mu\text{Sv/h}$, corresponding to the classification of a Non-Designated area.

Ambient dose equivalent rate scoring in the *service tunnel 2*



- The results shown in the plot illustrate **the ambient dose equivalent rate** resulting from pp collisions in the service tunnel n°2.

Ambient dose equivalent rate scoring in the *access tunnel*



- The results shown in the plot illustrate **the ambient dose equivalent rate** resulting from pp collisions in the access tunnel, passing through a three-legged chicane of 20 meters, 20 meters, and 30 meters respectively.

Klystron gallery

□ **Operational scenario (Z and ttbar)**

- The estimated dose rate within the klystron gallery, without the chicane in the waveguide duct, lead to values exceeding the upper threshold for a Supervised Radiation area. In this scenario, implementing a chicane would effectively attenuate the photon fluence, resulting in a substantial reduction in the dose rate by 5-6 orders of magnitude.

□ **Incidental scenario (Z and ttbar)**

- In both operational modes, if a full beam loss incident occurs without utilizing the chicane, the ambient dose within the klystron gallery remains below the annual dose limit for a Supervised Area, which is 6 mSv.
- This situation imposes no significant constraints or limitations in terms of radiation protection. However, implementing the chicane would lead to less doses, meeting the requirements even for a Non-designated area.

| Operation mode | Dose rate in the klystron gallery with chicane | Dose rate in the klystron gallery without chicane |
|----------------|------------------------------------------------|---------------------------------------------------|
| Z machine | < 1 nSv/h | 70 μSv/h |
| ttbar machine | < 1 nSv/h | 300 μSv/h |

Incidental scenario (full beam loss)

| Operation mode | Dose in the klystron gallery with chicane | Dose in the klystron gallery without chicane |
|----------------|-------------------------------------------|----------------------------------------------|
| Z machine | 10 μSv | 2 mSv |
| ttbar machine | 0.2 μSv | 50 μSv |

Radiological classification limits

| Classification | Ambient dose equivalent rate limit for permanent occupancy | Annual dose limit |
|------------------------|------------------------------------------------------------|-------------------|
| Non-designated area | 0.5 μSv/h | 1 mSv |
| Supervised area | 15 μSv/h | 6 mSv |
| Simple controlled area | 50 μSv/h | 20 mSv |

We conclude:

- ❑ **The primary source of uncertainty in this study is systematic** because X-ray emissions from the RF cavities primarily depend X-ray production source (energy distribution and locations, absolute dose rates) and the geometry and materials of the cavity, which were approximated based on the cryomodules used in LHC and measurements done on those. These results were used (energy/absolute dose rate) to normalise the simulation results.
- ❑ The use of the Klystron gallery during FCChh operation still must be defined, and if it shall remain accessible, the radiological conditions must be compliant for radiation sources present in the FCChh.
- ❑ While this systematic uncertainty allows for a margin of improvement, given the current state of the project and the conservative input parameters, **it would be cautious to integrate the duct chicane into the project's design to achieve the radiological standards required for the access of the klystron gallery, both for FCCee and FCChh.**

| Operation mode | Dose rate in the klystron gallery with chicane | Dose rate in the klystron gallery without chicane |
|----------------|------------------------------------------------|---------------------------------------------------|
| Z machine | < 1 nSv/h | 70 μ Sv/h |
| ttbar machine | < 1 nSv/h | 300 μ Sv/h |



Incidental scenario (full beam loss)

| Operation mode | Dose in the klystron gallery with chicane | Dose in the klystron gallery without chicane |
|----------------|-------------------------------------------|----------------------------------------------|
| Z machine | 10 μ Sv | 2 mSv |
| ttbar machine | 0.2 μ Sv | 50 μ Sv |

Radiological classification limits

| Classification | Ambient dose equivalent rate limit for permanent occupancy | Annual dose limit |
|------------------------|------------------------------------------------------------|-------------------|
| Non-designated area | 0.5 μ Sv/h | 1 mSv |
| Supervised area | 15 μ Sv/h | 6 mSv |
| Simple controlled area | 50 μ Sv/h | 20 mSv |

Arc




- ❑ The graphs at the top depict the 1D profile of the mean values along z, calculated within the volume enclosed by the dashed lines. This volume represents the most probable occupied space during access, typically at a distance of 1-2 meters from the beam line.
- ❑ The irradiation profile considers all the years of the operation mode, taking into account the winter shutdowns


ANALYSIS OF CONCRETE ACTIVATION – ttbar

(After the full operation period)

LL multiples for concrete (decay time: 1 week)



LL multiples for concrete (decay time: 1 month)



Irradiation profile (ttbar): full operation period / 1 week of cooling time


Irradiation profile (ttbar): full operation period / 1 month of cooling time

Activation is below clearance limit for the concrete structures of the tunnel.


ANALYSIS OF CONCRETE ACTIVATION – ttbar

(After the full operation period)

LL multiples for concrete (decay time: 1 year)



LL multiples for concrete (decay time: 10 years)



Irradiation profile (ttbar): full operation period / 1 year of cooling time


Irradiation profile (ttbar): full operation period / 10 years of cooling time

Activation is below clearance limit for the concrete structures of the tunnel.


ANALYSIS OF CONCRETE ACTIVATION – ttbar

(After 1 year of operation)

LL multiples for concrete (decay time: 24 h)





LL multiples for concrete (decay time: 1 month)



Activation is below clearance limit for the concrete structures of the tunnel.

ANALYSIS OF CONCRETE ACTIVATION – ttbar



(After 1 year of operation)



Activation is below clearance limit for the concrete structures of the tunnel.



Positron source

FLUKA geometry





Acknowledgment B. Humann and SY/STI for providing the geometry

Results – Residual radiation




- ❑ The graphs at the top depict the 1D profile of the dose rate values along z, calculated within the volume enclosed by the dashed lines. This volume represents the most probable occupied space during access.
- ❑ The irradiation profile considers one year of operation, taking into account the duty factor of the machine.

Results – Residual radiation (with shielding)



- ❑ The graphs at the top depict the 1D profile of the dose rate values along z, calculated within the volume enclosed by the dashed lines. This volume represents the most probable occupied space during access.
- ❑ The irradiation profile considers one year of operation, taking into account the duty factor of the machine.


Activation study



Air activation (Preliminary radiological environmental impact assessment for FCCee)

- ❖ **Quantity:** Annual effective dose to the Representative Person from the public
- ❖ **Input:** Activity releases through air from the FCCee arc in ttbar operation (highest releases, no recycling, no filtration).
- ❖ The exact exposure configuration is not yet known
- ❖ Experience with the existing CERN facilities comprising about 250 configurations – 95 Percentiles for the two most contributing radionuclide groups:
 - ❖ Short-lived gases (^{41}Ar): 4.5E-20 Sv/Bq
 - ❖ Agriculture (^{32}P): 9.5E-17 Sv/Bq
- ❖ Expected annual effective doses:
 - ❖ 2.3 TBq/y of ^{41}Ar : 0.1 $\mu\text{Sv/y}$
 - ❖ 60 kBq/y of ^{32}P : 5.8 pSv/y
- ❖ 3'000 times below the source-related dose constraint of 300 $\mu\text{Sv/y}$
- ❖ 100 times below the *de minimis* dose of 10 $\mu\text{Sv/y}$ (justified and optimized)

No relevant environmental impact expected from air releases from FCCee arcs.




Activation

$$\sum_{i=1}^n \frac{a_i}{LL_i} < 1$$

WHEN LL IS BELOW 1, THE MATERIAL CAN BE GENERALLY RELEASED FROM REGULATORY CONTROL



- Accelerator materials



- For each material, it is essential to identify the main contributors to long-term activity and, whenever feasible, avoid them.
- In the case of lead, the primary contributors to the activation are impurities like silver, cadmium, and bismuth.



Beam dumps

Residual dose rate



Dump shielding
IRON: 20 cm
CONCRETE 40 cm

At main beam dumps (Z mode)




- ❖ Study for Z mode, because of the highest beam density.
- ❖ Irradiation profile: 185 operational days/year, 1 beam dump per day.



- (1) No need for additional alcoves to accommodate the beam dumps
- (2) Sufficient space for additional shielding in the foreseen integration design

Residual dose rate

At main beam dumps (Z mode)



**Dump shielding
IRON: 20 cm
CONCRETE 40 cm**



- ❖ Study for Z mode, because of the highest beam intensity.
- ❖ Irradiation profile: 185 operational days/year, one beam dump per day.

- (1) No need for additional tunnels to accommodate the beam dumps
- (2) Sufficient space for additional shielding in the foreseen integration design



FUTURE
CIRCULAR
COLLIDER

