



FUTURE CIRCULAR COLLIDER

SAFETY CONCEPT OF THE FCC: OVERVIEW

A. Henriques, O. Rios
on behalf of the Safety WP team

Outline

- FCC Safety Work package
- Safety concept
 - Objectives and scope
 - Ten-years in the making: from conceptual to feasible
- Hazard registry: Standard Best Practices vs Performance-based
- Safety Systems
- Performance-based studies
- Consolidated safety design
- Next steps

FCC Safety Work package

Team



Thomas Otto
WP leader
Study coordination,
hazard register, editor



Andre Henriques
Occupational health and
safety



Oriol Rios
Fire Safety



Ghislain Roy
Operational safety,
personnel safety
systems



Guven Nergiz
Occupational health and
safety
Numerical modelling



Pavol Vojtyla
Environmental impact of
ionising radiation



Markus Widorski
Radiation protection



Giacomo Lavezzari
Radiation protection



Tomasz Ladzinski
Safety systems



Marc Nas
Emergency Preparedness and
response

Acknowledgements: Contributions, exchanges from all TIWG

See "Implementation scenario Plenary",
J. Gutleber


See "Civil Engineering Plenary",
T. Watson

Safety concept

Objective & Scope

Global repository for safety-related information for the FCC-ee feasibility study


- Focus on **Life Safety**
 - Environmental protection will be dealt in the Environmental Impact report - Initial State Analysis is ongoing and will be part of the feasibility study
 - Business continuity; asset protection: indirect impact; yet not quantified
- **3 phases:**
 - Civil Engineering construction
 - (machine) Installation
 - Operation
- Underground areas
 - Arc, caverns, galleries, alcoves
- Surface sites



Safety concept



Vol. 2: Accelerators, Technical Infrastructures, Safety Concepts



FUTURE CIRCULAR COLLIDER FCC-EE SAFETY CONCPET FCC-INF-RPT-00xx v.0.1
Date: 01/05/2024

Future Circular Collider

SAFETY CONCEPT

Safety Concept Report for FCC-ee

Document identifier: FCC-INF-RPT-00xx
Date: 01/05/2024
Work package/unit: Technical Infrastructures / Safety
Version: V0.1
Status: **Draft**

Abstract:
 A first iteration of the safety concept for the FCC study was performed for the CDR. Following the advancements of the study and the feedback from the mid-term review, the Safety WP of the TIWG pillar worked on an update of the safety concept, developing more detailed assessments, including fire and ODH simulations as well as evacuation modelling. This report will provide the full overview of the Safety concept, tailored to FCC, serving as main reference for Safety Reviews and the Feasibility Study report.

Individual detailed reports

FUTURE CIRCULAR COLLIDER FCC HELIUM RELEASE STUDY FCC-INF-RPT-00xx v.1
Date: 14/05/2024

Future Circular Collider

SAFETY NOTE

ODH STUDIES IN THE RF SECTION OF FCC-ee

FUTURE CIRCULAR COLLIDER TRANSPORT SAFETY HAZARDS AND OPTIONS FOR MITIGATION FCC-INF-PJA-0091 EEDMS 292508 v.1.1
Date: 3.9.2023

Future Circular Collider

SAFETY NOTE

TRANSPORT SAFETY HAZARDS AND OPTIONS FOR MITIGATION

FUTURE CIRCULAR COLLIDER FCC EVACUATION STUDY FCC-INF-RPT-0011 v.1.4
Date: 27/02/2024

Future Circular Collider

SAFETY NOTE

EVACUATION SIMULATION: INPUT FOR

FUTURE CIRCULAR COLLIDER EMERGENCY RESPONSE AND FIRE FIGHTING IN FCC FCC-INF-PJA-0081 EEDMS 2922006 v.0.4
Date: 14.03.2024

Future Circular Collider

SAFETY NOTE

EMERGENCY RESPONSE AND FIRE FIGHTING IN FCC


Document identifier: FCC-INF-PJA-0081 EEDMS 2922006 v.0.4
Date: 14.03.2024
Work package/unit: Technical Infrastructures / Safety
Version: V0.4
Status: Engineering Check

Abstract:
 The large inter-site distances in the FCC lay-out and the large distance of most FCC access points from the CERN Meyrin site call for innovative solutions for emergency interventions and firefighting by the CERN Fire and Rescue Services (CFRS) in the future. This note describes FCC in view of emergency interventions, defines such interventions and points to solutions and developments which are different from present emergency intervention practice at CERN.




See "FCC Feasibility Study status FCC Feasibility Study status Plenary", M. Benedikt

Safety concept




From conceptual to feasible



Double tunnel (sketch) - 2012



Lateral safe passage + smoke curtains - 2017





Hazard registry

Standard Best Practices vs Performance-based

- Systematic collection of Hazards in the FCC facilities during different phases of its lifetime
- No assessment of probability or severity

A1	External Hazard to Facility	Activation of ground Additional Traffic Noise (Environment) Release of pollutants: air Release of pollutants: solid Release of pollutants: water Release of radioactive liquid Release of radioactive solid Release of radioactivity by air	
A2	Hazard to the Environment		
B1	Physical Hazards		Dangerous surface Fall of object from height Fluid under pressure Uncontrolled object in motion Unprotected element in movement
B2	Radiation, ionising		
B3	Radiation, non-ionising		
B4	Noxious Substances		
B5	Fire Hazards		
B6	Mechanical Hazards		
B7	Electrical Hazards		
C1	Working Environment		
C2	Physiological Constraints		
C3	Unexpected events		
C4	Organisation		
C5	Psychological Constraints		

T. Otto, "FCC Safety Strategy for the Conceptual Design Report", FCC Week 2017, Berlin GE




See "Radiological studies for FCCee", G. Lavezzari

Hazard registry

Standard Best Practices

vs




Performance-based (Safety studies)



K. Hanke, "Residual magnetic field at surface of experimental points", FCC-INF-PM-0077 v.1



IP
Rating





SAFETY SYSTEMS

Safety Systems

Integrated approach



Evacuation guidance system
(dynamic signage, RFID)

Hazard Detection
(ASD, Fiber Optics, Optical sensors)

Longitudinal compartments
(static confinement)

Horizontal & Vertical egress redundancy
(shafts, lifts)

Emergency Response
(First Responders, Fire Fighting means, communication)

Air management
(dynamic confinement, smoke extraction)

Control the access
(PSS, authorized personnel, safety training)

Personnel Transportation
(vehicle driven egress)

<https://www.cityexperiences.com/blog/golden-gate-viewpoints/>








Figure 2.5 Illustration of the alternative tunnel ventilation concept without slab duct in emergency mode (deviation 4 in Table 2.1)




Safety Systems: Underground Air Management


Baseline strategy: Semi-transverse

Possible Optimization strategy: Longitudinal (cyclic)

CERN, Cooling and Ventilation Studies for the Future Circular Collider Study
Baseline tunnel ventilation concepts
Status: 27.05.2024




CERN, Cooling and Ventilation Studies for the Future Circular Collider Study
Alternative tunnel ventilation concepts
Status: 27.05.2024



Safety Systems: Tunnel Compartments

Objectives:

- Safe egress:
 - Allows safe evacuation for occupants
 - Allows static and dynamic smoke confinement
- Search & Rescue from Fire Brigade
 - Enables faster and safer intervention
 - Reduces the smoke diving (air supply)
- Reduces asset loss
 - Limits the propagation and damage to the accelerator and equipment




Example in SPS



Main Features

- Every 400 m there is a tunnel enclosure
- Length compatible with cell length
- Smoke tight
- Dynamic Danger signalization
- Robot automatic hatch
- Pressure compatible doors (if needed, damper)
- Position controlled
- Fire Resistance performance (tbd, EI30/60/90) with technical solution



Alcoves

- 5 + 2 / sector

Fire compartments:


- 28 / sector

Safety Systems Personnel Safety Systems

(incl. access control, hazard detection, alarms)

See "Personnel Safety Systems", T. Ladzinski

Systems installed to protect the **personnel** from **hazards** inherent to the facility.



Safety systems **Evacuation**

11 km evacuation distance: shall be assisted by other (mechanical) means





Nominal Strategy: Always available motorized vehicle

Logic

- Go to workplace with vehicle
- Vehicle parked in adjacent area (short intervention, near-by-stand-by)
- In case evac. Walk to vehicle and leave
- Cross-over possible
- Symmetrical vehicle. Reversing direction

Main Features

- Autonomous driving
- 4 seats + 4 bags (size equivalent to cabin luggage)
- Max speed: 30 km/h
- Battery driven; autonomy of 150-200 km
- Weight (fully loaded): 1500 kg
- Line guidance
- Equipped with LIDAR sensors and laser scanners
- Equipped with First Aid and first intervention material




No rescue refuges but Safe Areas

- Safe waiting are connected to shaft
- Over pressurized and fire rated
- Occupational crowding and size study. 40m²

Degraded Strategy: emergency + vehicle down

- Alternative vehicle (communication)
- Ultimate manual transportation in alcove (bike, tricycle, scooter)



G. Nergiz, "FCC Evacuation modelling, FCC Week 2023, London UK"

PERFORMANCE-BASED STUDIES

Update since FCC Week 2023

See “Radiological studies for FCCee”,
G. Lavezzari

Oxygen Deficiency Hazard in RF section

Input data

Ref: From Cryo SRF Task Force

Class/Case	Risk Situation	Mass Flow	Pressure Reached [bar]	Discharge Diameter
1	Static losses on cryomodule insulated from cryogenic plant	7.3 g/s	~ 1.7	1 SV of DN < 20mm
2	Sustained RF quench	2.9 Kg/s	~ 2	Min 4x48mm BD
3	Beam vacuum break (100 mm aperture)	9.2 Kg/s	~ 12	4 x DN80 BD not sufficient to contain the pressure build up

* Preliminary values scaled from LHC cryomodules. New simulations running with updated figures (FCC-related)

Assumption: Same discharge area from the LHC risk assessment

Scenario	Number of Release points per cryomodule	Release Diameter (each point) [mm]	Release Rate (each point) [kg/s]
1	1	100	2.9
2	2	100*	1.45 (2.9 / 2)
3	4	50	0.725 (2.9 / 4)


*It should be 71 mm in reality, but slightly more conservative

Helium Release conditions:

- @400 MHz Cryomodule;
- Inventory: **900 L**
- Mass flow rate **2.9 kg/s** * @ 2 bar
- Total Helium inventory = 107 kg
- Total release time = **37 seconds**
- Additional **20 s** after helium release **cut-off** (57 s in total)

Ventilation Conditions:

- Semi-Transverse ventilation concept **27000 m³/h**
- Tunnel ventilation inlet **25140 m³/h**
- Fresh air inlets **4 x 465 m³/h**



Version: 06.2023
FCC Tunnel Point H – RF Section

Objectives:


- Observe the turbulent effects near the release point(s)
- Extent of the ODH risk (O2 < 18%)
- Cloud propagation
- Impact on the cross-section geometry

Oxygen Deficiency Hazard in RF section


Release Point mid-section (-1.25 m)

Section K – K





SC1
1xDN100




SC2
2xDN100



SC3
4xDN50



Oxygen Level [%]



Oxygen Deficiency Hazard in RF section



SC1

1xDN100

SC3

4xDN50

Propagation speed and plug size



SC	Cloud front [m/s]	He Plug (< 37s) [m/s]	He Plug (≥ 37s) [m/s]	Plug size [m]
1	~1.52	~0.66	~0.58	~32.3
2	~1.33	~0.57	~0.7	~29.4
3	~1.66	~0.63	~0.81	~34.6

Conclusions:


- Turbulent effects near the release point(s) is confirmed
- O2 < %18 in 10 seconds
- He plug formed and for up to 35 m

Oxygen Deficiency Hazard in RF section

Next Steps – More simulations

- New simulations with updated cryomodule thermo-hydraulic and mechanical design
 - Updated risk assessment, tailored to FCC SRF
 - Significantly higher flow rates (↑ cavity surface areas)

- New simulations with
 - Updated Cross-section
 - Use of emergency extraction system (effect on the He plug)



Helium safety and PRDs


CM/ Case	Risk Situation	Heat load	Mass flow	T	Pressure reached (bar)	Discharge diameter	Comments
400MHz – Risk case scenario 3	Beam vacuum break (100 mm aperture)	380 kW	19.57 Kg/s	4.99K	~ 1.95 bara	$\varnothing_{min} = 130.5mm$ 1 x BD DN150 or 2 x BD DN100 (each one taking half of the flow rate)	HL calculated considering the wet surface of the cavities (9.5m ²) without protection (4 W/cm ²). Exceptional case. Mitigation measures are needed to contain the probability of this event (e.g. orifice limiting bellows protections, no mech. work with liquid inventory).
800MHz – Risk case scenario 3	Beam vacuum break (100 mm aperture)	195 kW	10.3 Kg/s	4.99K	~ 1.95 bara	$\varnothing_{min} = 95mm$ 1 x BD DN125 or 2 x BD DN80 (each one taking half of the flow rate)	HL calculated considering the wet surface of the cavities (4.96m ²) without protection (4 W/cm ²). Mitigation measures are needed to contain the probability of this event (e.g. orifice limiting bellows protections, no mech. work with liquid inventory).

See “SRF system integration - cryomodule functional specifications and design of the 400MHz”, K. Canderan

Smoke extraction and Life Safety: PBD Study

Aim and Scope

- ✓ Validate smoke extraction + compartment baseline
- ✓ Explore longitudinal alternative proposal
- ✓ Compare safety level
- ✓ Study degraded modes





Fresh-air duct
For semi-transverse only


Semi-Transverse

Longitudinal


Run/Access



Emergency



Mechanically controlled dampers in all compartments



Tunnel sector (L=11'400m)


Global Picture Comparison Between Concepts

Semi - Transverse

S-T Worst Case


The Last Compartment
The Last Door

Avg. Max. Flow Velocity
On the Door
2 m/s



Avg. Max. Flow Velocity
On the Door
4 m/s
(reduced with dampers)


Longitudinal Worst Case
The First Compartment
The First Door



S-T Worst Case

The Last Compartment
The Last Door

Avg. Max. Flow Velocity
On the Tunnel Cross-Section
0.5 m/s




Avg. Max. Flow Velocity
On the Tunnel Cross-Section
1 m/s

Longitudinal Worst Case
The First Compartment
The First Door


Longitudinal

Run/access/flushing modes



54000 m³/h

Smoke extraction and Life Safety: Criteria



Slices (Temp., Vel.)

Fire Designs

3.1 Fire designs: Fire#1 - Tray Fire

CABLE TRAY

3.1 Fire designs: Fire#2 - Drum Fire

DRUM

3.1 Fire designs: #Fire3 Kuka Fire

KUKA

• Those 3 scenarios are considered to be more representatives ones
 • Only fire scenarios are considered.
 • Fire Scenarios resulting from explosions are not accounted for.

400m Length Full fire compartment

Supply ↑ Exhaust ↑ Fire Door

Acceptability criteria	Criteria (after fire start)
Visibility	>10 m at height of 2m
Occupants exp. FED	< 0.3
Occupants' exp. Temperature	< 60 C

ASET
(Available Safe Evacuation Time)


Comparative criteria	Criteria (after fire start)
Time to FED	Time to FED = 0.3 and FED = 1.0
Time to lose Visibility	Time to reach 10m visibility at height of 2m
Exposed Occupants	Exposed by smoke or not (decreased visibility)
Smoke Travelling Speed	Avg. speed of smoke (smoke travelling speed from fire point to the long end of the tunnel)
Air Velocity at Fire Doors	Avg. air velocity on the fire door's cross-section

For Comparison, also degraded modes are studied

- Smoke extraction fails
- Fire Detection fails
- Smoke extraction delayed
- Make-up air fails



+ parametric exploration on optimal smoke extraction flow
 7.000 m³/h – 14.000 m³/h – 20.000 m³/h – 28.000 m³/h

Smoke extraction and Life Safety: Results





HRR + visibility + temperature
Horizontal velocity

Smoke + visibility



200.0


Temperatures field



199.9

Smoke extraction and Life Safety: Results



x 60
00 : 00
[min]



Visibility: Semi-transverse

400m

Visibility: Longitudinal – detection failure




Pre movement time: 0s, 150s, 260s
Walking speed: 0.8 m/s – 1.2 m/s

Margin time = ASET - RSET

>30 CFD runs

Smoke extraction and Life Safety: Results

Case Name	Ventilation Type	Failure Type	Failure Explanation	LBFV* [m/s]	Supply Rate [m³/s]	Exhaust Rate [m³/s]	Occupant Exposed or Not	Smoke Travelling Speed [m/s]	STS < Walking Speed	Speed margin [m/s]	Margin Time [min]	Time to FED 0.3 [min]	Time to FED 0.3 long end [min]	Time to FED 0.3 short end [min]	Time to FED 1.0 [min]	Air Velocity at Door > 3 m/s (critical)
1.1A	Semi-T.	-	-	0.36	0.48	0.48	No	0.37	Yes	0.4	4.7	16	24	18	22	-
1.1B	Semi-T.	-	-	-	-	-	-	-	-	-	5.7	16.5	26	18.5	24	-
1.1C	Semi-T.	-	-	-	-	-	-	-	-	-	11.2	17	>26	19.5	>26	-
1.1D	Semi-T.	-	-	-	-	-	-	-	-	-	13.7	18	>26	20.5	>26	-
1.5A	Semi-T.	Delay	60s F	-	-	-	-	-	-	-	10.2	17	>26	19	>26	-
1.6A	Semi-T.	Delay, 4	60s Fan	-	-	-	-	-	-	-	1.2	17	23	19	24	No
1.7A	Semi-T.	-	-	-	-	-	-	-	-	-	7.7	17	>26	19	25.5	-
1.2A	Semi-T.	-	-	-	-	-	-	-	-	-	4.7	16	24	25	22	-
1.2B	Semi-T.	-	-	-	-	-	-	-	-	-	12.7	19	>26	21	>26	-
1.8A	Semi-T.	1	No F	-	-	-	-	-	-	-	1.2	13	16	18.5	20	No
1.9A	Semi-T.	2	S	-	-	-	-	-	-	-	11.2	15.5	22.5	17.5	21.5	No
1.10A	Semi-T.	3	Ex	-	-	-	-	-	-	-	1.7	16	22	17.5	23.5	No
1.11A	Semi-T.	4	-	-	-	-	-	-	-	-	1.2	16.5	23	19	24	No
1.12A	Semi-T.	Delay	60s F	-	-	-	-	-	-	-	9.7	17	17	19	>26	No
1.13A	Semi-T.	1	No F	-	-	-	-	-	-	-	-2.8	18	21	>26	18	Yes (10)
2.1A	Long.	1	No F	-	-	-	-	-	-	-	1.2	16.5	19.5	17	21	No
2.2A	Long.	Delay	60s F	-	-	-	-	-	-	-	8.2	14.5	>26	16.5	21.5	-
2.3A	Long.	4	-	-	-	-	-	-	-	-	1.7	13.5	19.5	16	20.5	No
2.3B	Long.	4	-	-	-	-	-	-	-	-	3.2	15.5	23	18	21.5	No
2.3C	Long.	4	-	-	-	-	-	-	-	-	6.2	16	>26	18	21.5	No
2.3D	Long.	4	-	-	-	-	-	-	-	-	11.2	16	>26	18	22	No
2.4A	Long.	3	Ex	-	-	-	-	-	-	-	2.2	16	23	18.5	19	-
2.5A	Long.	-	-	-	-	-	-	-	-	-	3.2	15	23	17	20	-
2.5B	Long.	-	-	-	-	-	-	-	-	-	3.7	14.5	>26	16.5	21	-
2.5C	Long.	-	-	-	-	-	-	-	-	-	9.2	14.5	>26	16.5	22	-
2.5D	Long.	-	-	-	-	-	-	-	-	-	12.2	15	>26	17	22	-
2.6A	Long.	-	-	0.36	-	0.768	No	0.43	Yes	0.4	3.2	16.5	>26	18.5	20	-
2.7C	Long.	1	No Fire Detection	1	-	CLOSED	Yes	0.66	No	0.1	-0.3	16	20	19	22	No
2.7D	Long.	1	No Fire Detection	2	-	CLOSED	Yes	0.74	No	0.1	-1	13.5	18	22	22	Yes (4.35)
2.8A	Long.	Delay, 4	60s Fan Delay, Door Fail	0.36	-	1.44	Yes	0.36	Yes	0.4	5.2	16	>26	18	22	No
2.9A	Long.	1	No Fire Detection	1	15	CLOSED	Yes	1.42	No	-0.6	-3.8	>26	>26	>26	>26	Yes (21.2)



Smoke extraction and Life Safety: **Conclusion**

- ❑ Both **semi-transverse** and **longitudinal** normal ventilation mode **meet safety criteria IF nominal conditions are considered** (not degraded mode).
- ❑ **Semi-transverse** strategy performs better at the end of the compartment (larger safety margin), longitudinal case adds **efficient pressure confinement**.
- ❑ **Longitudinal** case becomes **unacceptable in case of failure to detect** (high speeds downwind).
- ❑ **Delay** in the **fan starting times** and/or door closing time leads to an increase in the smoke travelling speed, but, in nominal modes there is still margin.
- ❑ Exhaust Fan Failure and No Fire Detection simulations show that **prompt detection and active smoke extraction plays an important role for occupant safety in case of accidental fire**.

Longitudinal mode remarks:

- In case of door closing, pressure to open door needs to be assessed (and trapping solved)
- Dampers to be sized and integrated in cross section (in fire-walls)
- Passive infrastructure (slab-duct) to be replaced by active system (fire-wall reversible damper)

CONSOLIDATED SAFETY DESIGN



Other underground areas

See "Radiological studies for FCCee",
G. Lavezzari

Klystron gallery

Point H and L

- Klystrons galleries are high fire load + ignition risk areas
- Dedicated emergency connection staircase: (pressurized/SAS)
 - 4 connection PL (~1000m)
 - 8 connection PH (~2000m)
 - (no cul-de-sac)
- Dedicated smoke extraction
- Compartmentalization possible



Alcoves




Key: Alcoves are NOT a safety refuge

Safety features

- Fire compartment
- Smoke extraction system
- Detection system
- Limited depth to 40 m cul-de-sac


Safety features

- First-aid and rescue equipment
- Command post (every other alcove)
- Additional PPE (e.g. oxygen masks)
- Other equipment (e.g. fire extinguishers, stretchers, etc)
- Electronic racks for control of safety systems (e.g. Fire detection, ODH, radiation monitoring system)
- Lay-by area for parking vehicles




Experimental / Service Cavern @ IPs


ATLAS underground




CMS underground




FCC point A



FCC machine egress



- Single personnel shaft
- Independent safe path from machine and experiment
- 2 independent lift shafts (2 x 2 lifts)
- Several safe connections between exp-service caverns



Credits: afvoil, multibrief.



Surface Buildings

Safety of surface buildings:

Safety Concept = Prescriptive approach (standard HS safety level)

Surface points also important for global safety concept

- Helipad
- Fire Fighting equipment
- Infirmary/waiting room/temp. fire-medical station
 - (depending on point type)
- Advance command post



FCC intervention concept ≠ 4 x LHC's

Intervention Concept



0. Self-sufficient workers in FCC (minimize exposure)

1. Intervention before evac: Trained workers on site

- 1st Response to emergency (medical, fire, damage control)

2. Emergency response robots

- Establish Situational Awareness
- 1st Intervention (Firefighting, Search and Rescue?)

3. Professional human responders

- Verify SA
- 2nd Intervention
(Finalize SAR, Finalize FF, specific damage control)



defense.gov.au/



https://mobilityforesights.com/



Construction phase → Contractor + CFRS !
 Installation Phase → CFRS + Special plan (degraded)
 Operation (run/stops) → CRRS + Firs Aiders + Local

Key aspects

- **Safety by design** and focus on **prevention**
- A **trained workforce** that can do **first emergency intervention**
- A **strong collaboration** and interoperability with various local **HS** Emergency Services
- The positioning of several **autonomous emergency response robots** that support **information gathering** and **intervention**
- The positioning of '**CFRS equipment hubs**': Fire Engine/Rapid Intervention Vehicles, sub-command posts, support for air transport, casualty care and HS support
- A **CFRS roadmap** from current operations (2020) to FCC operations (2040)



NEXT STEPS

Next Steps FCC Feasibility Report

- Complete the safety studies
- Start editing the ‘Safety Concept’ report as **main deliverable for the Feasibility Study**
- Third party review of HSE’s contribution to the FCC study
- By consultant expert in large underground infrastructure projects
- Review of the concept as a whole and not individual safety systems or assumptions
- ... make sure we are not missing something important (namely in the construction and installation phases)



Future Circular Collider

SAFETY NOTE

ODH STUDIES IN THE ACCIDENTAL HELIUM RELEASE IN THE FCC-E

Document identifier: FCC-INF-0096
Date: 14.05.2024
Work package/unit: Technical
Version: V1
Status: Under rev

Abstract:
The SRF cryomodules of the FCC-ee would contain their superconductivity state. Following a risk assessment of helium release in the FCC tunnel (helium spill), when the helium is released in the tunnel, it displaces the air (Leakage Deficiency Hazard), moreover the low temperature frostbites. The methodology of the numerical simulation assessment as well as the characterization and the analysis of the ODH is presented in this report.

Future Circular Collider

SAFETY NOTE

TRANSPORT SAFETY HAZARDS AND OPTIONS FOR MITIGATION

Document identifier: FCC-INF-PM-0056 | EDMS 2757485 v.1.1
Date: 3. 9. 2022
Status: Released

Abstract:
The large inter-site distances in the FCC lay-out maintenance of the accelerator. Light electrical v operation and maintenance phases of the FCC acc the FCC presents the risk of accidents caused by v along the accelerator.
Three potential options for mitigation of the trans for further discussion. In a dedicated section, an as studies to be performed to draw relevant conclusio

Future Circular Collider

SAFETY NOTE

EVACUATION STUDY INPUT FOR SIZE OF SHELTER FOR FCC-EE M

Document identifier: FCC-INF-R-0072 v.1.0
Date: 27.02.2024

Abstract:
This paper summarizes the study on determining the minimum designated safety criteria. To simulate the worst case, pe selected as control section. It is assumed that one of the sh all occupants in the concerned sectors need to be evacuate of the tunnel. A probabilistic model was developed with tv and 200 (scenario #2) occupants per sector. The results sh in both scenarios, within a 95% confidence level.

Future Circular Collider

SAFETY NOTE

EMERGENCY RESPONSE AND FIRE FIGHTING IN FCC

Document identifier: FCC-INF-PM-0088 | EDMS 2922606 v.0.4
Date: 14. 03. 2024
Status: In Work

Abstract:
The large inter-site distances in the FCC lay-out and the large distance of most FCC access points from the CERN Meyrin site call for innovative solutions for emergency interventions and firefighting by the CERN Fire and Rescue Service (CFRS) in the future.
This note describes FCC in view of emergency interventions, defines such interventions and points to solutions and developments which are different from present emergency intervention practice at CERN.

