

# 2023-24 EYETS planning meeting

16.2.2024

A.Tauro



# EYETS 2023-24: access, cavern closure

- **Access perturbations:**
  - Individual System Test & DSO test: **15-16 February** → **no access UX25 cavern 15 February 13:00 PM - 16 February 18:00 PM**
- **March 1<sup>st</sup>: surprise organised by Klaus** 😊😊😊
- **Machine checkout** starts on Wednesday, March 6<sup>th</sup>
  - **Underground access** and **cavern visits** will stop on Tuesday, March 5<sup>th</sup> at 17:00
- EYETS will end on Monday, March 11<sup>th</sup>
  - **Physics restart** with beam on March 11<sup>th</sup>
- TE-VSC: reopen manual beampipe valve on Tuesday, March 5<sup>th</sup>

# Detector's activities

# 1/2

- **TPC:**
  - Laser maintenance (week 5)
  - Check leaks
  - Replace some Wiener PS
  - Install current measurement devices on FC
  - Replace Ne
- **TRD:**
  - Inspection cooling loops in week 3 as some tightness degradation suspected
  - Replace LVPS
  - Inspection of the LV connections (L3 C-side) with the infrared camera for any hot spots A few connections inside the LV rack are 'warm' and need to be tightened
- **TOF:**
  - x24 three-phase Notch Filter units (CAEN A3000NF) reinstalled in the cavern on Jan 26th and fully operational → TOF is fully powered & all links UP
- **PHOS:** planned activities from 21 February to 6 March (4 people, one of which is a watcher)
  - Work in A17: extract burned Wiener LVPS, replace it with a spare one, validate low-voltage operation of the PHOS module 2 which was affected by a broken Wiener
  - Work inside the L3 magnet: find and fix high-voltage short in module 1. Open feed-through flange, find and disconnect HV cable from FEE card which caused short current, verify HV current with switched FEE cards
  - Refill the crystal cooling plant with 11 liters of C6F14
  - PHOS crystal cooling plant is working at +15C now. We shall start cooling down to -25C after the HV trip repair. It will take the usual 2 weeks to reach the target temperature -25C, this is a remote operation without any need to go to the cavern.
  - Andre investigating with EN-EL to remove the crystal cooling plant differential current protection, which got triggered during the HI run → we cannot remove the differential protection



# Detector's activities

## 2/2

- **FIT-A:**
  - Survey
  - Investigation of a problem with one FT0-A MCP-PMT → either on Feb 20<sup>th</sup> or on Feb 26<sup>th</sup>
- **FDD:**
  - Inspection?
- **EMCal:**
  - Replace FEE + TRUs + checks → 1-2 days next week
- **MFT:**
  - Replacement of the cooling filters in PP0
  - Addition of flow limiters on the pneumatic valves to avoid bumps when turning ON/OFF
  - Addition of a 200 liters tank to increase the buffer volume, to reduce the time between 2 pump starts
  - Replacement of the thermal pads on the RO boards affected by the viscous fluid on one quarter of MFT (H0F0). H1F1 to be done next week,
  - Replacement of the thermal pads on the RO boards affected by the viscous fluid on a second quarter of MFT (H1F1), IMPACT 227502 (The second half on O-side will be done later if needed, possibly next YETS)
- **MCH:**
  - **Station 1:** address RO issues → Orsay team onsite next week. The quadrant with a faulty sector will be exchanged during the next YETS
  - **Station 2:** improve the read-out stability of the quadrants → Indian team will come to CERN in week 9 (26/02 - 06/03)
  - **Stations 3-4-5:** work on ST3 (mainly CH6L) next week. Work on ST4-5 mostly done, except replacement of one SOLAR board (nacelle needed)
- **MID:**
  - Faulty RPC disconnected, removed from half plane and tested on January 17 and 18 – seems ok

# TOF notch Filters refurbishment


- TOF has 24 Notch Filter units (CAEN A3000NF) filtering the three phase (400 V) supplying our 48 V power supplies (“Maciste”) in the cavern (balconies) + 2 spares
- All units have been refurbished in Viareggio in Dec and Jan, since some capacitors reached the EOL (provoking a start of fire x2 in ATLAS in the last few years):  
replacement of EOL caps done, fans replaced and overheating protection added → DONE




# TOF notch Filters refurbishment

- **All units re-installed** in the cavern last Friday Jan 26 and are **operational** (dismounted on Nov 27)
- CAEN reports (informally) that:
  - **ALICE-TOF**: 50% caps were still intact\*, **50% caps visible deformed (heat)**
  - **ATLAS** (x2-x3 power than TOF): 10% caps still intact\*, 90% visible deformed

\*those intact showed however a capacitance value degraded



1/6/2024





# MFT status

- Replacement of the cooling filters in PP0
- Addition of flow limiters on the pneumatic valves to avoid bumps when turning ON/OFF (EN-CV)
- Addition of a 200 litres tank to increase the buffer volume, to reduce the time between 2 pump starts (EN-CV)
- Replacement of the thermal pads on the RO boards affected by the viscous fluid
  - One quarter (H0F0) done last week
  - Second quarter (H1F1) will be done **next week**
  - O-side crates will be done during the next EYETS (if needed)

→ Last intervention next week (1-2 days inside L3)




# MCH status


- **Station 1:** address RO issues (few intermittent errors) → Orsay team onsite next week. The quadrant with a faulty sector will be exchanged during the next EYETS
- **Station 2:** improve the RO stability of the quadrants. Local shielding on the flat cables that present RO issue seems to fix the problem (to be confirmed with time). A few boards and connectors damaged at beginning of February → Indian team will come to CERN in week 9 (26/02 - 06/03)
- **Stations 3-4-5:** work on ST3 (mainly CH6L) next week. Work on ST4-5 mostly done, except replacement of one SOLAR board

→ Planned cavern interventions until March 6<sup>th</sup>

ST12 HeartBeat Rate (07/02/2024 - 16:53)



ST345 HeartBeat Rate (07/02/2024 - 16:53)






# MID status

- Faulty RPC inspected in November
- RPC disconnected from half-plane and repaired in January
- Isobutane circulating since early January


→ No other interventions foreseen until end of this EYETS






# FIT status

- Replacement of two burned power connectors in the FEE crate & FEE modules:
  - FEE disassembly / resoldering in the lab / FEE assembly - successfully finished by Feb 6<sup>th</sup>
- Stress-bias recovery of the FTC-A4 MCP-PMT. It was masked out in 2023 due to a HV breakdown across the MCP. Successfully finished on Feb 12<sup>th</sup> – now monitoring how permanent the annealing effect is
- Investigation of the reason of the FTA-E2 MCP-PMT being spoiled with internal noise (highly likely increased ion backflow after a vacuum leak). Requires access to the Miniframe, planned for Feb 20<sup>th</sup> or Feb 26<sup>th</sup>
- FT0 **survey** done in January
- FT0 laser scans with solenoid on - planned for March 4<sup>th</sup>



FT0 photosensors' status by the end of 2023:



# YETS activities Gas System

## MCH:

- Humidifier construction and installation -> construction done and in use now
- Software updated for Humidifier -> Done
- System restarted on 05/02/2023

## TRD:

- Install pressure sensor on pump filter -> will be done week 7 or 8
- Pump temperature sensors to fix -> week 7
- trap for humidity -> to be discourse

## MID:

- Pump to repair to send to manufacturer -> The pump will arrive at CERN week 8 or 9, then installed
- Replace faulty sensor in distribution-> Done, leak test done too
- ALICE MID leak search in the exhaust -> to be finish



# YETS activities Gas System



## TOF:

- PURIF Change purif material for O2 trapping -> Done about 20-25% of molecularsieve remove and replaced by copper in the two purifier columns.
- PURIF change regeneration gas (Ar/H2) -> Done
- PURIF Detection head to be installed (Ar/H2) -> Done
- PURIF Khrono flow sensors to be replaced -> Done
- ALICE TOF Pump/distribution leak test -> no leaks found on gas system

## TPC:

- Commissioning of modified backup system -> February
- Find leak on pump and in case send to manufacturer -> To be tested again
- Purifier filter pressure sensor to be connected -> week 7 or 8


## Standard maintenance:

- Filter cleaning -> on going
- Checking safety valves -> on going
- Humidifiers filling -> on going
- **Flammable gases:** circulation of i-butane and ArH2 restarted after Xmas break, CH4 still will be restarted by mid-March




# TPC gas issue


- A new **gas leak** appeared, possibly due to a large temperature excursion in the TPC during chilled water maintenance (Nov 6<sup>th</sup>, 2023)
  - Oxygen intake resulted in signal loss; leak hunted without success
- While trying to stop this leak, gas composition affected
  - Gain too low
- Subsequent maintenance of magnet ventilation: 10 days off
- After recovering the composition, removing O<sub>2</sub>, and containing the leak, **unacceptable signal loss** still present
  - Suspect SF<sub>6</sub> intake while ventilation off
- Propose to **preventively replace the TPC gas**
  - Buy neon (now affordable) - one battery ordered
  - Flush with CO<sub>2</sub> for several days
  - Fill with Ne (1 week)
  - In parallel, try to analyse the gas
- Detailed presentation in TPC weekly meeting (<https://indico.cern.ch/event/1382694/>)



Temperature inside TPC (Celsius)



Kr spectrum (good) – 30 Oct 2023




Kr spectrum (bad) – 20 Nov 2023

# TOF/PHOS/EMCaI cooling plant corrosion inhibitor

- Control cubicle replaced
- New PLC program based on PVSS Unicos
  - It requires a complete change of the DCS system as there is no Modbus communication anymore. All the values are now shared through DIP
  - Users will have the same interface of EN-CV for the control of the plant
  - Already done for HMPID and TRD
- Maintenance
  - Replacement of the vacuum pump & modification to have a redundant one
  - Replacement of the chilled water valve
- Corrosion inhibitor injection
  - Injection during first week of January
  - Copper level being monitored closely – now 1.12 mg/l (was 1.8 last year)
  - The treatment helped to recover particles. Filters were already cleaned twice (last time this Tuesday)
- Plant was handed over to users on Monday 22<sup>nd</sup> January.

Point de prélèvement : TOF (cf. Greg)		
Date du prélèvement :		02 Février 2024
Date des analyses :		02 Février 2024
Analyse	Limite de détection	Mesuré Unité
Conductivité	-	20.44 µS/cm
pH	-	6.9
Turbidité	-	0
TH	-	4 °f
TA	-	0 °f
TAC	-	1.5 °f
Zinc	-	0 mg/l
Fer	0,009 mg/L	0.054 mg/l
FerTotal	-	- mg/l
Fer Filtré	-	- mg/l
Cuivre	0,04 mg/L	1.12 mg/l
Aluminium	0,01 mg/L	0.005 mg/l





# P2tech activities

- Clean SNIFFER tubes → Feb 14<sup>th</sup> PM
- Complete consolidation L3 flowmeters
- Laser cleaning HMPID frame → to be organized (Fabio, Philippe)



# Magnets status

- **L3 transformer update:** towards end December we were informed by SY-EPC of a suspected **water leak** in one of the two L3 transformers (refurbished during LS2). Oil samples sent in January to three different labs, so far results only from one. The result shows a water content still a bit too high, but much better than in the analysis of last year. The dielectric breakdown voltage is within the normal values. SY-EPC will be able to reenergize the transformer if the reports from the other labs confirm these results. If this is not the case, a spare transformer will be installed.
- Maintenance of the L3 polarity switch complete (SY-EPC)
- **Magnet test on Monday March 4<sup>th</sup> from 10:00 to ~21:00, with a polarity inversion around 15:00**
  - Dipole magnet will be ramped down around 15:00
  - Laser calibration run for FV0 with solenoid ON and no beam
  - EP RD& Robotic activity in parallel



# Other activities

- EN-HE:
  - Cranes load test in week 4 (23-24-25 January)
  - Maintenance UX25 crane aux hoist on Mon 29 January (use O-side nacelle)
  - Remove bateries nacelles on Tuesday 5 March
  
- EN-AA:
  - Maintenance PAD/MAD → no access UX25 18-19-22-23 January between 18:30 and 23:30
  - Maintenance UX25 cavern lift (AS-724) on Mon 5 Feb 6:00 AM to 8:00 AM
  - Installation new SG2 fire detection: 22-24 January
  - Fire, Gas and SNIFFER Maintenance – all done

ALICE Schedule Fire, Gas and SNIFFER Detection Systems EYETS 23-24			
4System	Buildings	Dates	Comments
Safety Test	Experimental Caverns UX25 + PX24	27/12/2023	All Day
CSAM Test	Experimental Caverns UX25	05/01/2024	From 8h00 to 13h00
BIW Test	Experimental Caverns UX25	12/02/2024	From 18h00 to 22h00
Gas Detection #1	Gas barrack SG2, CR5 and UX25 Cavern	01/11/2023 – 03/11/2023	Interlocks test of gas systems during maintenance duration 2 hours max in collaboration with EP/DT
Fire Detection #1	UX25 cavern and counting rooms	06/11/2023 TO 10/11/2023	
Fire Detection #2	UX25 Racks	18/01/2024 TO 24/01/2024	
SNIFFER #1	CR5 and UX25 cavern	14/02/2024	Test of level 3 alarms and DSS after all rotations are done
SNIFFER #2	CR5 and UX25 cavern	TBD	Air sampling network cleaning