

Technical Infrastructure (TI)

Facility Coordinator last week	Gildas Langlois
Facility Coordinator this week	Ronan Ledru
Statistics	
Alarms	
Phone calls	1393
ODMs	186
Facility Status	
Summary	
Issues	<p>Tuesday December 17th at 02:10 Emergency stop on BEQ1 Firefighters on site but nothing found After investigation from EN-EL, the button was full of water. The chain has been opened when the water has frozen</p> <p>Wednesday December 18th Grey water leak in building 5 Fire brigade and SCE on site to fix the issue Lift out of order because of the leak</p> <p>Friday Decembre 20th at 9h20 Fire on UPS EBS11/82 in RE82 Trip of EOD5/82 (Cryo and IT impacted) A Borri technician was already at CERN, so the UPS has been repaired during the day.</p> <p>Sunday Decembre 22th A tent has blow away from the traveller camp in the BE2 substation Fire brigade onsite for taking out the tent</p>
Plans	