



HSE
Radiation Protection

AWAKE Kick-Off – Radiation Protection Work Package

C. Ahdida, C. Saury

AWAKE Kick-Off 2024
16 July 2024

EDMS 3132880

Outline

1. Radiological Assessment
2. RP monitoring
3. Operational RP support
4. RP Safety File




RP assessment – Empty TCC4


Area	Annual dose limit (year)	Ambient dose equivalent rate		Sign RADIATION
		permanent occupancy	low occupancy	
Non-designated	1 mSv	0.5 µSv/h	2.5 µSv/h	
Supervised	6 mSv	3 µSv/h	15 µSv/h	
Simple Controlled	20 mSv	10 µSv/h	50 µSv/h	
Limited Stay	20 mSv	-	2 mSv/h	
High Radiation	20 mSv	-	100 mSv/h	
Prohibited	20 mSv	-	> 100 mSv/h	

Residual dose rates in the empty TCC4 tunnel


Top view




Cross-sect. view



Cross-sect. view + shielding



1d along x at CNGS horn




- The TCC4 tunnel will still exhibit elevated radiation levels after the CNGS dismantling due to activation of the tunnel itself
- Additional **shielding** in the most critical area – the CNGS horn location – is needed to bring radiation levels down to a **Simple Controlled Area** (50 uSv/h limit)
- **AWAKE Run 2c/d equipment** will be located **in the critical areas** → works in the tunnel (e.g. installation/maintenance of equipment) will need to take the radiological environment into account (preparation and dose optimization of works in the area)

Top view

1-2 m above floor

04/2026




RP assessment – Run 2 c/d

Area	Annual dose limit (year)	Ambient dose equivalent rate		Sign RADIATION
		permanent occupancy	low occupancy	
Non-designated	1 mSv	0.5 μ Sv/h	2.5 μ Sv/h	[Sign]
Supervised	6 mSv	3 μ Sv/h	15 μ Sv/h	
Simple Controlled	20 mSv	10 μ Sv/h	50 μ Sv/h	[Sign]
Limited Stay	20 mSv	-	2 mSv/h	
High Radiation	20 mSv	-	100 mSv/h	[Sign]
Prohibited	20 mSv	-	> 100 mSv/h	


- Electron beam loss scenarios have been studied
- Both e^- injectors are in TCC4 tunnel inaccessible during electron (and proton) beam operation
- The closest accessible area is TSG4, which is a Supervised Radiation Area with low occupancy (15 μ Sv/h limit)
- Two loss scenarios were studied:
 1. e^- source I beam losses – dipole polarity failure
 - Electron energy: 20 MeV
 - Beam size : $\sigma_x=135 \mu\text{m}$, $\sigma_y=133 \mu\text{m}$
 - Beam charge: 600 pC, 10 Hz rate (3.75e10 el/s)
 - Beam diagnostics by means of a 1.2 cm thick Cu Faraday Cup
 - Highest dose rates in TSG4 for dipole polarity failure
 2. e^- source II beam losses – dipole polarity failure
 - Electron energy: 150 MeV
 - Beam size : $\sigma_x=135 \mu\text{m}$, $\sigma_y=133 \mu\text{m}$
 - Beam charge: 150 pC, 10 Hz rate (9.38e9 el/s)
 - Beam diagnostics by means of a 5 cm thick Cu Faraday Cup at worst location (in front of TSG43)
 - Highest dose rates in TSG4 for dipole polarity failure

➤ Additional 35 cm concrete shielding on the TSG4 side next to the TSG43 passage + RP monitor w/ interlock are needed


FLUKA model for e^- loss verification



H*(10) for convolution of both loss scenarios




Dose rates along TSG43



RP monitoring for RUN2 c/d operation

Layout for RUN2 c / d




Monitors needed for RUN2 c / d (additional to already existing monitors):

- **3 PMI** monitors placed along the beamline (exact locations to be defined later depending on radiation losses)
- **1 IG-5** Argon chamber (number and exact location depends on shielding, access needs and final area design)
- **1 BAI** air activation monitor (could be omitted in case AWAKE accepts a given waiting time after beam prior to access)
- **1 dedicated X rays radiation detector** system allowing to interlock the **klystrons** (type to be defined, klystrons shielded)
- It shall be noted, that the **number of RP monitors might increase depending on the final design of Run 2 c/d**
- Thanks to the **re-use of existing CNGS equipment** and budget provided by the **HSE Ramses-2-Crome consolidation project**, the majority of budget needed for the **AWAKE run 2c/d monitors is already covered**


Operational RP aspects

- Run 2 c/d will occupy a significantly much **larger area** with **more equipment**
- Next to that the equipment will be in an area with **higher radiological risks** in view of the remaining tunnel activation from CNGS operation
 - **Limited Stay Radiation Area** before shielding installation
 - **Simple Controlled Radiation Area** during equipment installation and operation
- Run 2 c/d will require **more operational RP workforce** in view of higher radiological risks (Limited Stay and Simple Controlled Radiation Area)
 - Works strongly linked to activities in TCC4 and will include planning and dose optimisation, follow-up of dosimetry, RP surveys before/after shielding installations, surveying drillings for installations, etc.

Area	Annual dose limit (year)	Ambient dose equivalent rate		Sign
		permanent occupancy	low occupancy	
Non-designated	1 mSv	0.5 µSv/h	2.5 µSv/h	
Supervised	6 mSv	3 µSv/h	15 µSv/h	
Simple Controlled	20 mSv	10 µSv/h	50 µSv/h	
Limited Stay	20 mSv	-	2 mSv/h	
High Radiation	20 mSv	-	100 mSv/h	
Prohibited	20 mSv	-	> 100 mSv/h	





Residual dose rates empty tunnel



RP Safety File

- Similarly to AWAKE Run 1, an **RP Safety File** for **AWAKE Run 2** should be written
- As long as there are **no main differences** in **proton beam parameters** and **beam losses**, many aspects from Run 1 Safety File and operational experience can be included in the Safety File for Run 2
- Some main differences for Run 2 RP Safety File:
 - Empty tunnel studies
 - Accidental electron beam loss scenarios
 - Updated RP monitoring layout
 - In case additional RP studies for Run 2 c/d would be needed, such studies would have to be supported by an additional Fellow (EDMS 3024267)
- The RP Safety File should be finalised before the first beam operation together with the other Project Safety Files (demonstrative, descriptive)

AWAKE Run 1 RP Safety File

CERN CH1211 Genève 23 Suisse	N° EDMS 1719605 v.1	REV. 0.3	VALIDITÉ Released
	RÉFÉRENCE CERN-RP-2016-169-REPORTS-TN		
9 th of October 2017			
OCCUPATIONAL HEALTH & SAFETY AND ENVIRONMENTAL PROTECTION UNIT			
Safety File			
AWAKE Radiation Protection Aspects of the Design, Commissioning, Operation and Decommissioning			
Abstract			
DOCUMENT PRÉPARÉ PAR : Eduard Feldbaumer Sylvia Cipiccia Helmut Vincke	DOCUMENT VÉRIFIÉ PAR : Christelle Saury Yann Pira	DOCUMENT APPROUVÉ PAR : Stefan Roesler	
GROUPE D'APPROBATION			
 EDMS 1719605 v.1 status Released access Sensitive_context PDF from RP_AWAKESafetyFile_vs1_techNote.docx modified 2017-10-09 17:28			

