




Internal monitoring for Crab-cavities



Vivien RUDE
2024-10-14

HL-LHC Collaboration Triumf-STFC-CERN

From Teddy Capelli

Overview of assembly sequence - DQW CRYOMODULE for LHC

Activities performed in clean room

Step 1 **Step 2** **Step 3** **Step 4** **Step 5** **Step 6** **Step 7** **Step 8** **Step 9** **Step 10** **Step 11** **Step 12**

Additional STEP for validation tests:

- STEP 13 - Installation of the cryogenic lines
- STEP 14 - Installation of the cryogenic lines
- STEP 15 - Installation of the cryogenic lines
- STEP 16 - Installation of the cryogenic lines

Transport

- Transport trolley
- Lifting blocks
- Covers

M7 tests

- Cryogenic safety extensions
- Support jack
- Inclinometer
- Jumper
- Pump instrumentation box
- Vacuum instrumentation

LHC

- Beam extension lines
- Cryogenic safety extensions
- Jumper
- Wavoguides
- Pump instrumentation box
- WPS
- Inclinometer
- Support jack
- Cryogenic safety extensions
- Beam extension lines
- PS RM/LX

Technologies and contact

- Radiofrequency:** Claudio CALVO
- Survey/Alignment:** Maurizio SOGIN, Vivien RUDE
- Cryogenic lines:** Christophe BROZZINI/K, Laurent DELPRAT
- Vacuum:** Chiara PASQUINO, Riccardo FIORE, Vincent BARON, Valérie BAGIN
- Design:** Silvia CAPATINA, Remy ARTAUD, Teddy CAPPELLI, Luca DASSA
- Tuner:** Kurt ARTOOS, Pierre Minghelti

Manufacturing and contact


- CERN Manufacturing:** Matteo GARLASCHE, Simon BARRIÈRE
- STC:** Christophe FENELTON (STFC), Shaikat PATILKARWAR (STFC), Christophe BOUYE (LACORST), Andrew BENT (STFC), Carine GRILLERIS (STFC), Edward JORDAN (STFC)

WELDING ACTIVITY
WELD INSPECTOR - LEAK TEST

NOT UPDATED

	Step	
Part 0 : CMM data	0	Validation of trolley
		Position of the capacitive plates w.r.t. external references → CERN
		Valve plate measurement
Part 1 : in clean room	1-2	Alignment in ISO5 (before connection in ISO4)
		Alignment in ISO5 (after connection in ISO4)
Part 2 : before cryostating	4-5	Alignment of different equipment
		Installation of FSI supports
		Measurement of FSI supports
		Installation FSI targets
Part 3 : cryostating (top plate)	6	Alignment of the cavities before cryostating
		Measurement of the top plate cryomodule
		Alignment trolley and top plate
Part 4 : cryostating (OVC cryomodule)	10	Measurement of the OVC cryomodule
		Alignment top plate and OVC cryomodule
Part 5 : after cryostating	10	Installation of FSI heads on OVC and top plate
		Measurement of FSI heads on OVC and top plate
		FSI validation (comparison with a laser tracker)
		Alignment with adjustment system
Part 6 : cold test at STFC or Triumf	12	Measurement ambient pressure
		Measurement under vacuum
		Measurement at cold
Part 7 : cold test at CERN		Measurement ambient pressure
		Measurement under vacuum
		Measurement at cold

General principle : 3 objects \rightarrow 3 coordinate systems similar



Part 0 : CMM data

Step

0

Validation of trolley

Position of the capacitive plates w.r.t. external references → CERN

Valve plate measurement



Part 0 : CMM data


Step

0

Validation of trolley

Position of the capacitive plates w.r.t. external references → CERN

Valve plate measurement



Advice :

- Install fiducial points on both sides of the trolley.
- Test the trajectory of the component on the rails
- Test the impact of load on the trolley

Coordinate frame :

- Primary axis : Nominal axis (cavity line) → trajectory of the rails
- Secondary axis : Normal vector to vertical plane of rails
- Origin : Beginning of the rail

Part 0 : CMM data


Step

0

Validation of trolley

Position of the capacitive plates w.r.t. external references → CERN


Valve plate measurement



	Step	
Part 0 : CMM data	0	Validation of trolley
		Position of the capacitive plates w.r.t. external references → CERN
		Valve plate measurement

Final coordinate system (R-capacitive-plates):

- Y-axis (primary axis): Defined by the capacitive plate axis
- Z-axis (secondary axis): Defined from the projection of the center of circle FPC on line of the capacitive axis
- Origin: projection of the center of circle FPC on line of the capacitive axis.





	X (mm)	Y (mm)	Z (mm)
Flange_A_Inox	0	-500.857	-0.039
Flange_B_Inox	0	179.144	-0.254
Flange_FPC_Inox	0	0	234.834
Flange_HOM_A_Inox	0.381	-320.512	249.645
Flange_HOM_B_Inox	89.659	-274.265	-250.260
Flange_HOM_C_Inox	-90.249	-273.956	-249.957
Flange_pick_up_A_Inox	239.994	-385.315	-0.423
Flange_pick_up_B_Inox	240.000	65.110	-0.137
Line2 A	-194.522	-508.330	0.298
Line2 B	-194.489	187.668	0.335
C1	121.217	-0.148	214.856
C2	156.375	-304.377	214.999
C3	-184.520	-410.281	215.239
C4	223.532	-342.117	134.529
C5	223.371	47.401	134.695
C6	223.138	-296.469	-135.616
C7	223.011	-43.997	-135.468
C8	142.837	166.124	82.412
C9	-41.267	166.172	-144.759
C10	-142.858	166.060	132.874
C11	-305.115	30.952	135.617
C12	-304.967	-374.040	135.433
C13	-305.525	69.491	-109.469
C14	-305.465	-316.935	-134.642
C15	-41.117	-486.970	-145.082
C16	-142.617	-487.408	132.577
C17	143.050	-487.184	82.045
Tunning_BOTTOM	-0.947	-160.451	-369.724
Tunning_TOP	0.599	-160.218	369.329
Capacitive_plate_CENTER	0	-160.238	0
Capacitive_plate_IN	0	-250.538	0
Capacitive_plate_OUT	0	-70.099	0
Origine	0	0	0
Axe_X	1000	0	0
Axe_Y	0	1000	0
Axe_Z	0	0	1000
IN	0	-500.857	0
OUT	0	179.144	0

	Step	
Part 0 : CMM data	0	Validation of trolley
		Position of the capacitive plates w.r.t. external references → CERN
		Valve plate measurement

Coordinate system

For both Valve Plates,

- **X axis** – along the line passing through the centres of the two cylinders (**Secondary Axis**)
- **Y axis** – Normal to the measured 7 planes
- **Z axis** – Perpendicular to XY Plane (**Primary Axis**)



Valve Plate A


Part 1 : in clean room

Step

1-2

Alignment in ISO5 (before connection in ISO4)


Alignment in ISO5 (after connection in ISO4)



Please note:
No thermal contraction or movement due to vacuum is considered at this stage
(V. Rude, T. Capelli).


		X	Y	Z	Rx	Ry	Rz						
Valve plate 1	A1	0	+/- 0.5	--	--	0	+/- 0.5						
	A2	--	--	--	--	0	+/- 0.5						
	Vect Na	--	--	N	N	--	--	0	+/-3.8 mrad	--	--	0	+/-2.5 mrad
Cav 1	IN (Cap)	0	+/- 0.1	--	--	0	+/- 0.1	--	--	0	+/-1.2 mrad	--	--
	FPC	--	--	1065.25	+/- 2mm	--	--	--	--	--	--	--	--
	OUT (cap)	0	+/- 0.1	--	--	0	+/- 0.1	--	--	--	--	--	--
Cav2	IN (Cap)	0	+/- 0.1	--	--	0	+/- 0.1	--	--	0	+/-1.2 mrad	--	--
	FPC	--	--	2027.74	+/-	--	--	--	--	--	--	--	--
	OUT (cap)	0	+/- 0.1	--	--	0	+/- 0.1	--	--	--	--	--	--
Valve plate 2	B1	0	+/- 0.5	--	--	0	+/- 0.5	--	--	--	--	--	--
	B2	--	--	--	--	0	+/- 0.5	--	--	--	--	--	--
	Vect Nb	--	--	2504.5	+/- 5mm	--	--	0	+/-3.8 mrad	--	--	0	+/-2.5 mrad

	Step	
Part 2 : before cryostating	4-5	Alignment of different equipment
		Installation of FSI supports
		Measurement of FSI supports
		Installation FSI targets






Objective / Results :


- Cryogenic line : at 1 mm
- Oblong bellows plate : at 1 mm
- ...





	Step	
Part 2 : before cryostating	4-5	Alignment of different equipment
		Installation of FSI supports
		Measurement of FSI supports
		Installation FSI targets



	Step	
Part 2 : before cryostating	4-5	Alignment of different equipment
		Installation of FSI supports
		Measurement of FSI supports
		Installation FSI targets



Each FSI supports should be measured 3 times
 Max dispersion : 15 μm per axis



	Step	
Part 2 : before cryostating	4-5	<i>Alignment of different equipment</i>
		<i>Installation of FSI supports</i>
		<i>Measurement of FSI supports</i>
		<i>Installation FSI targets</i>




	Step	
Part 3 : cryostating (top plate)	6	Alignment of the cavities before cryostating
		Measurement of the top plate cryomodule
		Alignment trolley and top plate


Into taking in account vacuum, cold and hanging motions

— Nominal position
— Position after alignment

Vertical position of the cavities w.r.t. Nominal





Radial position of the cavities w.r.t. Nominal




	Step	
Part 3 : cryostating (top plate)	6	Alignment of the cavities before cryostating
		Measurement of the top plate cryomodule
		Alignment trolley and top plate

Top face of the upper plate
Vertical reference



Extremity face of the upper plate
Longitudinal reference



Lateral face of the upper plate
Transversal reference



R-top plate


Primary axis : Z : normal vector to top plate (on the edges)

Secondary axis : Y : normal vector to lateral face


Origin : center of the 3 planes shifted of :

- X = 390 mm
- Y = 0 mm
- Z = 565 mm

	Step	
Part 3 : cryostating (top plate)	6	Alignment of the cavities before cryostating
		Measurement of the top plate cryomodule
		Alignment trolley and top plate



The 2 coordinate systems should be at the same position





	Step	
Part 4 : cryostating (OVC cryomodule)	10	Measurement of the OVC cryomodule
		Alignment top plate and OVC cryomodule

Advice :

Install top plate on the OVC.

The coordinate system of the top plate will be the coordinate system of the OVC



R-top plate = R OVC

Primary axis : Z : normal vector to top plate (on the edges)


Secondary axis : Y : normal vector to lateral face

Origin : center of the 3 planes shifted of :

- X = 390 mm
- Y = 0 mm
- Z = 565 mm

	Step	
Part 4 : cryostating (OVC cryomodule)	10	Measurement of the OVC cryomodule
		Alignment top plate and OVC cryomodule

The 2 coordinate systems should be at the same position



OVC

	Step	
Part 5 : after cryostating	10	<i>Installation of FSI heads on OVC and top plate</i>
		<i>Measurement of FSI heads on OVC and top plate</i>
		<i>FSI validation (comparison with a laser tracker)</i>
		<i>Alignment with adjustment system</i>



EDMS :
2996397

	Step	
Part 5 : after cryostating	10	Installation of FSI heads on OVC and top plate
		Measurement of FSI heads on OVC and top plate + TANK position
		FSI validation (comparison with a laser tracker)
		Alignment with adjustment system

Legend


○ Station

⊞ Cryomodule



	Step	
Part 5 : after cryostating	10	Installation of FSI heads on OVC and top plate
		Measurement of FSI heads on OVC and top plate
		FSI validation (comparison with a laser tracker)
		Alignment with adjustment system

Should be less inside :
[-0.040 mm : 0.040 mm]






	Head	Target	FSI 3 D distance	Laser Tracker 3 D distance	Comparison
TANK 1	1	1			
TANK 1	2	2			
TANK 1	3	3			
TANK 1	4	4			
TANK 1	5	5			
TANK 1	6	6			
TANK 2	7	11			
TANK 2	8	12			
TANK 2	9	9			
TANK 2	10	10			
TANK 1	11	7			
TANK 1	12	8			
TANK 2	13	13			
TANK 2	14	14			
TANK 2	15	15			
TANK 2	16	16			

EDMS : 3065249



	Step	
Part 5 : after cryostating	10	Installation of FSI heads on OVC and top plate
		Measurement of FSI heads on OVC and top plate
		FSI validation (comparison with a laser tracker)
		Alignment with adjustment system

Should be less inside :
[-0.040 mm : 0.040 mm]



	Step	
Part 6 : cold test at STFC or Triumf	12	Measurement ambient pressure
		Measurement under vacuum
		Measurement at cold



Legend

-  Station
-  Cryomodule



	Step	
Part 6 : cold test at STFC or Triumf	12	Measurement ambient pressure
		Measurement under vacuum
		Measurement at cold



Legend

-  Station
-  Cryomodule



	Step	
Part 6 : cold test at STFC or Triumf	12	Measurement ambient pressure
		Measurement under vacuum
		Measurement at cold

Legend

-  Station
-  Cryomodule






**Thank you
for your attention**

SPARE


Alignment Objective n°1 : Fiducialisation

Cavity radio frequency axis \rightarrow Approximated to mechanical axis of the capacitive plate



Alignment requirement
Position : $50 \mu\text{m}$ (1σ)
Roll : $100 \mu\text{rad}$ (1σ)

Alignment Objective n°2 : Internal monitoring




Alignment requirement
Position : $< 100 \mu\text{m}$ (1σ)
Roll : $< 400 \mu\text{rad}$ (1σ)

Internal monitoring : Configuration

- FSI : Frequency Scanning interferometry**

→ Absolute distance measuring interferometric technique


Largest standard uncertainties	Uncertainty (1σ)
Position of the FSI Sensor in the framework of the cryomodule	40 μm
Position of the FSI target in the framework of the crab-cavity	<15 μm




FSI Head (sensor) on the Cryomodule



FSI target on the flange of Helium TANK of the cavities



FSI Acquisition system



Flange of Helium Tank of RF Crab-cavities


Internal monitoring : Challenges and prerequisites

Ambient pressure Measurement + Adjustment

The position of the FSI sensors w.r.t. cryomodule must be measured with an accuracy of less than 40 microns.

All adjustments should be carried out at ambient pressure.


ANTICIPATION : The position of the cavities should be at their nominal position at warm with an accuracy of less than 40 microns.



Under vacuum Anticipation

Anticipation of the Deformation of the outer envelope with an accuracy of less than 40 microns (deformation up to 1.2 mm)


Anticipation of the Movement of the cavities : (Complex movement up to 0.4 mm 6 DOF)



Cooling down Anticipation

Anticipation of the Deformation of the outer envelope with an accuracy of less than 40 microns (deformation up to 0.1 mm)

Anticipation of the Movement of the cavities : (Complex movement up to 1.2 mm 7 DOF)




The position of two cavities should be determined **at cold** at less than 0.1 mm (1sigma)

The position of two cavities **at cold** should be aligned **at less than 0.1 mm** (1sigma)

Two inner components

Non compensable misalignment on the external envelope

No possibility to adjust




Alignment analysis of the RFD prototype during cold test at CERN




Deformations of the cryomodule (due to pumping and cooling down)

No deformation was observed on the edge of the top plate during pumping.



During cooldown, the top plate observed a thermal contraction due to thermal convection between the thermal screen and the top plate --> not expected but repeatable--> Can be anticipated



Ambient pressure

Max deformation :
1.20 mm

Under vacuum

Max deformation :
0.12 mm

Cold

Shape Repeatability
For 3 cycles :

- Maximum dispersion : 67 μm
- Average dispersion : 18 μm

Shape Repeatability
For 3 cycles :

- Maximum dispersion : 57 μm
- Average dispersion : 16 μm

Shape Repeatability
For 3 cycles :

- Maximum dispersion : 68 μm
- Average dispersion : 17 μm

Shape of the cryomodule at ambient pressure
Repeatable at +/- 0.040 mm (RMS)

Shape of the cryomodule under vacuum
Repeatable at +/- 0.040 mm (RMS)

Shape of the cryomodule at cold
Repeatable at +/- 0.040 mm (RMS)

Relative Motions of the cavities due to vacuum and cooling down (cycle 3)

