


# Technical Infrastructure (TI)

**Facility Coordinator last week** Ronan Ledru


**Facility Coordinator this week** Jesper Nielsen

## Statistics


### Alarms



### Phone calls



### ODMs



<b>Facility Status</b>	
<b>Summary</b>	Quite a busy week with a fair amount of electrical emergency stop tests and general YETS work still ongoing.
<b>Issues</b>	<b>Thu 06/02/25 10:48</b> During the emergency stop tests in LHC P7 the lift got blocked. The lift seems to get blocked after a power cut, and requires a reset, which is not normal behaviour. A ticket has been filed with the external company.
<b>Plans</b>	