




ENGINEERING  
DEPARTMENT


# Cooling and ventilation studies

*F. Dragoni, N.Zaric/ EN-CV,  
HI-ECN3 WP4 – TARGET COMPLEX – COORDINATION MEETING #8 –  
30.01.2025.*

# BA82 building: Current cooling station



# BA82 building: Current cooling station



# BA82 building: Current cooling station

## Demineralized water – Now, given by Users

WP related	Site	Building	Position / room	User (Dep/Group)	Equipment	Number of equipment	Cooling parameters									Type of water		
							T <sub>in</sub> (°C)	T <sub>out</sub> (°C)	Flow / unit (l/min)	(m <sup>3</sup> /h)	Dissipated power / unit (kW)	Total dissipated Power (kW)	Pmax (bar)	Pressure drop (bar)	Total flow (m <sup>3</sup> /h)			
<b>Magnets</b>																		
MBHHE.X1010051	Prevessin	TCC8	ECN3	TE/MSC	PXMBHHEHWC	1	26	42	118	7.1	0.5	0.5	30	15	7.1	Demineralized		
MBHHE.X1010054	Prevessin	TCC8	ECN3	TE/MSC	PXMBHHEHWC	1	26	42	118	7.1	0.5	0.5	30	15	7.1	Demineralized		
MBHHE.X1010057	Prevessin	TCC8	ECN3	TE/MSC	PXMBHHEHWC	1	26	42	118	7.1	0.5	0.5	30	15	7.1	Demineralized		
MCXCA.X1010011	Prevessin	TCC8	ECN3	TE/MSC	PXMCXCAHWC	1	26	48	11	0.7	18.1	18.1	30	15	0.7	Demineralized		
MCXCA.X1010049	Prevessin	TCC8	ECN3	TE/MSC	PXMCXCAHWC	1	26	48	11	0.7	18.1	18.1	30	15	0.7	Demineralized		
MCXCA.X1010059	Prevessin	TCC8	ECN3	TE/MSC	PXMCXCAHWC	1	26	48	11	0.7	18.1	18.1	30	15	0.7	Demineralized		
MTR.X1010017	Prevessin	TCC8	ECN3	TE/MSC	SPMTR_HWP	1	26	35	66	4.0	33.0	33.0	30	15	4.0	Demineralized		
MTR.X1010021	Prevessin	TCC8	ECN3	TE/MSC	SPMTR_HWP	1	26	35	66	4.0	33.0	33.0	30	15	4.0	Demineralized		
MTR.X1010029	Prevessin	TCC8	ECN3	TE/MSC	SPMTR_HWP	1	26	35	66	4.0	33.0	33.0	30	15	4.0	Demineralized		
MTR.X1010033	Prevessin	TCC8	ECN3	TE/MSC	SPMTR_HWP	1	26	35	66	4.0	33.0	33.0	30	15	4.0	Demineralized		
QNL.X1010036	Prevessin	TCC8	ECN3	TE/MSC	SPQNL_8WP	1	26	46	28	1.7	14.0	14.0	30	15	1.7	Demineralized		
QNL.X1010041	Prevessin	TCC8	ECN3	TE/MSC	SPQNL_8WP	1	26	46	28	1.7	17.8	17.8	30	15	1.7	Demineralized		
QNL.X1010046	Prevessin	TCC8	ECN3	TE/MSC	SPQNL_8WP	1	26	46	28	1.7	14.0	14.0	30	15	1.7	Demineralized		
QNL.X1010061	Prevessin	TCC8	ECN3	TE/MSC	SPQNL_8WP	1	26	46	28	1.7	7.8	7.8	30	15	1.7	Demineralized		
QNRB.X1010005	Prevessin	TCC8	ECN3	TE/MSC	SPQNRB_8WP	1	26	47	27	1.6	3.6	3.6	30	15	1.6	Demineralized		
QNRB.X1010009	Prevessin	TCC8	ECN3	TE/MSC	SPQNRB_8WP	1	26	47	27	1.6	14.5	14.5	30	15	1.6	Demineralized		
QNRB.X1010013	Prevessin	TCC8	ECN3	TE/MSC	SPQNRB_8WP	1	26	47	27	1.6	8.1	8.1	30	15	1.6	Demineralized		
MBHHJ.X1010249	Prevessin	ECN3	ECN3	TE/MSC	PXMBHHJHWC	1	26	42	118	7.1	147.1	147.1	30	15	7.1	Demineralized		
MBXHD.X1010082	Prevessin	ECN3	ECN3	TE/MSC	PXMBXHDCWP	1	26	56	62	3.7	54.7	54.7	30	15	3.7	Demineralized		
MBXHD.X1010085	Prevessin	ECN3	ECN3	TE/MSC	PXMBXHDCWP	1	26	56	62	3.7	55.5	55.5	30	15	3.7	Demineralized		
MBXHD.X1010095	Prevessin	ECN3	ECN3	TE/MSC	PXMBXHDCWP	1	26	56	62	3.7	55.1	55.1	30	15	3.7	Demineralized		
MBXHD.X1010098	Prevessin	ECN3	ECN3	TE/MSC	PXMBXHDCWP	1	26	56	62	3.7	55.1	55.1	30	15	3.7	Demineralized		
MCXCA.X1010068	Prevessin	ECN3	ECN3	TE/MSC	PXMCXCAHWC	1	26	48	11	0.7	18.1	18.1	30	15	0.7	Demineralized		
MCXCA.X1010102	Prevessin	ECN3	ECN3	TE/MSC	PXMCXCAHWC	1	26	48	11	0.7	18.1	18.1	30	15	0.7	Demineralized		
MQNEG.X1010077	Prevessin	ECN3	ECN3	TE/MSC	PXMQNEGTWP	1	26	41	15	0.9	5.7	5.7	30	15	0.9	Demineralized		
MQNEG.X1010079	Prevessin	ECN3	ECN3	TE/MSC	PXMQNEGTWP	1	26	41	15	0.9	5.7	5.7	30	15	0.9	Demineralized		
QNL.X1010065	Prevessin	ECN3	ECN3	TE/MSC	SPQNL_8WP	1	26	46	28	1.7	5.4	5.4	30	15	1.7	Demineralized		
MDXSS.X1010090	Prevessin	ECN3	ECN3	TE/MSC	PXMDXSSCWC	1	26	36	12	0.7	8.3	8.3	30	15	0.7	Demineralized		
												<b>696.4</b>			<b>77.8</b>			
<b>Power converters</b>																		
RSM2	Prevessin	BA82	BA82	SY/EPC	RSM2	1	26	36	34	2.0	45	45	16	3	2.0	Demineralized		
												<b>45</b>			<b>2.0</b>			
<b>Vacuum pumps</b>																		
	Prevessin	ECN3	ECN3	TE/VSC	7 cryo pumps	7			0.15	0.009	0.10	0.73			0.063	Demineralized		
	Prevessin	ECN3	ECN3	TE/VSC	1 big turbo	1			1.67	0.1	1.15	1.15			0.1	Demineralized		
	Prevessin	ECN3	ECN3	TE/VSC	1 primary pump	1			3.33	0.2	2.31	2.31			0.2	Demineralized		
												<b>4.19</b>			<b>0.363</b>			
	Prevessin			EN/EL	<b>Water cooled cables</b>							200			17.30	Demineralized		
					<b>EHN2/Amber facility</b>							4000			105	Demineralized		
												<b>Σ</b>	<b>4945.5</b>			<b>Σ</b>	<b>202.5</b>	



# BA82 building: Current cooling station

## Demineralized water – Nominal values

	T <sub>in</sub> (°C)	T <sub>out</sub> (°C)	P <sub>max</sub> (bar)	Pressure drop (bar)	Total dissipated Power (kW)	Total flow (m <sup>3</sup> /h)	Type of water
Magnets	26	35-42-46-56	30	15	696.4	77.8	Demineralized
Power converters	26	36	16	3	45	2	Demineralized
Vacuum pumps					4.19	0.363	Demineralized
Water cooled cables					200	17.3	Demineralized
EHN2/Amber facility					4000	105	Demineralized
				Σ	4945.59	202.46	

Current measurement:  
Cooling capacity: 6.0MW  
Flow rate: 290 m3/h

## Demineralized water - Future


	T <sub>in</sub> (°C)	T <sub>out</sub> (°C)	P <sub>max</sub> (bar)	Pressure drop (bar)	Total dissipated Power (kW)	Total flow (m <sup>3</sup> /h)	Type of water
1st cooling substation							
Power converters	26	36	16	3	206	18.12	Demineralized
					4.19	0.363	Demineralized
2nd cooling substation					450	35	Demineralized
SHIP					200	17.3	Demineralized
Water cooled cables					3300	105	Demineralized
EHN2/Amber facility							
3rd. 4th, 5th cooling substation							
Target Proximity shielding					380	65.76	Demineralized
Magnetic coil	27	30-33.7-35.6					
					Σ	4540.19	241.54

Chilled water – in progress  
Mixed water needs – no need so far

# BA82 building: Current cooling station

## Demineralized water – measurement results

	Total cooling Power (kW)	Total flow rate (m <sup>3</sup> /h)	Type of water
ECN3, TCC8 branch: Magnets, Power converters, WC cables, vacuum pumps, NA62 experiment	2700	185	Demineralized
EHN2/Amber facility	3300	105	Demineralized
<b>Σ</b>	<b>6000</b>	<b>290.00</b>	



Current measurement:  
Cooling capacity: 6.0MW  
Flow rate: 290 m3/h

# BA82 building: Current cooling station

---

- **Current status:**

- Demineralized water: We will have enough power & flow rate in future
- Chilled water: collected data, 4.35MW maximum power, nominal 4.4MW;

Additional chilled water needs in future:

- Beryllium facility: 200kW
- New service building: 250kW
- We have to “recover” 450kW from the chilled water loads, NA62 experiment 2 AHUs will be removed, mixed water circuit to be removed, total capacity to be recovered about 150kW
- Maximum capacity (4.35MW) happened only once
- 46 times (hours) we had capacity more than 3.9MW
- Mixed water: no needs so far

- **Preparing for the TCC on cooling meeting – status for 5<sup>th</sup> cell of CT2, presenting results of consumption analysis, requests from Users side, strategy for implementation of HI-ECN3**
- **User requirements’ document – in progress**




# BA82 building: Current cooling station

Demineralized water – Nominal values

	Total dissipated Power	Total flow	Type of water
	(MW)	(m <sup>3</sup> /h)	
ECN3, TCC8 branch: Magnets, Power converters, WC cables, vacuum pumps, NA62 experiment	2.7	185	Demineralized
EHN2/Amber facility	3.3	105	Demineralized
<b>Σ</b>	<b>6</b>	<b>290.00</b>	




Current measurement:  
Cooling capacity: 6.0MW  
Flow rate: 290 m<sup>3</sup>/h

Demineralized water - Future



Pending final verification BA82 stations for EHN2, TCC8 and ECN3 have sufficient power and flow rate

# New service building: Integration model



Current status: enough space for all the skids



[home.cern](http://home.cern)