

LHC Injectors Upgrade





LHC Injectors Upgrade



PSB Main Power Supply

Serge Pittet

Jean-Paul Burnet, Karsten Kahle, Fulvio Boattini, Max Chamiot-Clerc




- Overview of the existing Booster MPS system.
- The 2GeV requirements.
- LIU baseline: The “POPS” style alternative.
- Technical alternatives.



Booster MPS load characteristic

16 periods, 4 rings



	Magnets quantity	Total resistance [mOhms]	Total inductance [mH]
Dipoles outer ring	64	172	64
Focusing quadrupoles	128	74	8
Reference magnet	4	10	4
Defocusing quadrupoles	64	51	6
Dipoles inner ring	64	172	64
Total	324	479	146



Booster MPS circuit



1.4GeV margins:



MPS voltage: **-2%**

MPS peak current: **-2%**

MPS rms current: 3%

TRIM A peak current: 40%

TRIM Q peak current: 0%





Booster MPS: the eighties

TE
EPC






Booster MPS: 1998 consolidation

Automation & firing



Trims





- Overview of the existing Booster MPS system.
- The 2GeV requirements.
- LIU baseline: The “POPS” style alternative.
- Technical alternatives.



LIU project scaling factors



- From 1.4 GeV to 2 GeV. B-field: x1.3
- Considering some saturation effect, margin for B-field regulation and operation. Peak Current: x1.4
- Power dissipation in the magnets with today's ramp rate Power: x2
Far from design margins (20-30%)...
- Power dissipation in the magnets with existing MPS at maximal ramp rate. Power: x1.8
Better but not enough...

New magnets and/or new MPS needed in any case





The existing Booster MPS at 2 GeV

Upgrade scaling on one cycle

MPS peak current: **+30%**



MPS rms current: **+35%**

18kV apparent power: **+77%**

18kV peak power: **+45%**

TRIM A peak current: **+540%**

TRIM Q peak current: **+40%**






Impact on the 18kV Meyrin network



Fast transients with 2GeV cycle which can not be compensated by Meyrin SVC.

50% increase of active power, 30% increase of reactive power





- Overview of the existing Booster MPS system.
- The 2GeV requirements.
- **LIU baseline: The “POPS” style alternative.**
- Technical alternatives.




“POPS” basic principles



The energy to be transferred to the magnets is stored in capacitors.

- DC/DC converters transfer the power from the storage capacitors to the magnets.
- Four flying capacitor banks are not connected directly to the mains. They are charged via the magnets.
- Only two AC/DC converters (called chargers) are connected to the mains and supply the losses of the system.

Power to the magnets:



Power from the mains



Flying capacitors




LIU Baseline: Fast cycle



2 GeV with 5kV limitation (2320A_{RMS})

— Inner Ring Current [A] — Load voltage [V]
— Load power [kW] — Network power [kVA]




Upgrade scaling on one cycle

MPS peak current: +30%

MPS rms current: +3%


18kV apparent power: -26%

18kV peak power: -78%





LIU-PSB 5.2 WU- MPS power converter





Benefits

- Overall voltage available increases and would allow a reduction of the RMS current using a faster ramping.
- The capacitor bank totally absorbs the peak power on the 18kV network. Meyrin SVC would then become optional.
- Spare sharing between MPS A and B and eventually with POPS.
- Only a few new cables needed between the reference magnet (BCER) and the MPS.
- New B-field regulation to minimize eddy currents and saturation effects impact at higher current and acceleration rate.

Drawbacks

- Cost.






LIU-PSB 5.2 WU- MPS civil engineering




physics		LS1	physics			LS2	physics	
2011	2012	2013	2014	2015	2016	2017	2018	2019

- 2011: Civil engineering pre-study completed
- 2012: Civil engineering designed
- 2013: Civil engineering heavy workload done
- 2014: Building infrastructure & services ready




With this new building:

- We can install and commission during Booster operation.
- We have a backup power supply during the first years.
- Easy connection to existing cables and cooling services.





Building 245 - Preliminary Drawing





- Overview of the existing Booster MPS system.
- The 2GeV requirements.
- LIU baseline: The “POPS” style alternative.
- **Technical alternatives.**




Existing MPS with new magnets




- Preliminary design of the magnets by TE-MS: $R=0.52\Omega$, $L=0.42H$, $I_{nom}@2GeV=3500A$.
- Simulation shows that the existing MPS could be reused (consolidation still needed!).
- Stress on the meyrin 18kV network similar to what is measured today at 1.4GeV.

Voltage and current



POWER DRAWN FROM 18KV GRID:
2GEV THYR BASED MPSB New Mags







New MPS with new magnets

- Allows fast cycle and significant reduction of the RMS current in the magnets.
- Cost of an adapted POPS style MPS to be compared to the consolidation cost of the existing one.




TE
EPO






Comments on Power Consumption

- Values plotted below are based on the existing magnets, 5000 hours of operation per year and 0.051CHF/kWh (average price in 2010).
- In any cases several MCHF would be saved on a new supply and/or on electricity consumption with new magnets.
- **Does not include a foreseeable increase of the price per kWh.**





LHC Injectors Upgrade

THANK YOU FOR YOUR ATTENTION!

