


# Alarm statistics w06-07

G. Rigoletti



EP-DT  
Detector Technologies

# Alarms w06-07



Andrea (05 Feb - 12 Feb)

- TGC regulation valve alarm
  - Due to purifier swap
- ATLAS RPC L water level
  - Warning received but ok to run for the weekend, no actions taken
- ATLAS RPC Purifier 1 column A pressure during regeneration too high
  - switched to column 2
- ATLAS RPC purif 1 col A pressure during regeneration too high
  - Received again, one manual valve was closed