



***ILC CFS BASELINE
TECHNICAL REVIEW***

AMERICAS REGION LIFE SAFETY

***CONVENTIONAL FACILITIES
AND SITING***

V. Kuchler, J. Niehoff


Basis of Design and Analysis

- **National Fire Protection Association**
 - **Key Elements**
 - **Building portion within a subterranean space, NFPA 101 Life Safety Code.**
 - **Subterranean space, NFPA 520, Standard for Subterranean Spaces**


Key Components of NFPA 520

- ***Defines common space as the area of the developed subterranean space other than buildings; Hughes Engineering has defined the tunnel space as the common space***
- ***Travel distance through common space to a portal, or refuge area, or exit shall not be more than 610 m (2,000 ft)***
- ***Width of an exit not less than 112 cm (44 in) except with magnet mover or non-fixed equipment can be reduced to 56 cm (22 in)***
- ***Two paths of egress required at all locations***

Main Linac Cross Section



Damping Ring Cross Section



Analysis

- *Hughes Engineering prepared a Life Safety/Fire Protection Requirements Report based on NFPA 520*
- *Hughes Engineering developed Fire Models to verify NFPA 520 and their Report requirements*
- *Fire modeling was conducted using a computational fluid dynamics, known as Fire Dynamics Simulator (FDS) developed by NIST*



LIFE SAFETY/FIRE PROTECTION ANALYSIS

for

**THE INTERNATIONAL LINEAR COLLIDER
Single Deep or Near Surface Tunnel Options**

Prepared by



HUGHES ASSOCIATES, INC.
FIRE PROTECTION ENGINEERS
CODE CONSULTANTS

September 18, 2009
Revised May 21, 2010

Hughes Associates, Inc.
1420 Kensington Road
Suite 102
Oak Brook, IL
60523-T 630.368.0660
F 630.368.0667
www.haifire.com

**FIRE AND EGRESS ANALYSIS FOR THE
INTERNATIONAL LINEAR COLLIDER
(DRAFT)**

Prepared for

Fermilab
Kirk Road & Pine Street
P.O. Box 500
Batavia, IL 60510

Prepared by



HUGHES ASSOCIATES, INC.
FIRE SCIENCE & ENGINEERING

3610 Commerce Drive, Suite 817
Baltimore, MD 21227-1652
410-737-8677 Fax: 410-737-8688

December 9, 2011

Rev 0



Approach



- Research tunnel fire dynamics
- Model representative tunnel fire scenarios using (FDS) to analyze the effects of:
 - Smoke movement
 - Fire size
 - Fire location (tunnel or base cavern)
 - Sprinklers
- Determine the time required for occupants to evacuate
- Determine the maximum fire size that will allow occupants to evacuate safely






Main LINAC Tunnel Geometry

22 m long near-field
tunnel section



5 inch cells – isometric
view showing grid



Fire modeled in
center of high-fidelity
tunnel section


400 m long tunnel
section.





Base Cavern and Tunnel Geometry


- Base cavern modeled using 10 inch cells
 - Base cavern height assumed to be approximately the same height as tunnel






Curved Damping Ring Tunnel Geometry

- Curved and straight tunnel sections modeled



Tunnel Fire Dynamics


- Smoke movement in level, naturally ventilated tunnels



Near the fire, the smoke layer is hot (strong buoyancy) and remains close to the ceiling with little mixing.

As the smoke moves away from the fire, cooling occurs causing smoke to lose buoyancy. Descending smoke mixes with the entrained air and is drawn back towards the fire. This is referred to as "back-layering"








Summary of Main LINAC Tunnel Fire Results

Tunnel Diameter (m)	Limiting Fire Size (kW)	Maximum Fuel Spill Area (m ²)	Maximum Unconfined Spill Rate (L/min)
4.5	750	0.8	1.3
5.0	1,000	1.0	1.7
5.5	1,100	1.1	1.9
6.5	1,500	1.4	2.6

- **Results for Main LINAC apply to straight portions of damping ring tunnel**
 - Smoke movement is essentially the same in straight tunnels of the same diameter. The difference in obstructions between the Main LINAC and damping ring have a minimal effect.



Main LINAC Tunnel Fire Results




Travel speed required to outrun back-layering = 1.03 m/s
Travel speed required to stay ahead of smoke layer = 0.63 m/s

SFPE Handbook for Fire Protection Engineering uses 1.25m/s as Average Unrestricted Walking Speed



Main LINAC Tunnel Fire Results

6.5 m Ø Main LINAC Tunnel, 1500 kW Fire, Sprinklers
Plan View – Visibility Slice 6 ft above Floor



SFPE Handbook for Fire Protection Engineering uses 1.25m/s as Average Unrestricted Walking Speed





Summary of Base Cavern Fire Results


Tunnel Diameter (m)	Limiting Fire Size (kW)	Maximum Fuel Spill Area (m ²)	Maximum Unconfined Spill Rate (L/min)
4.5	3,000	2.4	5.1
5.0	4,000	3.0	6.8
5.5	4,500	3.3	7.7
6.5	6,000	3.6	10.2

- Limiting fire sizes in base cavern increase significantly over straight tunnel sections
 - Smoke spills out of the base cavern and impacts tunnel walls causing the ceiling jet velocity to decrease



Base Cavern Fire Results

4.5 m Ø Main LINAC Base Cavern, 3000 kW Fire, Sprinklers
Plan View – Visibility Slice 6 ft above Floor




Travel speed required to outrun back-layering = 0.83 m/s
Travel speed required to stay ahead of smoke layer = 0.62 m/s

**SFPE Handbook for
Fire Protection
Engineering uses
1.25m/s as Average
Unrestricted Walking
Speed**



Base Cavern Fire Results

6.5 m Ø Main LINAC Base Cavern, 6000 kW Fire, Sprinklers
Plan View – Visibility Slice 6 ft above Floor



Travel speed required to outrun back-layering = 0.94 m/s
Travel speed required to stay ahead of smoke layer = 0.73 m/s

**SFPE Handbook for
Fire Protection
Engineering uses
1.25m/s as Average
Unrestricted Walking
Speed**





Summary of Damping Ring Fire Results


Tunnel Diameter (m)	Limiting Fire Size (kW)	Maximum Fuel Spill Area (m ²)	Maximum Unconfined Spill Rate (L/min)
4.5	2,500	2.0	4.3
5.0	3,250	2.5	5.5
5.5	4,000	3.0	6.8
6.5	5,000	3.6	8.5

- Results apply to curved sections of damping ring
- Limiting fire sizes in curved section of tunnel increase over straight tunnel section
 - The speed at which smoke descends to head-level decreases due to the curvature of the tunnel
- The straight tunnel sections of the damping ring represent limiting fuel spill quantities for the damping ring



Damping Ring Tunnel Fire Results

4.5 m Ø Damping Ring Tunnel, 2500 kW Fire, Sprinklers
Plan View – Visibility Slice 6 ft above Floor




Travel speed required to outrun back-layering = 0.98 m/s
Travel speed required to stay ahead of smoke layer = 0.5 m/s





Damping Ring Tunnel Fire Results

6.5 m Ø Damping Ring Tunnel, 5000 kW Fire, Sprinklers
Plan View – Visibility Slice 6 ft above Floor



Travel speed required to outrun back-layering = 0.91 m/s
Travel speed required to stay ahead of smoke layer = 0.65 m/s



Fire Location	Tunnel Diameter (m)	Limiting Fire Size (kW)	Maximum Fuel Spill Area (m ²)	Maximum Unconfined Spill Rate (L/min)
LINAC / Straight Damping Ring Tunnel	4.5	750	0.8	1.3
	5.0	1,000	1.0	1.7
	5.5	1,100	1.1	1.9
	6.5	1,500	1.4	2.6
Base Cavern	4.5	3,000	2.4	5.1
	5.0	4,000	3.0	6.8
	5.5	4,500	3.3	7.7
	6.5	6,000	3.6	10.2
Curved Damping Ring Tunnel	4.5	2,500	2.0	4.3
	5.0	3,250	2.5	5.5
	5.5	4,000	3.0	6.8
	6.5	5,000	3.6	8.5

Ventilation

- *Each exit passageway and access portal will be designed to provide positive air pressure not less than 12.5 N/m² (0.05 inch per water column)*
- *Each refuge are will be design to provide air quantity of 944 L/s (20 cfm) per person and positive air pressure not less than 12.5 N/m² (0.05 inch per water column)*
- *Smoke control system is not required*

Drawings Developed for Final Report




MULTIPURPOSE FIRE EXTINGUISHER



FIRE DEPARTMENT AUTOMATIC
SPRINKLER CONNECTION - SIAMESE



FIRE HYDRANT




FIRE DEPARTMENT HOSE VALVE
CONNECTION



EMERGENCY TELEPHONE



ACCESSIBLE EMERGENCY EXIT ROUTE



DIRECTIONAL ARROW



ILLUMINATED EXIT SIGN (2 SIDES)




ILLUMINATED EXIT SIGN (1 SIDE)




ELEVATOR


Access Portal at Shaft Base Cavern



Area of Refuge



NOTE:
AREA OF REFUGE SHALL BE
OUTFITTER WITH FOOD, DRINKING
WATER, EMERGENCY LIGHTING,
BLANKETS, TOILET FACILITIES,
AND FIRST AID KITS.



Fire Protection Requirements

- ***Automatic sprinkler protection provided throughout the facility***
- ***Class I standpipe, fire department hose valves throughout***
- ***Fire extinguishers throughout the facility***
- ***Fire hydrants provided at surface of Service Buildings/Access portals***

Fire Detection/Alarm Requirements

- ***Two-way fire department communication system provided throughout the facility***
- ***Emergency voice alarm system provided throughout the facility***
- ***Smoke detection provided throughout tunnel and cavern***
- ***Manual pull stations located at each access portal, exit gallery, spaced 122 m (400 ft) along tunnel***

Fire Command Stations

- ***Located at service building(s)***
- ***Two-way fire department communication controls***
- ***Emergency voice alarm controls***
- ***Heat, smoke, sprinkler water status***
- ***Graphic annunciator of complex***
- ***Status indicators of elevators, emergency and standby power systems***