



Radiation safety evaluation for “KAMABOKO” Main Linac Tunnel



KEK-APL : T.Sanami, S.Ban

KEK-ACC : A.Enomoto, M.Miyahara

ILC Mechanical & Electrical Review and CFS Baseline Technical Review
at CERN (21-23 March 2012)

Background

Cost optimization for RDR design



“KAMABOKO” single tunnel with
Separation wall



-Two tunnel area with affordable cost

Advantage:

Service tunnel

Higher ceiling

Controllable shield thickness



Radiation safety design

Radiation Safety design for ILC-ML tunnel

Direct radiations

Thickness of the wall

Design for special sections


- Personal passage way, Waveguide hole, penetrations, tune-up dumps, collimators, etc

Induced activities

Activity in air, water

Damage for devices

Operation and decommissioning



Methodology

Beam loss :

1 W/m for normal operation (Not authorized yet)

18 MW for system failure

Limitation :

20 mSv/event/year (KEK) (How many events ?)

20 μ Sv/h for normal operation (KEK)


Tools :

Bulk wall thickness : Jenkins empirical equation




Maze and holes : MARS Monte-Carlo code

Induced activity : IAEA technical rep. 188 (Swanson)

Bulk wall thickness



Personal passage way+ Waveguide hole




Model for Monte-Carlo calculation


90 cm width crank with one 10cm thick iron slide door

Materials		
IM	Name	Modify
-1(on)	BHOLE	
0(on)	VAC	
1(on)	CU	
2(on)	STST	
3(on)	AIR	
4(on)	CONC	
5(on)	W	
6(on)	PB	
7(on)	LHE	
8(on)	YOKE	
9(on)	AR	
10(on)	W	
11(on)	BE	
12(on)	SI	
13(on)	AL	
14(on)	CH2	
15(on)	SOIL	
16(on)	CONC	
Reset		

Plan view



Elevation view




Uniform line loss along the beam line




1 mrad grazing angle

Dose rate for 1 W/m uniform loss

Plan view




Elevation view



1 $\mu\text{Sv/h}$ for 1 W/m $< 20 \mu\text{Sv/h}$

Radioactivity in air

	Beam loss rate	Length of ventilation unit	Total exhaust time	Beam loss power	Fraction of energy deposit to air	L_path	Unit volume	Surface area	Thermal neutron production rate	Neutron production rate
	W/m	m	h	kW		m	m ³	cm ²	n/s	n/s
ILCML air condition unit	1	5000	3	5	0.01	2	89000	78250	4.8E+9	9.5E+12



Radioactivity in air

Nuclide	Saturation activity	Saturation activity concentration	Limit of activity in air	Limit of activity in exhaust	Ratio to air limit	Ratio to exhaust limit	Half life	Cooling time	Ratio to exhaust limit after cooling
	Bq/m/kW	Bq/cm3	Bq/cm3	Bq/cm3			h	h	
3-H	5000000	5.61798E-06	0.8	0.005	7E-06	0.0011	106872		
7-Be	1000000	1.1236E-06	0.5	0.002	2E-06	0.0006	1286.4		
11-C	10000000	1.1236E-05	0.2	0.0007	6E-05	0.0161	0.34		
13-N	520000000	0.00058427	0.2	0.0007	0.0029	0.8347	0.166	0.1	
15-O	56000000	6.29213E-05	0.2	0.0007	0.0003	0.0899	0.034		
38-Cl	220000	2.47191E-07	0.3	0.003	8E-07	8E-05	0.62		
39-Cl	1500000	1.68539E-06	0.3	0.003	6E-06	0.0006	0.9367		
41-Ar		6.52484E-05	0.1	0.0005	0.0007	0.1305	1.83		
Total					0.004	1.0734			0.5995

Radioactivity in water

Cooling water inside the accelerator tunnel

Closed loop water pipes

1 W/m loss
for 5000 m

5000 m long
2 "diam. X 2

	Beam power	Beam loss fraction	Beam loss power	Amount of cooling water	Ratio to deposit power
	kW		kW	cm ³	
ILCML tunnel unit	1.80E+04	0.0002778	5.000E+00	2.03E+07	0.0020

Nuclide	Saturation activity factor	Saturation activity	Limit of radioactivity in wastewater	Ratio to limit	Half life	Cooling time	Ratio to limit after cooling time
	GBq/kW	Bq/cm ³	Bq/cm ³		h	h	
3-H	7.40E+00	3.65	6.00E+01	0.061	106872.00		0.06
7-Be	1.48E+00	0.73	3.00E+01	0.024	1286.40		0.02
11-C	1.48E+01	7.30	3.00E+02	0.024	0.34	1	0.00
13-N	3.70E+00	1.83	5.00E+00	0.365	0.17		0.00
15-O	3.30E+02	162.83	5.00E+00	32.566	0.03		0.00
total				33.04			0.09

Conclusion

“KAMABOKO” tunnel design is evaluated
from radiation safety view point

- The basic concept has possibility to meet requirements of radiation safety criteria
- Beam loss powers and conditions are important for further evaluation

The outstanding merits of “KAMABOKO” tunnel,
Two tunnel area with affordable cost,
Shorter penetrations, Easier installation,
Additional space for utilities,
can accommodate with radiation safety design

Spare slides

RDR Tunnel design

Geological conditions

(7.5 m separation between two tunnels)

Penetration for waveguides


(48cm diam. with 7.5 m long)

Personal passage way


(Every 500 m, 90 cm width

Dose rate for 18 MW

maximum credible beam loss



Tunnel separation design



Personal passageway


Ideas:

Keep bulk wall thickness as 3.5 m


1.6 m additional thickness with 8 m long available

Maze structure

Partially use heavy concrete




Elevation view



Elevation view

Thinner wall above 3 m




Shorten a waveguide hole

Smaller hole size

Easy installation


Additional space for utilities

Dose rate for 18 MW point loss




250 mSv/h for 18MW

Dose rate for 18 MW point loss




250 mSv/h for 18MW

Radioactivity in groundwater




$\sim 1 \text{ mSv/h}$



$\cong 5 \text{ mSv/h}$ (Depend on environment)


WAVEGUIDE HOLE



250 mSv/h for 18MW

CRANK WITH DOOR


90 cm width crank with one 10cm thick iron slide door



Pseudo Target for 18 MW point loss

WAVEGUIDE HOLE

30 cm diam., 2m long waveguide hole at 3m above FL



Pseudo Target for 18 MW point loss

Radioactivity in water

Nuclide	Saturation activity factor	Saturation activity	Limit of radioactivity in wastewater	Ratio to limit	Half life	Cooling time	Ratio to limit after cooling time
	GBq/kW	Bq/cm ³	Bq/cm ³		h	h	
3-H	7.40E+00	3.65	6.00E+01	0.061	106872.00		0.06
7-Be	1.48E+00	0.73	3.00E+01	0.024	1286.40		0.02
11-C	1.48E+01	7.30	3.00E+02	0.024	0.34	1	0.00
13-N	3.70E+00	1.83	5.00E+00	0.365	0.17		0.00
15-O	3.30E+02	162.83	5.00E+00	32.566	0.03		0.00
total				33.04			0.09