



**n-TOF review**

# **HVAC and cooling systems**

YB-JIG 15/06/07



# HVAC system

# HVAC system proposal #1

## Principle


- 100% recycling
- No pressure control
- Area treated comprise between doors 202 & 203

## Air Handling Unit

- An access section with door
- A filter section
- An access section with door
- A filter section, absolute filter
- A fan section with centrifugal fan, and one speed motor
- Tapping for RP monitoring system

## Estimate

Total : 35 kCHF





# HVAC system proposal #2

## Principle

- One 100% recycling AHU + one extraction AHU
- No pressure control
- Area treated comprise between doors 202 and 203
- AHUs located in bldg. 375

## Air Handling Units

- recycling AHU same as for proposal #1
- Extraction to be designed in accordance with the RP requirements for contaminant dispersion.
- By-pass of the extraction filters for cold smoke extraction

## Estimate


35 kCHF (AHU1) + 40 kCHF (AHU2) + 15 kCHF (electrical) + 40 kCHF (CE works)

Total : 130 kCHF

## Operating modes

- To be determined
- Smoke extraction policy to be defined

# HVAC system proposal #2



xxxx- nTOF  
 Unité pour mesures RP + extraction + by-pass extraction fumées  
 Schéma de principe - Principle schematic



ORGANISATION EUROPÉENNE POUR  
 LA RECHERCHE NUCLÉAIRE  
 EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH  
 GENEVE

Ouvrage 0802

INDICE



# HVAC system proposal #3

## Principle

- One 100% recycling AHU + one extraction AHU + one fresh air AHU
- Differential pressure control
- Area treated comprise between doors 202 and 203
- AHUs located in bldg. 375

## Air Handling Units

- Recycling AHU, extraction AHU same as for proposal #2
- Fresh air AHU fitted with heating and cooling coils

## Estimate


35 kCHF (AHU1) + 40 kCHF (AHU2) + 15 kCHF (electrical) + 40 kCHF (CE works) + 50 kCHF (AHU3)

Total : 180 kCHF

## Operating modes

- To be determined
- Smoke extraction policy to be defined

# HVAC system proposal #3



xxxx- nTOF


Unité pour mesures RP + extraction + by-pass extraction fumées + air neuf  
Schéma de principe - Principle schematic



ORGANISATION EUROPÉENNE POUR  
LA RECHERCHE NUCLÉAIRE  
Porte 203 EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH  
GENÈVE


Ouvrage 0802

INDICE



exhausts






exhausts



exhausts





# Water cooling system



# Water cooling system : proposal #1

## Present state

- Contamination of the pipes with radioactive isotopes (higher degree of contamination in the lower part)

## Cleaning proposal

- Installation of a high capacity ion-exchange cartridge (200l)
- Circulation of water through the circuit (target removed) and recuperation of the contaminant in the resin
- If required, cleaning of the circuit with a nitric acid


## Waste disposal

- Regeneration of the cartridge and treatment of the regeneration wastewater (possibility to store the cartridge for a given time before treatment) at CERN
- If required, neutralization of the acid and treatment at CERN

## Estimate

- Around 15kCHF

# Water cooling system : wastewater treatment





# Water cooling system : proposal #2

Dismantling of the distribution circuit and installation of a new one (to be decided if the cooling station is replaced)

## **Estimate**

- Estimate based on CV contract pricelist : < 60 kCHF
- 3-5 weeks of work

## **Constrains**

- No CV Contractors qualified for this work

## **Consequences**

- Need to launch MS and IT (technical specification to be written, delay for the answers and signature of the contract, ...)
- Planning : MS 6 weeks, IT 6 weeks, award of contract 3 weeks, works (incl. design + execution) 6 weeks

# Summary

<b>Task</b>	<b>Estimate</b>	<b>Duration (tendering + works)</b>
<b>Ventilation proposal #1</b>	<b>35 kCHF</b>	<b>10 weeks</b>
<b>Ventilation proposal #2</b>	<b>130 kCHF</b>	<b>14 weeks</b>
<b>Ventilation proposal #3</b>	<b>180 kCHF</b>	<b>17 weeks</b>
<b>Water cooling proposal #1</b>	<b>15 kCHF</b>	<b>-</b>
<b>Water cooling proposal #2</b>	<b>&gt;200kCHF</b>	<b>21 weeks</b>