



Working on a drill

Claudio Bortolin







Tools

- Drilling:
 - tungsten carbide tip welded on twisted ss cable
 - drill to operate the rotation
 - counter-flow at 200 mbar w/manometer to detect the presence of the hole



Cleaning:

- rilsan pipe connected to a rotary vane vacuum pump
- magnet tip on twisted ss cable
- cleaning machine to force counter-flow wise a cleaning fluid



Procedure



Drilling:

- the drill rotates the tool inside the pipe
- pressure drop (~20-30 mbar) on a manometer with specific trend when hole is done


Cleaning:

- 1. suction of drilling remains with small pipe inside the stainless steel pipe (down to the filter) and vacuum pump
- 2. ''walk'' with magnet inside the pipe
 - the steel of the filter is slightly magnetic
- 3. counter-flow with C_6F_{14} for 30' @ 1.5 bar
- 4. pipe drying with Ar flow @ 1.5 bar
- 5. repeat 1-4 4 more times (5 cycles total)
- 6. last counter-flow with fluid lasts 12 h











SEM analyses: before and after the cleaning



Particles collected before...




...and after cleaning!








SEM analyses: Most particles are carbon and iron

















Sector 9 drilling procedure and results



- > It never worked properly (max result: 6 HSs ON beginning of 2008)
 - vacuum cleaning + 3 magnet sweeps + vacuum cleaning + counterflow
 - last counterflow left running overnight
 - flow: from 0.27 to 0.46 g/s
- > Drilling: Wed 15 Feb morning
- > Cleaning: 5 cycles (overnight counter-flow between cycle 3 and 4)
- > Results:

Flow=2.0 g/s at 4,5 bar (was: 0,27 g/s at 6,3 bar)

Modules on= 100% (was: 0%)



GIAUUIU DUITUIIII - GEITIN



Next steps



Sector 7

- The filter was drilled last Monday morning.
- Cleaning is ongoing
- We expect to restart loop/sector this afternoon: waiting for SEM results
- Other sectors will be drilled according to the results of sector 7
- Drilling schedule to be decided soon (Technical stops time table)



SDD/SSD cooling maintenance

ALICE

- pump: replaced
- outlet filter: replaced
- demineralized cartridge: replaced
- mechanic filter on air control: replaced
- SSD chilled water valve: replaced (it was leaking)
- safety valve on the tank: replaced
- alarm security test: done
- upload new program PLC (ramp of p regulator SSD): **done**
- temperature sensors loop 17 & 18: replaced





SPD cooling maintenance



- pump replaced
- dehydrator cartridge replaced
- inlet mechanic 1um filter replaced
- chilled water valve replaced (leak on the top)
- one of compressor was replaced
- some safety valves were recalibrated and installed (10 bar pump valve and 8,5 bar in the inlet manifold, 3,5 bar tank valves): done
- 10 safety valves on the loops (return side) replaced
- test security alarm: **to be done**
- BPRs installation: **Postponed to 2013**



UX25 access restrictions



	Dec				Jan						Feb				Mar		
Wk	49	50	51	52	1	2	3	4	· 5	6	· 7	· 8	9 ·	10 [.]	11		
Мо	Ę	5	19	19 26		9	9 16	i 23	30	6		20	27	5	12		
Tu		After							•		After						
We		17:00							•		17:00						
Th									•				DSO				
Fr	After 17:00	Open L3					AUG			Close L3	48V (EL)	Lift	030				
Sa											After 17:00						
Su			Xmas Day	NY Day													

Access restrictions:

Removal/installation of shielding (restriction includes RB24 triplets)

- PX24 blocks: no access CR5 and UX25
- PX24 beams (35t): no access CR1-5, Expo, and UX-25
- All other blocks: no access to UX-25 (or 1-2 teams max, not on A-side) TRD insertion: no access to MNF and L3

AUG test (*Arrêt Urgence General* – General Emergency Stop) – no access UX25 DSO test (Department Safety Officer) – no access UX25

No access SX2 during manipulation of blocks in SX2 (except ACR and WRs)



No access (except transport)

Access possible

No access