



**High
Luminosity
LHC**

Current Limitations and Plans for CRYO System (arc and insertions)

3rd HL-LHC Parameter and Lay-out
Committee

Rob van Weelderen,

Cryogenic Group, Technology Department, CERN

based on 2nd HL-LHC -- LARP meeting in Frascati (Nov 2012) of Laurent Taviani

with the contribution of K. Brodzinski, G. Ferlin, U. Wagner




The HiLumi LHC Design Study (a sub-system of HL-LHC) is co-funded by the European Commission within the Framework Programme 7 Capacities Specific Programme, Grant Agreement 284404.



Content

- Overall HL-LHC layout
- Local and global cryo-limitation in Sectors
- Specific Inner Triplet cryo-limitations
- Cryogenic layout proposals at:
 - Point 1 and Point 5
 - Point 4
 - Point 7
- Specific studies and tests
- Schedule and conclusion

Overall HL-LHC layout



- HL-LHC cryo-upgrade:
 - 2 new cryoplants at P1 and P5 for high luminosity insertions
 - 1 new cryoplant at P4 for SRF cryomodules
 - New cooling circuits at P7 for SC links and deported current feed boxes
 - Cryogenic design support for cryo-collimators and 11 T dipoles at P3 and P7

Sector heat loads: local limitation

(valves, HX, piping,...)

- Synchrotron radiation
- Image current
- Beam gas scattering
- Resistive heating

$$\rightarrow Q_{sr} = Q_{sr_{nom}} \cdot \left(\frac{E}{E_{nom}}\right)^4 \cdot \frac{Nb}{Nb_{nom}} \cdot \frac{nb}{nb_{nom}}$$

$$\rightarrow Q_{ic} = Q_{ic_{nom}} \cdot \left(\frac{Nb}{Nb_{nom}}\right)^2 \cdot \frac{nb}{nb_{nom}} \cdot \left(\frac{0.7189 \cdot E + 1.967}{E_{nom}}\right)^{0.5}$$


$$\rightarrow Q_{bgs} = Q_{bgs_{nom}} \cdot \frac{Nb}{Nb_{nom}} \cdot \frac{nb}{nb_{nom}}$$

$$\rightarrow Q_{rh} = Q_{rh_{nom}} \cdot \left(\frac{E}{E_{nom}}\right)^2$$

	LHC nominal	LH-LHC	
		25ns	50ns
Nb	1.15E+11	2.2E+11	3.5E+11
nb	2808	2808	1404
bunch length [m]	7.50E-02	7.50E-02	7.50E-02

		Qs	Qsr	Qic	Qbgs	Qrh	Total	Locally installed	Local margin (e.g. for e-cloud)	
		[W]	[W]	[W]	[W]	[W]	[W]	[W]	[W]	[W/m per aperture]
Half-cell beam- screens @ 4.6-20 K	Nominal	7.5	18	19	0	0	44	255	211	2.0
	HL-LHC 25 ns	7.5	34	70	0	0	112	255	143	1.3
	HL-LHC 50 ns	7.5	27	89	0	0	123	255	132	1.2
Cell cold-masses @ 1.9 K	Nominal	18	0.11	0.12	5.1	11	34	90	56	0.26
	HL-LHC 25 ns	18	0.20	0.42	9.8	11	39	90	51	0.24
	HL-LHC 50 ns	18	0.16	0.53	7.8	11	37	90	53	0.25

Sector heat loads: global limitation



Load transfer from
1.9 K to 4.6-20 K
refrigeration

~1 W/m per aperture available
for e-cloud
→ ~20 % lower than local
limitation (OK !)

		Total*	Globally installed	Global margin w/o load transfer		Global margin with load transfer	
		[W]	[W]	[W]	[W/m per aper.]	[W]	[W/m per aper.]
Sector beam-screens @ 4.6-20 K	Nominal	2597	7600	5003	0.87	10630	1.8
	HL-LHC 25 ns	6296	7600	1304	0.23	6243	1.1
	HL-LHC 50 ns	6951	7600	649	0.11	5850	1.0
Sector cold-masses @ 1.9 K	Nominal	975	2100	1125	0.19	0	0
	HL-LHC 25 ns	1112	2100	988	0.17	0	0
	HL-LHC 50 ns	1060	2100	1040	0.18	0	0

*: 54 half-cells + 1 LL inner triplet + 1 SC link


Specific present IT cryo-limitations

Point (status 25.03.2010)	Present Cryogenic power available for secondaries (W)	After LS1 Cryogenic power available for secondaries (W)
L1	147	270
R1	270	270
L2	147	270
R2	270	270
L5	270	270
R5	147	270
L8	147	270
R8	270	270

Present Inner Triplets *have limitations* for extraction of secondaries due to:

- 1) Collapsed and repaired, with lower capacity, Hell two-phase heat exchanger (*will not be consolidated*)
- 2) Erroneous mounting of passive heating strips for excess liquid evaporation (*will be consolidated in LS1*)


Main components at Point 1 and 5



?: For Q5, Q6 and probable Q7+ ? 1.9 K or 4.5 K operation will influence the cryo QRL interface significantly (1.9 K needs 2 jumpers with present QRL design hardware)

P1 & P5 layout 1: Matching section cooled with sector cryoplants


Q5, Q6 and probable Q7+ ? 1.9 K or 4.5 operation



Note: Cryo for Sector- and LSS-powering are **combined** except for IT & D1

P1 & P5 layout 2: Matching section cooled with inner triplet cryoplants

Q5, Q6 and probable Q7+ ? 1.9 K or 4.5 K operation



Note: Cryo for Sector- and LSS-powering are as well **separated**
(links and DFBA / DFBX leads **re-arrangement**)

LSS specific magnet cryo-layout issues

- Stand-alone magnets **1.9 K** cooling QRL interface requires **more space than 4.5 K** cooling in with present QRL / jumpers / Service modules design (*either 2 service modules, twin-DFBX-like module, both with QRL extensions*)
- D2-Crab cavities-Q4 layout would need **3 jumpers** if Crab cavities cryostat are kept **independent** (cold / warm transition) from neighbouring magnets
- **IT cooling arrangement** under study with TE-MS-C-LMF, TE-MS-C-CMI (*# of jumpers, D1 and/or CP conduction cooled, link cooling, phase-separator placing, piping sizing, beam-screen*)


In the light of the above, **adapting the existing QRL** to the HL-LHC LSS needs might be possible but **looks increasingly difficult**

Comparison of layouts at P1 and P5

	Advantage	Drawback
Layout 1: MS with sector	Corresponds to the CtC baseline (minor modification on the existing QRL, i.e. only new jumper extensions foreseen)...	...but reuse of existing QRL if the new MS layout largely differ from the existing one (operating temperature and/or new equipment (D2, CC, Q4, Q5, Q6? Q7+?...)) → could be also expensive and space consuming... ...and maybe not feasible!
Layout 2: MS wit IT	Optimisation of the distribution and space with respect to the HL-LHC need. Allow the upgrade of "A" boxes during LS2 Complete sectorization of MS + IT allowing mechanical intervention without warm-up of the two adjacent sectors (but interconnection, if any, must be designed accordingly)	Increase of the CtC (~1 km of compound transfer line with ~20 service modules) → additional cost (8-10 MCHF tbc)

Layout 2 as future **baseline**? Decision needed

Interconnection for partial redundancy




Present redundancy baseline w/o interconnection (IB) in between cryoplants !

“Partial” redundancy:

- cold standby during technical and Xmas stops
- low beam-intensity operation in case of major breakdown on the new cryoplant (full nominal redundancy not possible)
- what about redundancy with detector cryogenics ?

↓
Cost increase

Interconnection box (IB)




Up to 10 cryogenic valves to be integrated in the tunnel (space ?)

→ Volume in between valves used as controlled volume for safe cryo-consignation

→ Valve DN's depend on the level of needed redundancy

Space requirement in caverns and shafts



Shaft requirement → In addition to the **3 SC links**:


- 1 compound cryoline (~DN500)
- 3 warm recovery lines (~DN100-150)

Cavern requirement:


- 1 cold compressor box

Minimum CCB requirement in cavern


Double CC train



Single CC train



Best for cavern integration




Depending of the total cooling capacity and operating temperature




Global or distributed ?
(500 W max size for distributed HX !)

Number of cold compressor trains





Minimum size of cold compressor box (CCB)




- + electrical cabinets in protected area for instrumentation, AMB controllers and variable-frequency drives ($\sim 0.6 \times \sim 2.7 \times \sim 2.2 \text{ m}^3$)
- Ground level installation of cabinets under study with 150 m of cabling (today: 25 m max)

P4 Layout: new cryogenics for SRF module




With interconnection for partial redundancy (Accepted as baseline)

P4 cryogenic process & flow diagram



P7 Layout: Deported current feed boxes

- New cooling circuits for SC links and deported current feed boxes
- Extension of the warm recovery lines to the TZ76
- Cryogenic design of new SC links and current feed boxes.




Specific cryogenic studies and tests (or what differ from LHC design ?)

- Cooling circuits for large heat deposition:
 - on 1.9 K cold masses up to 10 W/m
 - heat extraction from SC cables and quench energy margin
 - Generic heat flow in magnet cross section
 - on beam-screens up to 13-20 W/m (image current effect ?)
- Cooling of HTS SC links and current feed boxes
- Cooling and pressure relief of crab-cavities
- Validation tests on SC link, crab-cavities, magnets, beam screens...
- Reactivation of the Heat Load Working Group
- Quench containment and recovery (cold buffering ?)
- Large-length cable (150 m) for cold-compressor controls and drives
- Large capacity (750-1500 W) sub-cooling heat exchangers
- Larger turndown capacity factor on 1.8 K refrigeration cycle: up to 10?

From users to cryogenic infrastructure



Schedule



★ : Freeze of heat load requirement

Conclusion

- Several HL-LHC cryogenic layouts have been presented with alternatives for cooling sectorization and redundancy → *decision needed for main sectorization option*, additional study needed on detailed options
- Preliminary heat load estimate is defined :
 - local and global limitation for sector cryogenics are compatible with the proposed HL-LHC beam parameter.
 - the HLWG to refine and follow the heat load inventory have to be reactivated.
- Specific cryogenic studies and tests are defined → some of them have already started
- Integration study of new underground equipment must be done to validate:
 - layout and interface requirements of all LSS magnet systems as function of their operation temperature
 - the possible reuse of part of the existing distribution system (QRL)
 - the underground space availability for the cold compressor boxes at

P1 and P5



cern.ch