ICEC/ICMC 2014 Conference



Contribution ID: 138

Type: Poster presentation (105min)

Design of the Helium Purifier for IHEP-ADS Helium Purification System

Tuesday 8 July 2014 14:15 (1h 45m)

With the development of superconducting accelerators, a massive increase of helium is needed for the superconducting equipment of the Accelerator Driven Sub-critical System in the Institute of High Energy Physics (IHEP-ADS). Since the cryogenic system requires a high standard of helium purity, a helium purification system will be built to use helium efficiently and circularly. The purifier is designed to work at a temperature of 77K. Oil and moisture are removed by coalescing filters and a molecular sieve bed, while nitrogen and oxygen are condensed by a phase separator and then adsorbed in several activated carbon absorbers. The purifier will work in a flow of 5 g/s at 200 bar in continuous operation for 12 hours. After purification, the purified helium has an impurity content of less than 5ppm.

Authors: Dr ZHANG, Jianqin (IHEP,CAS); Prof. LI, Shaopeng (IHEP,CAS)
Co-authors: Dr GE, Rui (IHEP,CAS); Mr ZHANG, Zhuo (IHEP,CAS)
Presenter: Dr ZHANG, Jianqin (IHEP,CAS)
Session Classification: Tue-Af-Posters Session 1.1

Track Classification: C-01: Large scale refrigeration, liquefaction