



---

# Radiation protection of Linac4

M. Silari  
Radiation Protection Group



# Basic assumptions for the shielding design



- Classification of radiation areas (and workers)
- **Beam loss pattern**
- Routine operation and incidental conditions

Type of area	Max. annual effective dose	Max. ambient dose equivalent rate	RP requirements
Non-designated (non-permanent occupation)	1 mSv	0.5 $\mu\text{Sv h}^{-1}$	None
Supervised	6 mSv	3 $\mu\text{Sv h}^{-1}$	Personal dosimeter
Controlled	20 mSv	10 $\mu\text{Sv h}^{-1}$	Personal dosimeter + individual dosimeter with alarm function



- **Occupationally exposed :**
  - Class A  $> 6 \text{ mSv} / 12 \text{ months}$
  - Class B  $< 6 \text{ mSv} / 12 \text{ months}$
  
- **Short term visitors:**  $< 1 \text{ mSv} / 12 \text{ months}$   
(not classified as occupationally exposed)
  
- **Non occupationally exposed:**  
 $< 1 \text{ mSv} / 12 \text{ months}$



### Action level

Any exposure exceeding **6 mSv** during any consecutive **12-month period** must be justified in a joint review by the department concerned and the RP group and authorized by the department head.

The Swiss authorities must be notified if an individual exceeds **2 mSv** over one month.

### Design constraint (*effective dose*)

Use of a design constraint in the design of new facilities, to ensure that the annual dose received by an individual at the time of the operation of the facility will not exceed a pre-defined value.

### CERN reference levels

- 1) the annual individual doses should stay below 6 mSv
- 2) the effective dose due to internal exposure shall stay below 1  $\mu$ Sv per hour of stay

## Basic assumptions on machine parameters

---



- Beam energy: 160 MeV
- As injector into the PSB:
  - 2 Hz, 32  $\mu\text{A}$  average beam current,  $2 \times 10^{14}$  protons per second, 5.1 kW at 160 MeV, 0.08% of the SPL duty cycle
- “Routine” beam losses:
  - 10 W point losses every 10 m (past the shield equivalent to constant beam loss of 1 W/m)
- Accidental beam loss:
  - full loss of the entire beam in a given location for a limited amount of time
  - beam interlock required
- Radiation protection dimensioned for the operation of Linac4 as SPL Front-End



- Analytical model
  - point-source, line-of-sight for shielding
  - universal transmission curves for ducts and mazes
- Monte Carlo simulations (FLUKA)
  - to validate analytical calculations and to estimate induced radioactivity
- Layout
  - linac tunnel underground
  - klystron gallery on the surface on top of it, supervised area but  $1 \mu\text{Sv/h}$  taken as design value as building wall are thin and the area around is non-designated

# Radiation protection calculations

---




- Direct stray radiation from the linac into the klystron building. Depth of linac tunnel finally dictated by the SPL downstream
- Neutron streaming through the standard waveguide ducts – Various configurations investigated
- Low-energy (3 MeV section) waveguides
- Access maze, lift shaft, ventilation and cable ducts, rooms on the upper floor at the low-energy end of the linac tunnel
- Ventilation and cable ducts at the high-energy end of the linac tunnel
- Additional shielding required in the existing Linac2 building around the Linac4 – PSB transfer line

# Low-energy section




All MC simulations performed by Egidio Mauro



FLUKA geometry plot. Cross-sectional view of the low energy section of the Linac4. The view is looking downstream of the tunnel, towards the high-energy end of the accelerator.




# Low-energy section: access maze




Beam loss in a  $5 \times 5 \times 5 \text{ cm}^3$  copper target, 10 W, 11 MeV. Cross sectional view of the Linac4 tunnel and of the access area with the addition of the maze.  $H^*(10)$  in  $\mu\text{Sv/h}$ .

# Low-energy section: "safe room"




Beam loss in a  $5 \times 5 \times 5 \text{ cm}^3$  copper target, 10 W, 11 MeV. Top-cross sectional view of the safe room at the height of 3.5 m with respect to the tunnel floor.  $H^*(10)$  in  $\mu\text{Sv/h}$ .

# Low-energy section: gallery on first floor



Beam loss in a  $5 \times 5 \times 5 \text{ cm}^3$  copper target, 10 W, 11 MeV. Top cross sectional view of the gallery on the first floor in the linac4 tunnel at an height of 7.6 m.  $H^*(10)$  in  $\mu\text{Sv/h}$ .

# Waveguide duct



Beam loss in a  $5 \times 5 \times 5 \text{ cm}^3$  copper target, 10 W, 160 MeV. Cross sectional view of the Linac4 tunnel, the 3-leg duct and the klystron building. Left: dose equivalent rate in the first duct. Right: dose equivalent rate in the second duct.  $H^*(10)$  in  $\mu\text{Sv/h}$ .



- Civil-engineering related RP studies essentially completed
- Upcoming studies:
  - dump at the end of the linac
  - induced radioactivity in materials, water, air