

CRYOGENICS OPERATIONS 2008


# CRYOGENICS OPERATIONS 2008

Organized by CERN

**Collection of data related to the  
operation experience on the Tore Supra  
cryogenic system**

**Related to the European Fusion Development Agreement  
Task TW6-TSL-004**

**Reynaud Pascal  
Commissariat à l'Énergie Atomique-IRFM**




CRYOGENICS OPERATIONS 2008

# OUTLINE

## **“News from Tore Supra”**


- **Introduction**
- **Description of the EFDA task**
- **Recalls of the cryogenic system**
- **Data management**
- **Overall availability**
- **Remarks and conclusions**



CRYOGENICS OPERATIONS 2008


## Description of the EFDA task

- **Work related to an EFDA task,**
- **Objective: enrich a fusion specific data collection**
- **Refers to systems relevant to ITER project**
- **Deliverable 1: Water cooling system**
- **Deliverable 2: Toroidal field magnet safety system**
- **Deliverable 3: Cryogenic system**
- **Duration : 1 year**
- **Information required per component of the system**
  - Number of failures
  - Mean time between failures
  - Resulting downtime
  - Availability of the component
  - Associated maintenance




CRYOGENICS OPERATIC

# Recalls of the cryogenic system




## TF coil cooling system




# Recalls of the cryogenic system


	1.8 K			4.5K				80 K
<b>Transient load</b>	Heat load (kJ)	$\Delta T$ (K)	Recovery time	Heat load (kJ)	$\Delta T$ - casing (K)	$\Delta T$ - bath (K)	Recovery time	Heat load
PF cycle	30	0.0 2	4 min	120	0.7	0.1	4 min	-
Disruptions	50	0.0 4	12 min	1200	3.9	0.4	25 min	-
Fast Safety Discharge	235	0.1 2	35 min	400	1.8	0.15	8 min	-
Cleaning Discharge	0.2 / cycle		2 s	1.5 / cycle	0.3	0.25	2 s	-
<b>Static load</b> (vessel at 120°C)	120 to 160 W			300 W				12kW
<b>Static load</b> (baking at 200°C)	-			-				20 kW
<b>Refrigerator power</b>	300 W			800 W + 3 g/s (C.L)				16 kW + LN <sub>2</sub> (total = 30kW)



CRYOGENICS OPERATIONS 2008


# Recalls of the cryogenic system





# Recalls of the cryogenic system


<b>Main Cold components</b>			
<b>Turbine T1</b> AL C5-500	<b>In/out Temperature</b> 110/80K	<b>Power</b> 16kW	<b>Flow rate</b> 110g/s
<b>Turbine T2</b> AL C3-500	<b>In/out Temperature</b> 50/30K	<b>Power</b> 2.8kW	<b>Flow rate</b> 24g/s
<b>Turbine T3</b> AL C4-500	<b>In/out Temperature</b> 19/10K	<b>Power</b> 2.2kW	<b>Flow rate</b> 50g/s
<b>Wet reciprocating engine</b> AL/KPS model 1400	<b>In/out Temperature</b> 6/4.5K	<b>In/out Pressure</b> 18/1.2bar	<b>Flow rate</b> 10g/s
<b>Cold compressor PF1</b> AL/S2M	<b>Suction conditions</b> 10mb/4.5K	<b>Compression ratio</b> 3	<b>Flow rate</b> 14g/s
<b>Cold compressor PF2</b> AL/S2M	<b>Suction conditions</b> 34mb/10K	<b>Compression ratio</b> 2.3	<b>Flow rate</b> 14g/s
<b>Liquid storages</b>	20000l of LHe + 2 x 50000l of LN2		



# Recalls of the cryogenic system

<b>Main Warm components</b>			
<b>Compressor C1 STAL S7</b>	<b>In/out Pressure 1/4.5bar</b>	<b>Flow rate 101g/s</b>	<b>Electrical power of motor 200kW</b>
<b>Compressor C2 STAL S73</b>	<b>In/out Pressure 1/4.5bar</b>	<b>Flow rate 101g/s</b>	<b>Electrical power of motor 200kW</b>
<b>Compressor C3 STAL S51</b>	<b>In/out Pressure 4.5/18bar</b>	<b>Flow rate 144g/s</b>	<b>Electrical power of motor 250kW</b>
<b>Compressor C4 STAL S57</b>	<b>In/out Pressure 4.5/18bar</b>	<b>Flow rate 218g/s</b>	<b>Electrical power of motor 400kW</b>
<b>Oil ring pump P1 Alstom Hydro PL 160</b>	<b>In/out Pressure 70/600mbar</b>	<b>Flow rate 14 g/s</b>	<b>Electrical power of motor 315kW</b>
<b>Oil ring pump P2 Alstom Hydro PL 50</b>	<b>In/out Pressure 0.6/1bar</b>	<b>Flow rate 60g/s</b>	<b>Electrical power of motor 132kW</b>
<b>Recovery compressor C7 Sulzer type C5U</b>	<b>Pressure max 200 bar</b>	<b>Flow rate 10g/s</b>	<b>Electrical power of motor 90kW</b>
<b>Recovery compressor C8 Sulzer type C5U</b>	<b>Pressure max 200bar</b>	<b>Flow rate 10g/s</b>	<b>Electrical power of motor 75kW</b>
<b>Gas bags</b>	<b>160m<sup>3</sup> + 360m<sup>3</sup></b>		
<b>HP storage</b>	<b>Pressure max 200bars</b>	<b>Whole capacity : 1500kg</b>	





# Data management

## **PHASE 1 : Extraction of data automatically recorded**


**From** ○ **Command-control system PANORAMA**

- **To find the stable operational modes and the transitory modes during which the component was required in service and to enter time corresponding**
- **To enter the time during which the component required in service was unavailable**

## **PHASE 2 : Comparison with various sources of information**

**From** ○ **PAVANE Incident database**  
○ **Computerized logbooks**  
○ **Operator interviews**

- **To check and discriminate the real origin of the unavailability of the component, because some were rather induced by operating conditions**



# Data management

## **PHASE 3 : Treatment of data**

**With** ○ Excel conversion, VB macros

- **To identify the real availability times of the component compared to the real-time of operation requested**

## **PHASE 4 : Addition of the maintenance actions and costs**


**From** ○ Computerized logbooks

- **To finalize the report**

◇ **Task closed in August 2008**

◇ **Easiest years for data extraction and retrieval : 2004-2007**


**This huge work highlights the availability of the cryogenic system**



# Overall availability

## Time spent in the different operating modes from 2004 to 2007


Operating mode	2004		2005		2006		2007	
	hours	totals	hours	totals	hours	totals	hours	totals
Warm stop confirmed	1732 h	20 %	1311 h	15 %	543 h	6 %	1342 h	15%
Idle at 80 K confirmed	476 h	5 %	853 h	10 %	338 h	4 %	421 h	5 %
Liquefaction at 300K confirmed	222 h	3 %	577 h	7 %	192 h	2 %	192 h	2%
Liquefaction at 80 K confirmed	501 h	6 %	558 h	6 %	89 h	1 %	399 h	5 %
Liquefaction at 4 K confirmed	1841 h	21 %	1893 h	22 %	3645 h	43%	1512 h	17 %
Liquefaction at 2 K confirmed	177 h	2 %	0 h	0 %	0 h	0 %	0 h	0 %
Nominal operation confirmed	1770 h	20%	2036 h	23 %	2495 h	28 %	2445 h	28 %
Total time spent in transitions	2013 h	23 %	1518 h	17 %	1394 h	16 %	2440 h	28 %
TOTAL	8784 h	100 %	8760 h	100 %	8760 h	100 %	8760 h	100 %




CRYOGENICS OPERATIONS 2008

# Overall availability

## Relative importance of the different operating modes from 2004 to 2007







CRYOGENICS OPERATIONS 2008

# Overall availability (2004)

## Toroidal magnet temperature throughout 2004






CRYOGENICS OPERATIONS 2008

# Overall availability (2004)


	Dates	What happened?	Number of days lost
<b>Event 1</b>	2 <sup>nd</sup> half of January	Cooldown test at 2 K, toroidal magnet test at 1.8 K, then baking of the vacuum vessel at 200°C while the cryo stayed at 4.5 K until campaign start	NOT A FAILURE
<b>Event 2</b>	17/02/2004	Turbine replacement	1 day lost
<b>Event 3</b>	02/03/2004-10/03/2004	P1 pump electrical failure (motor and circuit breaker)	6.5 days lost
<b>Event 4</b>	30/03/2004-05/04/2004	WRE failure (bearings damaged)	4 days lost
	06/04/2004-08/04/2004	Cold pumps failure (clogging of a valve of the He/He heat exchanger circuits)	3 days lost
<b>Event 5</b>	3 <sup>rd</sup> week of July	1 <sup>st</sup> liquefaction at 80 K, then cooldown test to 4.5 K after summer warm stop	NOT A FAILURE
<b>Event 6</b>	1 <sup>st</sup> week of August	Cadarache 1-week closure for summer holidays	NOT A FAILURE
<b>Event 7</b>	07/09/2004-17/09/2004	C3 compressor failure (bearings damaged)	8.5 days lost
<b>Event 8</b>	2 <sup>nd</sup> half of October	Test of the auxiliary cold box and water leak (not on the cryogenic system)	NOT A FAILURE




CRYOGENICS OPERATIONS 2008

# Overall availability (2005)

## Toroidal magnet temperature throughout 2005






# Overall availability (2005)

## Notable events in 2005

	Dates (dd/mm/yyyy)	What happened?	Number of days lost
<b>Event 1</b>	05/04/2005-13/04/2005	1 <sup>st</sup> liquefaction at 80 K	NOT A FAILURE
<b>Event 2</b>	30/04/2005	Electrical failure	No day lost
	1 <sup>st</sup> week of May	Cooldown and toroidal field test at 1.8 K	NOT A FAILURE
<b>Event 3</b>	01/07/2005-19/07/2005	Test of the auxiliary cold box and removal of ICRF antennas while at 4.5 K (later reinstalled in the "unplanned" maintenance period in Sept-Oct)	NOT A FAILURE
<b>Event 4</b>	23/10/2005	Power supply failure due to storms	Not related to the cryogenic system
<b>Event 5</b>	15/11/2005-18/11/2005	Water in oil circuits and in 1 <sup>st</sup> He/He heat exchanger	5 days lost to HUMAN ERROR
<b>Event 6</b>	01/12/2005-06/12/2005	Water in 1 <sup>st</sup> He/He heat exchanger	3 days lost to HUMAN ERROR







CRYOGENICS OPERATIONS 2008

# Overall availability (2006)

## Toroidal magnet temperature throughout 2006






# Overall availability (2006)

## Notable events in 2006


	Dates (dd/mm/yyyy)	What happened?	Number of days lost
<b>Event 1</b>	3 <sup>rd</sup> week of February	1 <sup>st</sup> liquefaction at 80 K	NOT A FAILURE
<b>Event 2</b>	2 <sup>nd</sup> half of March	Cooldown and toroidal field tests at 1.8 K then 1 week at 4.5 K for baking of the vacuum vessel	NOT A FAILURE
<b>Event 3</b>	24/04/2006	Cold pumps stop (compressed air supply failure)	Not related to the cryogenic system
<b>Event 4</b>	2 <sup>nd</sup> week of August	Shutdown due to storms and Cadarache 1-week closure for summer holidays	Not related to the cryogenic system
<b>Event 5</b>	Last week of August	Test of the auxiliary cold box, then general power supply failure on Cadarache	Not related to the cryogenic system
<b>Event 6</b>	2 <sup>nd</sup> & 3 <sup>rd</sup> week of Sept.	Water leak on water cooling system	Not related to the cryogenic system
<b>Event 7</b>	Last week of October	Legal holidays	NOT A FAILURE




CRYOGENICS OPERATIONS 2008

# Overall availability (2007)

## Toroidal magnet temperature throughout 2007






CRYOGENICS OPERATIONS 2008

# Overall availability (2007)

## Notable events in 2007


	Dates (dd/mm/yyyy)	What happened?	Number of days lost
<b>Event 1</b>	2 <sup>nd</sup> half of February	1 <sup>st</sup> liquefaction at 80 K (1 <sup>st</sup> campaign)	NOT A FAILURE
<b>Event 2</b>	20/04/2007	Replacement of compressor C2 motor	1 day
	02/05/2007	Replacement of P2 coupling	1 day
<b>Event 3</b>	1 <sup>st</sup> week of September	1 <sup>st</sup> liquefaction at 80 K (2 <sup>nd</sup> campaign)	NOT A FAILURE
<b>Event 4</b>	Mid-September	Tests of C3 compressor on backup power supply	NOT A FAILURE
<b>Event 5</b>	End of September / beginning of October	Cooldown and toroidal test at 1.8 K then baking of the vacuum vessel at 4.5 K	NOT A FAILURE



# Overall availability

## Availability relatively to the plasma experimental campaign


	2004		2005		2006		2007	
<i>Operating mode</i>	<i>hours</i>	<i>total</i>	<i>hours</i>	<i>total</i>	<i>hours</i>	<i>total</i>	<i>hours</i>	<i>total</i>
<b>Nominal operation confirmed</b>	1770 h	20%	2036 h	23 %	2495 h	28 %	2445 h	28 %
Availability of the cryogenic system**	76.2 % (relatively to experimental campaigns)		92.9 % (relatively to experimental campaign)		100 % (relatively to experimental campaign)		97.3 % (relatively to experimental campaigns)	
Availability of the whole Tore Supra installation	53 %		54 %		76 %		80 %	




CRYOGENICS OPERATIONS 2008

# Conclusion

*Number of failures per year – CRYO-PLANT  
PAVANE Source only*



**2001: new command-control system**




CRYOGENICS OPERATIONS 2008

# Conclusion

More than 20 years after its commissioning, and without any large updating, the cryogenic system of Tore Supra is operated in quasi-industrial conditions with a satisfying level of performance and availability.

Keeping a human presence on the site, performing daily inspections of the critical components and a reliable and ergonomic control-command system make possible an increase of availability during the 4 last years.




CRYOGENICS OPERATIONS 2008

# Extra slide









CRYOGENICS OPERATIONS 2008

# Extra slide

Nominal operation







CRYOGENICS OPERATIONS 2008

# Extra slide


Liquefaction at 4K






# Extra slide

Liquefaction at 80 K







CRYOGENICS OPERATIONS 2008

# Extra slide


Liquefaction only






# Extra slide


Stand-by at 80 K






# Extra slide

### Temperature of the TF magnet



Heavy maintenances  
 ~ 3 months per year  
 Regulatory controls for  
 Cryogenic system , CWS  
 Power Supplies  
 Tore Supra Configuration

Plasma Operation rhythm ~ 40 hours a week  
 4 days a week : TF magnet at 1.8K  
 3 days at 4.2K w.e. and maintenance day (Monday)




CRYOGENICS OPERATIONS 2008

## Extra slide


- **PAVANE database: from 1996 up to now**
  - » Data related to tests and plasma discharges
  - » Data related to failures
  - » A few continuous data but mainly reports from different systems operators





- **PEGASE database: from mid-2003 up to now**


- » Operating parameters automatically collected from systems Command-Control
- » Continuously collected data, stocked with a 3s interval, but only retrieved from the database 5000 points at a time, for any given length of time:
  - 5000 points/year > ca. 1h45 interval
  - 5000 points/month > ca. 9min interval



CRYOGENICS OPERATIONS 2008

## Extra slide

- **Log books from the start of Tore Supra (1989) up to now**
  - » Data related to tests and plasma discharges
  - » Data related to failures
- **Incidents reports**
- **Maintenance reports**
- **Operators interviews**



CRYOGENICS OPERATIONS 2008

# Extra slide

C1 Operating Time (2005)

