

Concentric vacuum insulated transfer lines: feedback from Atlas and CMS newly installed systems

Monday 30 June 2014 14:15 (30 minutes)

In order to transfer CO₂ coolant from the cooling systems to the detector, coaxial vacuum insulated transfer lines have been chosen by both ATLAS IBL and CMS Pixel Phase I Upgrade. This work summarizes the recent installation experience in both experiments, the issues encountered and gives some preliminary results on the performances.

Author: TROPEA, Paola (CERN)

Co-authors: VERLAAT, Bart (NIKHEF (NL)); BORTOLIN, Claudio (University of Innsbruck (AT)); POSTEMA, Hans (CERN); GODLEWSKI, Jan (CERN); DAGUIN, Jerome (CERN); ZWALINSKI, Lukasz (CERN); GUTTMOSTOWY, Marek Leslaw (CERN); BACCHETTA, Nicola (Universita e INFN (IT)); PETAGNA, Paolo (CERN); EISEL, Thomas (CERN); BLASZCZYK, Tomasz Piotr (AGH University of Science and Technology (PL))

Presenter: TROPEA, Paola (CERN)