



COOLING AND VENTILATION IN THE TUNNEL



J. Inigo-Golfin - C. Martel
CERN TS/CV

Wednesday 15th October 2008




*This is a preliminary study.
Some concepts are presented based
on estimated values to be confirmed.
The confirmation of rate air/water is still standing.*

Ventilation

- Ventilation functions
- Heat load levels
- HVAC principle
- Tunnel section
- Safety
- Equipment
- Perspectives


Cooling

- Water cooling requirements
- Fluid circuits
- Cooling principle
- Main cooling station
- Tunnel section. Piping
- Equipment
- Perspectives




Tunnel ventilation functions

- Fresh air for people and ventilation (obligation).
- Requested ambient conditions ($T^{\circ}\text{C}$ and humidity).
- Remove heat loads in the air.
- Prevent from any air stratification, condensation.
- Purge before access.
- Smoke or gas extraction (obligation).
- Overpressure control linked to radiation (obligation).




Heat loads in the air

Drive Beam sector = 250 kW
UTRA cavern = 200 kW
Loop = 90 kW





Heat loads in the tunnel:
250 kW / DB sector
1250 kW between two shafts

Heat loads in the Loops & UTRA:
290 kW / DB sector
1450 kW between two shafts




HVAC of underground areas





Tunnel Air flow rate considerations


Tunnel section = 20 m²
 DB sector volume = 17 000 m³
 Inter shaft volume = 90 000 m³




Basic data: Delta Temperature (Extraction - Supply) = 28 - 18 = 10°C


		<u>Heat loads in the tunnel</u>	<u>Air flow rate</u>	<u>Air duct section</u>	<u>Air duct Diameter</u>
Input data	DB sector	250 kW	75 000 m ³ /h	1.73 m ²	1.48 m
	Intershafts	1250 kW	370 000 m ³ /h	8.56 m ²	3.3 m
Proposal	Intershafts	500 kW	150 000 m ³ /h	3.3 m ²	2 m

To be
Optimised ...




Tunnel Air handling from the surface






Semi transversal ventilation in tunnel




SHAFT
POINT

Optimisation of the air flow rate.
Low air speed in the tunnel < 0.1 m/s.
Optimisation of the temperature gradient.
Recycling of the tunnel air possible.
Reversible operation possible.
Energy recovery possible.

NEXT
SHAFT
POINT



Semi transversal ventilation in tunnel



SHAFT POINT




1 Smoke extraction trap per sector

Minimum maintenance
Sealed, modulated
Fire resistant
Compressed air control




1 supply and 1 extraction grilles per 30 m

NEXT SHAFT POINT




Safety considerations




SHAFT
POINT


- Control of the pressure from both ends of a sector.
- Control of the pressure (overpressure or underpressure in each area).
- Fire detection per sector compatible to fire fighting via water mist.



Tunnel section





This cross section is for study purposes only
Approved CLIC tunnel Diameter is currently 4.5m





Equipment issues


Not standard industrial fans



High pressure fans
Adapted products
Not standard equipment





CLIC WORKSHOP - Ventilation




Equipment issues

Special design


- Fan in specific concrete section
- Concrete air ducts
- Direct driven fans (no belts)
- Fan in specific concrete section
- Concrete sound attenuation






Perspectives

- Heat loads in tunnel air to optimize
- Heat loads in Exp. caverns, Klystrons to be defined?
- Radiation levels in the various areas to be defined
- Integration of ventilation ducts in the tunnel section to finalize




Cooling

- Water cooling requirements
- Fluid circuits
- Cooling production
- Main cooling station
- Tunnel section. Piping
- Equipment considerations
- Perspectives




Water cooling requirements

Modules cooling (circuit A)




Modules total power: 70 MW
Required flow-rate: 3215 m³/h
Delta temperature: 20 K
Temp. Supply: 25 °C




Water cooling requirements

General cooling (circuit B)




Modules total power: 15 MW
Required flow-rate: 1612 m³/h
Delta temperature: 8 K
Temp. Supply: 27 C





Fluid circuits per side

- **CIRCUIT A** : MODULES COOLING – 70 MW
Demineralised water, 25/45°C, 2 pipes Ø600
Accelerator structure, Loads, PETS, Quadripoles
- **CIRCUIT B** : GENERAL COOLING – 15 MW
Demineralised water, 27/35°C, 2 pipes Ø300
UTRA, UTRC, Loop, Vacuum, Beam Dump
- **CIRCUIT C** : FIRE FIGHTING - Water mist – Ø80
- **CIRCUIT D** : REGULATION
Compressed Air – 760 m³/h, Ø150, 8 bars
 - For solids (dust): class 1 with max. 0.1 mg/m³
 - For water : class 2 with -40°C dew point
 - For oil : class 1 with max. 0.01 mg/m³


CLIC WORKSHOP - Cooling



Raising circuits




Tunnel section



Raising pumps





CLIC WORKSHOP - Cooling




Cooling Production

Longitudinal section 1:25'000 / 2'500


Water Transfer Tunnel




CLIC WORKSHOP - Cooling




Main Cooling station




WATER MIST
CIRCUIT A
CIRCUIT B






Tunnel section. Piping




This cross section is for study purposes only
Approved CLIC tunnel Diameter is currently 4.5m




Equipment considerations

- Out of standard pipe diameters
- Special tooling, welding process
- On request manufacturing, PN an issue?
- Extra large heat exchangers

6 MW
Heat
Exchanger






Missing items affecting main cooling station


- Cooling power for experimental cavern ?
- Cooling power for Main dumps
- HVAC and cooling for klystrons
- Confirmation about the rate air/water

Other items to be considered:

- Fire-fighting flow-rates
- Infiltration water, raising pumps, slopes



Longitudinal principle



Large air flow rate
High speed
Temperature gradient

Base:
150 000 m³/h
1250 kW
Delta T°C = 24 = (41-17)
Air speed = 2 m/s