


YEARS / ANS **CERN**



YEARS / ANS CERN



# Radiation protection study for the HIE- ISOLDE project


S. Giron\*, A.-P. Bernardes, A. Dorsival, D. Voulot  
and J. Vollaire\*\*

\* Marie-Curie Fellow now at EDF (France)

\*\* Presenting




CATHI Final Review Meeting 22-26 September - Barcelona




# Outline

- Radiation Protection challenges of HIE-ISOLDE
- Shielding design for the post-accelerator
  - X-ray measurements
  - FLUKA calculations for the post-accelerator
- Ion interactions after post-acceleration
  - Operational parameters for HIE-ISOLDE
  - Activation calculations
- Radiation Monitoring System upgrade
- Conclusions



# RP challenges of HIE-ISOLDE

- Field emission in RF cavities lead to X-rays
  - Accelerating structures within a shielded enclosure
  - BUT many feed-trough for services
  - Keep the current radiological classification of the hall
- Beam accelerated above the Coulomb barrier
  - Possibility to have nuclear reactions
  - Strong wish to keep the current working practices (access to experimental setup during operation)
- RIB implantation (risk increases with intensity)
  - Hot-spot for gamma emitters
  - Contamination risks when opening the vacuum chamber or working on vacuum related equipment




# Outline

- Radiation Protection challenges of HIE-ISOLDE
- Shielding design for the post-accelerator
  - X-ray measurements
  - FLUKA calculations for the post-accelerator
- Ion interactions after post-acceleration
  - Operational parameters for HIE-ISOLDE
  - Activation calculations
- Radiation Monitoring System upgrade
- Conclusions




# X-ray measurements


## Measurements in SM18



## Measurements in Orsay




Time dependent measurements  
+ passive dosimeters




# X-ray measurement results

- Measurements in different phases (conditioning, Q...)
- Implementation of the SM18 setup in FLUKA
  - Emission of electrons at the beam axis level
  - Electron emission rate derived from the measured dose rate


### Measurements in Orsay




### Measurements in SM18



### FLUKA simulation







# FLUKA calculations


- Detailed model of the accelerator implemented in FLUKA
- Source term based on X-ray measurements (900 keV e<sup>-</sup>)
- Considering the most penalizing case (conditioning of all cavities at the same time)

## 3D model






## FLUKA geometry






# Some results



- $10^5$  dose reduction factor
- Exclusion area on the roof (RF on)
- Simulations for Phase 1 and 2
- Conservative scenario...






# Outline

- Radiation Protection challenges of HIE-ISOLDE
- Shielding design for the post-accelerator
  - X-ray measurements
  - FLUKA calculations for the post-accelerator
- **Ion interactions after post-acceleration**
  - Operational parameters for HIE-ISOLDE
  - Activation calculations
- Radiation Monitoring System upgrade
- Conclusions






# Operational parameters

- RIBs delivered at very low intensity ( $\sim$ ppA)
- Stable beam (C, N, O, Ne or Ar) for setup from REXEBIS rest gas or gas injection
  - 20 e-pA (beam tuning on a weekly basis)
  - Exceptionally (typically once a year) up to 500 e-pA for commissioning and for machine development
- Gas injection is done by experts only and can be destructive (in case of gas leaked in EBIS)

$$1 \text{ p-e pA} = 6.25 \times 10^6 \text{ particle-charge /s}$$



# Prompt dose rate

- Analytical approach for different combinations of beam/target
- Neutron dose rate @ 1 m and 90 degree
- Verified with FLUKA

(approach described in ISAC-II safety file)






Figure 7-3: The neutron dose rate at 1 m and at 90° from the interaction point of ions bombarding a medium mass target (Fe, Ni or Cu). The discrete points are measured values and the solid line is a fit using the semi-empirical recipe of Walden<sup>10</sup>.

Area Classification	Ambient Dose Rate (permanent workplaces)	Ambient Dose Rate (Low occupancy)
Supervised Radiation Area	<3 μSv/h	<15 μSv/h
Simple Controlled Radiation Area	<10 μSv/h	<50 μSv/h





# Ion interactions (FLUKA)


Example full beam loss of 1 ppA



Example full beam loss of 1 ppA




Generic geometries (dipole, flange or FC)



Very good agreement with the analytical approach used in the ISAC-II safety file






# Classification / mitigations


- Optimization (posting) for beam tuning with 20 epA
- Special measure for emittance measurements (beam permit, exclusion areas ....)
- Experimental setups remain accessible during operation and standard tuning periods

	A	Z	q	A/q	MeV/u			20.0 epA Sv/h at 1 m			500.0 epA Sv/h at 1 m		
					Stage1	Stage2	Stage3	Stage1	Stage2	Stage3	Stage1	Stage2	Stage3
He	4	2	1	4	6.47	10.20	11.45	3.8E-07	3.3E-06	5.0E-06	9.6E-06	8.2E-05	1.2E-04
	4	2	2	2	10.19	16.90	20.05	1.6E-06	6.6E-06	9.0E-06	4.1E-05	1.6E-04	2.2E-04
C	12	6	3	4	6.47	10.20	11.45	1.3E-07	1.1E-06	1.7E-06	3.2E-06	2.7E-05	4.1E-05
	12	6	4	3	7.73	12.54	14.54	2.3E-07	1.6E-06	2.4E-06	5.8E-06	4.1E-05	6.0E-05
	12	6	5	2.4	8.97	14.77	17.38	3.8E-07	2.0E-06	2.8E-06	9.5E-06	5.0E-05	6.9E-05
	12	6	6	2	10.19	16.90	20.05	5.4E-07	2.2E-06	3.0E-06	1.4E-05	5.5E-05	7.5E-05
N	14	7	4	3.5	7.01	11.22	12.81	1.4E-07	1.2E-06	1.7E-06	3.5E-06	2.9E-05	4.3E-05
	14	7	5	2.8	8.09	13.19	15.37	2.3E-07	1.5E-06	2.2E-06	5.8E-06	3.8E-05	5.4E-05
	14	7	6	2.333333333	9.15	15.08	17.77	3.5E-07	1.7E-06	2.4E-06	8.6E-06	4.3E-05	6.0E-05
	14	7	7	2	10.19	16.90	20.05	4.7E-07	1.9E-06	2.6E-06	1.2E-05	4.7E-05	6.4E-05
O	16	8	4	4	6.47	10.20	11.45	9.6E-08	8.2E-07	1.2E-06	2.4E-06	2.1E-05	3.1E-05
	16	8	5	3.2	7.42	11.97	13.79	1.5E-07	1.1E-06	1.7E-06	3.8E-06	2.9E-05	4.2E-05
	16	8	6	2.666666667	8.36	13.67	15.98	2.3E-07	1.4E-06	2.0E-06	5.7E-06	3.4E-05	4.9E-05
	16	8	7	2.285714286	9.28	15.31	18.07	3.2E-07	1.5E-06	2.1E-06	7.9E-06	3.8E-05	5.3E-05
	16	8	8	2	10.19	16.90	20.05	4.1E-07	1.6E-06	2.2E-06	1.0E-05	4.1E-05	5.6E-05
Ne	20	10	5	4	6.47	10.20	11.45	7.7E-08	6.6E-07	9.9E-07	1.9E-06	1.6E-05	2.5E-05
	20	10	6	3.333333333	7.23	11.62	13.33	1.1E-07	8.7E-07	1.3E-06	2.8E-06	2.2E-05	3.2E-05
	20	10	7	2.857142857	7.98	13.00	15.12	1.5E-07	1.0E-06	1.5E-06	3.9E-06	2.6E-05	3.7E-05
	20	10	8	2.5	8.73	14.33	16.83	2.1E-07	1.2E-06	1.6E-06	5.2E-06	2.9E-05	4.1E-05
	20	10	9	2.222222222	9.46	15.64	18.47	2.7E-07	1.2E-06	1.7E-06	6.7E-06	3.1E-05	4.3E-05
	20	10	10	2	10.19	16.90	20.05	3.3E-07	1.3E-06	1.8E-06	8.2E-06	3.3E-05	4.5E-05
	22	10	5	4.4	6.12	9.54	10.55	5.9E-08	5.0E-07	7.5E-07	1.5E-06	1.2E-05	1.9E-05
	22	10	6	3.666666667	6.81	10.85	12.32	8.2E-08	6.9E-07	1.0E-06	2.1E-06	1.7E-05	2.6E-05
	22	10	7	3.142857143	5.07	7.50	13.99	1.9E-08	1.1E-07	1.2E-06	4.7E-07	2.8E-06	3.1E-05
	22	10	8	2.75	8.19	13.37	15.59	1.5E-07	9.7E-07	1.4E-06	3.8E-06	2.4E-05	3.5E-05
	22	10	9	2.444444444	8.86	14.57	17.13	2.0E-07	1.1E-06	1.5E-06	5.0E-06	2.7E-05	3.8E-05
22	10	10	2.2	9.53	15.75	18.62	2.5E-07	1.1E-06	1.6E-06	6.2E-06	2.9E-05	3.9E-05	
Ar	40	18	9	4.444444444	6.08	9.47	10.46	3.2E-08	2.7E-07	4.0E-07	8.0E-07	6.7E-06	1.0E-05
	40	18	10	4	6.47	10.20	11.45	3.8E-08	3.3E-07	5.0E-07	9.6E-07	8.2E-06	1.2E-05
	40	18	11	3.636363636	6.85	10.92	12.40	4.6E-08	3.8E-07	5.8E-07	1.2E-06	9.6E-06	1.4E-05
	7.23	11.62	13.33	5.5E-08	4.3E-07	6.4E-07	1.4E-06	1.1E-05	1.6E-05				
	7.60	12.31	14.24	6.5E-08	4.8E-07	7.0E-07	1.6E-06	1.2E-05	1.8E-05				
7.23	11.62	13.33	4.7E-08	3.7E-07	5.5E-07	1.2E-06	9.3E-06	1.4E-05					
3.36	13.67	15.98	9.1E-08	5.5E-07	7.8E-07	2.3E-06	1.4E-05	2.0E-05					
3.73	14.33	16.83	1.0E-07	5.8E-07	8.2E-07	2.6E-06	1.4E-05	2.0E-05					
3.10	14.99	17.66	1.2E-07	6.0E-07	8.4E-07	3.0E-06	1.5E-05	2.1E-05					
3.46	15.64	18.47	1.3E-07	6.2E-07	8.6E-07	3.3E-06	1.6E-05	2.2E-05					



Dose rate @ 1 m / 90 degree in Sv/h








# Beam induced activation

- Demonstrate that bulk activation of intercepting devices is not an issue (**still contamination from RIBs !**)
  - Criteria :  $\sum_{i=1}^n A_i/LE_i < 1$  (LE = exemption limit)

	Nuclide	T <sub>1/2</sub>	LE <sub>i</sub> (Bq)	A <sub>i</sub> (Bq)	A <sub>i</sub> /LE <sub>i</sub>
Copper target	<sup>73</sup> As	80.3 d	4E+04	4.5E+00 ± 0.96 %	1.1E-04
	<sup>68</sup> Ga	67.7 m	1E+05	3.1E+01 ± 1.53 %	3.1E-04
	<sup>68</sup> Ge	270.8 d	8E+03	3.1E+01 ± 1.53 %	3.9E-03
	<sup>65</sup> Zn	244.2 d	1E+02	2.5E+01 ± 1.02 %	2.5E-01
	<sup>63</sup> Ni	100.1 y	7E+04	8.6E+00 ± 1.43 %	1.2E-04
	<sup>60</sup> Co	5.3 y	1E+02	1.2E+01 ± 3.25 %	1.2E-01
	<sup>57</sup> Co	272.0 d	1E+03	3.5E+01 ± 1.37%	3.5E-02
	<sup>56</sup> Co	77.3 d	1E+02	1.2E+00 ± 2.37%	1.2E-02
	<sup>55</sup> Fe	2.7 y	3E+04	5.5E+01 ± 1.36%	1.8E-03
	<sup>54</sup> Mn	312.5 d	1E+02	1.6E+01 ± 2.20%	1.6E-01
	<sup>3</sup> H	12.3 y	1E+05	1.3E+02 ± 0.99%	1.3E-03
					Sum = 0.00141




- No activation of the water in the dipole cooling circuit



# Outline


- Radiation Protection challenges of HIE-ISOLDE
- Shielding design for the post-accelerator
  - X-ray measurements
  - FLUKA calculations for the post-accelerator
- Ion interactions after post-acceleration
  - Operational parameters for HIE-ISOLDE
  - Activation calculations
- **Radiation Monitoring System upgrade**
- Conclusions





# Monitoring upgrade

- Additional radiation monitors needed to ensure the proper area classification
  - Unsufficient number of monitor in some areas
  - New projects
- Old monitoring system not scalable (ARCON)
- New architectural options
  - gamma monitoring (GRAMS)
  - RAMSES (LHC standard)
- Scheduling: LS1 was a good time window



# New RAMSES system

- Ionisation chambers, induced activity / X-ray monitors, Hand foot monitors.....

PS - ISOLDE - Experimental hall [Level 0] Alarms not ack: 30 Filter applied: Yes 02/09/14 11:49:15 User: dorsval Workstation ID: 140 Hostname: TSS\_5

**Channel Name: PAXIS301**  
 Dose Rate: 1.599  $\mu\text{Sv/h}$   
 Mean DR: 0.170  $\mu\text{Sv/h}$   
 Timestamp: 02/09/14 11:49:11

Device Type: AMF  
 Meas. Sampling Time: 1.2 s  
 Alarm Threshold: 10.0  $\mu\text{Sv/h}$   
 High Alarm Th.: 20.0  $\mu\text{Sv/h}$   
 Alarm Sampling Time: 60.0 s  
 Alarm Hysteresis: 5 %  
 Calibration factor: 1.16E-07 A or cs / Sv/h  
 Correction factor: 2.83

Channel status:  
 Channel OK  DA Type  
 Prim. UA  DA Power  
 Sec. UA  Parameters  
 Alarm  CRC Param.  
 High Alarm  Sensor  
 Acknow.  Sensor Cnx.  
 UA Trans.  UA DA Com.

Channel mode:  
 Measure  Maint.  Simu.  
 Off  Test

Primary UA status:  
 Normal  H Alm  Alm  
 Off / Fault  H Alm Test  Alm Test


Secondary UA status:  
 Normal  H Alm  Alm  
 Off / Fault  H Alm Test  Alm Test


ad.	UA Names	ad.	UA Names
0	PADIS301	8	
1	PADIS302	9	
2	PADIS303	A	
3		B	
4		C	
5		D	
6		E	
7		F	

Experimental Hall [Level 0] Experimental Hall [Level 1] Target Area

Lin2	Lin3	Lin4	Lin4 / Test	Lin-PS [ARCON]	Booster	ISOLDE	PS	East Area	CTF3	AD	nTOF	PS overview
25/09/14	20:03:09	Alarm on - ack.		System Fault		ISOLDE						
25/09/14	20:03:09	Alarm on - ack.		System Fault		NA62						

02/09/14 01:30:00 - TIME SYNCHRO > SNTP time synchronization with domain CERN executed





# Environmental monitoring

## Monitoring of facility releases

Aerosols  
Sampler

Gas  
monitor





Iodine Sampler

Radon/Thoron  
Monitor





INEMIA project






# GRAMS in the hall






# Conclusions

- Complete radiological analysis for the new post-accelerator
  - Post-accelerator shielding (X-ray measurements and FLUKA calculations)
  - Prompt dose due to ion beams interactions
- New monitoring system will facilitate future upgrades of ISOLDE (MEDICIS, TSR....)
- Thanks to partners visited in the frame of the CATHI program (INFN Legnaro, Triumpf, GANIL, IPNO, CEA where Sandra made her secondment...)





# Questions ?






# Experimental benchmark




**Uncertainty on beam intensity prevent to be conclusive**

	Interaction model	Evaporation model	Evolution model
PHITS 2011.2b-5	BME	SDM	DCHAIN SPD2001
		GEM	
FLUKA 2.64	QMD	New evap model (heavy fragments)	RADDECAY





# Experimental benchmark



Uncertainty on beam intensity prevent to be conclusive

