# HL-LHC Cryogenics for sc links

S. Claudet, 19Nov'14 KEK - 4th joint HiLumi LHC-LARP Annual Meeting

# Content

• The case of P7: (LS2 t.b.c)


Detailed cooling scenario & schemes studied by Udo Wagner Slides mostly extracted from MS57 reference document recently integrated in HILUMILHC-DeI-D6-2-V0

• The case of P1/P5:


Basic considerations so far (LS3...)

Link cooling almost for free due to large mass-flow required for leads (how to make sure for P7 that the rather small cooling flow is well distributed around the conductor all along the length and bends?)

## HL-LHC new sc links @P7




#### Baseline as presented in "HILUMILHC-DeI-D6-2-V0"




4th LHC-LARP Meeting, KEK, Nov'14

#### Baseline as presented in "HILUMILHC-Del-D6-2-V0" with out modification of the QRL header. *Schematic & work by Udo Wagner*



4th LHC-LARP Meeting, KEK, Nov'14



- 1 warm compressor station (WCS) in noise insulated surface building
- 1 upper cold box (UCB) in surface building
- 1 cold quench buffer (QV) in surface
- 1 or 2 cold compressor boxes (CCB) in underground cavern,
- 2 main cryogenic distribution lines
- 2 interconnection valve boxes with existing QRL





QRI


 $\bowtie$ 

### Text extracted from Del 6.2

Cooling options for the cold powering system

The cooling system for the current feed boxes of the inner triplets and the matching sections at LHC P1 and P5 is still under study. At this stage, the general cooling principle retained is the same as for the arc current feed boxes in these points. For the feed boxes, the option exists to use a dedicated transfer line on surface level between the new refrigerator and the DFHX to cool the current leads – instead of using the link for transferring gas from the tunnel as done for the cold powering system at LHC P7.

A final cooling system will be elaborated in parallel with the work to be made for the definition of the new refrigerators and for the design of the DFA and DFH cryostats.



## Main messages

- For P1 & P5, a completely new cryogenic distribution system will be studied and implemented: the needs for the sc links will surely be part of the design and associated optimisation. The potential vertical part might need specific study (transient, stability)
- For P7, a cooling process compatible with existing constraints exists since spring'14, we would be ready to proceed with definition of piping & valve requirements