



Contribution ID: 100

Type: Poster Presentation

## Development of a cooling system for 66/6.9kV-20MVA REBCO superconducting transformers with a Ne turbo-Brayton refrigerator and subcooled liquid nitrogen

*Monday, June 29, 2015 9:00 AM (2 hours)*

In Japan, we have developed 3 $\phi$ -66/6.9kV-20MVA RE1Ba2Cu3O7- $\delta$ (RE:Rare Earth, Y, Gd and so on, REBCO) superconducting transformers with a current limiting function as a national project. First we made a basic research on the ac loss reduction and the enhancement of current capacity of REBCO superconducting tapes, the dielectric strength of liquid nitrogen, a current limiting function of REBCO superconducting windings and so on. The subcooling of liquid nitrogen was required from the viewpoint of dielectric strength. We have finished the design of a 20MVA transformer and fabricated a 1/10 model, i.e. 3 $\phi$ -66/6.9kV-2MVA one. The superconducting windings were installed in a GFRP cryostat and cooled with subcooled liquid nitrogen at 65 to 77 K. The iron core was located at room temperature. For the sake of a long maintenance interval and a high cooling efficiency, we developed a turbo-Brayton refrigerator with neon gas as a working fluid. The cooling capacity was 2kW at 65K. Here an expansion turbine and a two-stage turbine compressor with non-contact magnetic bearings were adopted. In the 2MVA model, liquid nitrogen was forced-flowed between the GFRP cryostat and an additional cryostat in which a pumping system and a heat exchanger between the neon gas and the liquid nitrogen were installed. In addition, for the future system, we are making a research and development of a new cooling system in which a radiator-type heat exchanger was directly installed into the GFRP cryostat. In this paper we will report the progress of the research and development.

*This work was supported in part by New Energy and Industrial Technology Development Organization (NEDO) as Technological Development of Yttrium-based Superconducting Power Equipment.*

**Primary author:** IWAKUMA, Masataka (Kyushu University)

**Co-authors:** Dr HAYASHI, Hidemi (Kyuhen); Dr HIRAI, Hirokazu (Taiyo Nippon Sanso Co.); Mr ADACHI, Kazuhisa (Kyushu University); Mr YUN, Kiwook (Kyushu University); Dr YOSHIDA, Shigeru (Taiyo Nippon Sanso); Dr IZUMI, Teruo (ISTEC); Mr EGUCHI, Tohru (Kyushu Electric Power Co.Inc.); Mr SUZUKI, Yoshiaki (Taiyo Nippon Sanso Co.); Dr SHIOHARA, Yuh (ISTEC); Mr OHTSUBO, Yuhei (Kyushu University)

**Presenter:** IWAKUMA, Masataka (Kyushu University)

**Session Classification:** C1PoA - Cryogenics for Power Applications, Energy, Fuels and Transportation I

**Track Classification:** CEC-02 - Large-Scale Systems, Facilities, and Testing