


# Probabilistic fire risk assessment in ESS

## Preliminary Safety Analysis Report – challenges and opportunities – OECD fire



Fredrik Jörud

Fire Protection Manager

[www.europeanspallationsource.se](http://www.europeanspallationsource.se)

# Agenda

- Statistic input
- Requirements
- Example on waste building
  - Safety documentation application #2
- How to improve statistics



# Stronger statistics important to justify the probabilistic analysis

Organisation for Economic Co-operation and Development –  
Headquarters 2 rue André Pascal, 75775 Paris

## OECD FIRE Database

This release of the database is for project members ONLY. It is preliminary and should NOT be distributed to others. Project members are national Coordinator organizations or organizations who have provided data - National Coordinators must ensure proper distribution.

2005-05-15 Demo

Confidential under the agreement of CSNI/NEA task force on International Fire Data Exchange

- Fire event VIEW
- Fire event EDIT
- Search with codes
- QA Search
- Exit

# Why statistics ?

NBSG Report 2009:008 "Fire Event Trees Construction Based on OECD Fire Database" – 310 incidents from 10 countries



**Table 1. List of cause/initial event**

<b>Event</b>	<b>number</b>
Heater	11
Hot work	23
Oil on insulation	20
Material/Component/design	20
Human error/carelessness	27
Filter	4
Generator	8
Kitchen/changing room/office etc	4
Garbage	5
Lamp/Light	3
Electrical motor	3
Electrical fault	36
Poor Maintenance	5
Oil	5
Bearing	5
Procedure	6
Fan	3
Pump	3

# Event tree accuracy



## NBSG Report 2009:008 "Fire Event Trees Construction Based on OECD Fire Database"

	Detection system present	Fire Detected by system	Fire detected manually	Automatic Extinguishing system present	Extinguished by system	Fire Extinguished manually	Fire self extinguish/ room integration OK		
									Limited to room
					yes				Limited to room
				yes					Limited to room
					no	yes			Limited to room
						no	yes		Limited to room
							no		Fire spread out of room
		yes							Limited to room
				no		yes			Limited to room
						no	yes		Limited to room
							no		Fire spread out of room
					yes				Limited to room
				yes		yes			Limited to room
					no	no			Limited to room
	yes						yes		Limited to room
		no	yes				no		Fire spread out of room
				no					Limited to room
						yes			Limited to room
						no			Limited to room
Fire in more than one component in one room			no				yes		Limited to room
							no		Fire spread out of room

# Ionization radiation requirements

# Rad safety “Probabilistic Requirement”

ESS- 0015358 SSM licensing conditions

Demonstrate how to avoid:



> 0,1 mSv to public within a return time of 100 years

> 1 mSv to public within a return time of 10 000 years

> 20 mSv to public within a return time of 1 000 000 years

> 100 mSv to public within a return time of 10 000 000 years

# Public at 300 m from Target



Public



# Reference values – environmental/ public impact

ESS- 0015358SSM licensing conditions



<u>Event class</u>	<u>Reference value (mSv)</u>
Anticipated events (H2)	0.1
Unanticipated events (H3)	1.0
Improbable events (H4A)	20
Events with multiple failures (H4B)	20
Highly improbable events (H5)	100

## H2 – anticipated fire

To be expected from statistics is:  
Fire  $\approx$  within a return time of 4 years

References:  
- OECD database  
- Existing Lab experience



# Definition of Fire

To be expected from statistics is:

Fire + Jeopardize of radiation barrier < 100 years return time

References:

- OECD database
- Existing Lab experience



H3

# Probabilistic requirement – H3

ESS- 0015358 SSM licensing conditions

*Unanticipated events (H3):*

events and circumstances outside the specified conditions and restrictions which are not expected to occur during the facility's lifetime. The frequency range is greater than or equal to  **$10^{-4}$**  but less than  **$10^{-2}$**  per year,

# Deterministic requirements

# Statistics is useless if you can not validate the circumstances

Statistics based on this....




Is no good to justify this.....



# Fire- & Explosion Safety Program





BUILDING- & OPERATIONS PERMIT



# Defence in depth (DID)

ESS- 0015358 SSM licensing conditions

## SSM Ch4

- |  | IAEA   | NS-G-1.7                      |
|--|--|-------------------------------|
| 1. <b>prevent</b> deviations from normal operations  |    | ▪ Prevent fires from starting |
| 2. <b>detect</b> deviations  |  |                               |
| 3. <b>minimise the impact</b>  |    | ▪ Detect & extinguish quickly |
| 4. ensure that radioactive <b>emissions</b> to the environment are <b>as low as reasonable</b> |    |                               |
| 5. <b>mitigate</b> the radiological consequences   |  | ▪ Prevent spread              |




# Waste building example

# Representative H3 event

- Dropped transport container with target material
- Fire in **waste building**
- Fire in HEPA filter or cyclone filter for the He cooling circuit

**Release factor** assumed on nuclide inventory:  
Volatiles 10% of the inventory  
Aerosols <1% of the inventory



# What to do if frequency of rad exposure is not acceptable!

- Improve fire frequency statistics ?
- Improve accuracy on nuclide inventory ?
- Improve barrier ?
  
- The ESS-0002642 improve barrier!



List PIE as addressed in [4] & [5] at designated building (Ch 3.1, 4.1, 5.1)

Interpret maximum radiation exposure possible ref. [22]

Estimate maximum consequences for rescue workers and public & tag unacceptable consequence CR1, CR2, CR3...etc.

Suggest redesign of machine/building (Ch. 6) OR Increase protection of barriers as necessary (Ch. 3.3, 4.3 & 5.3)

Identify DID active systems necessary for barrier integrity in case of fire or explosion in H3 [2] or more frequent. Also secondary effects are considered.

Adopt SF & CCF & EQ on components necessary for protection of barriers

Apply features as necessary. Tagged as "SF" or "CCF" or "EQ"

<p>Fire or explosions</p> <p>[5]/[4]</p> <p>Identity of Top Event</p>	<p>Equipment involved in the scenario &amp; estimated frequency based on ref [4], [5]</p>	<p>Estimated radiological release from fire scenario if <u>not</u> contained or shielded but with presumption proton beam is shut down when rescue operation is initiated</p> <p>Estimations are based on Ref [22]</p> <p>Acceptable (A)/ Not Acceptable (NA)</p>			
		<p><b>Rescue workers <u>without</u> breathing apparatus</b></p> <p>acc. level 50 mSv</p>		<p><b>Public at 300 m distance or external residual water systems</b></p> <p>acc. level 5 mSv (H3)</p> <p>20 mSv (H4)</p>	
		<p><b>Direct Radiation</b></p>	<p><b>Air Contamination</b></p>	<p><b>Air Contamination</b></p>	<p><b>Solids in residual fire fighting water</b></p>
<p>22/-</p>	<p><b>Hot Cell</b></p> <p>Irradiated tungsten wheel, HEPA- filter and electrical equipment</p> <p>Frequency H3</p>	<p>(NA)</p> <p><b>CR4</b></p>	<p>(NA)</p> <p><b>CR5</b></p>	<p>(NA)</p> <p><b>CR6</b></p>	<p>(NA)</p> <p><b>CR7</b></p>
<p>23/-</p>	<p><b>High Bay</b></p> <p>Hydrogen fire or plastic shielding</p>	<p>(A)</p>	<p>(A)</p>	<p>(A)</p>	<p>(A)</p>

# Evaluate building envelope



Waste building

# Where is the barrier ?


1. A fire is postulated (H3)
2. The building does not resist a full scale fire






# Barrier design

# Single Failure & Common Cause Failure



claimed passive  
(ref ESS-0002642)




**3<sup>rd</sup> part of the PSAR documentation  
(justify deterministic barrier)**

Seismic/below frostline/pressure from heavy goods transport => High density PE 16 bar



# Zone of influence & severity factor

Ref. EPRI/NRC-RES Fire PRA Methodology CR6850



*4<sup>th</sup> part of the PSAR documentation  
(realistic probabilistic justification)*

# General information

OECD FIRE ID

### 3.1.1 Event title

### 3.1.2 Plant

### 3.1.4 Date and time of detection (YYYY-MM-DD HH:MM)

### 3.1.10 Operation mode prior to event

### 3.1.11 Suppression time (HH:MM)

### Suppression time clarification

### 3.1.12 Duration time (HH:MM)

### Duration time clarification

### 3.1.7 OECD FIRE Event description

Plant: Olkiluoto 2

Operational mode: Power operation, reactor power prior the fire 100%, after the fire 25 %.


Location: turbine building

On 28.1.1998 the control room personnel observed during regular checking of the plant parameters that an oil level in the turbine oil tank was decreasing. According to plant computer the level decrease had started at

### 3.1.8 Sequence of events

Time	Description
1998.01.28 18:30	Indirect indication - oil level decreasing, process computer
1998.01.29 00:20	Localisation of oil leakage

# Ignition phase

OECD FIRE Events		Edit	
		OECD FIRE ID	JP-20021212
<b>3.2.1 Building where the fire started</b>	Turbine building		
<b>3.2.2 Room/Plant area where the fire started</b>			
<b>3.2.3 Type of room where the fire started</b>	Other	Turbine floor	
<b>3.2.4 Component where the fire started</b>	Turbine generator		
<b>3.2.5 Ignition mechanism</b>	Hot component		
<b>3.2.6 Root cause</b>	Equipment		
Press CTRL and select one or more code from the list	Equipment Other Human error Unknown	<input type="button" value="Select Codes"/>	
<b>3.2.7 Type of fire detection</b>	Plant walk down		
Press CTRL and select one or more codes from the list	Fire alarm system Fire guard/watch Plant walk down Indirect signals	<input type="button" value="Select Codes"/>	
<b>3.2.8 Detector Type</b>	Unknown		
Press CTRL and select one or more codes from the list	Flame detector Heat detector Infrared detector	<input type="button" value="Select Codes"/>	

# Extinguishing phase

## OECD FIRE Events

Edit



OECD FIRE ID JP-20021212

### 3.3.1 Type of Extinguishing

Press CTRL and select one or more codes from the list

Fixed system - Automatic actuation;Manual fire fighting

Fire source isolation  
Fixed system - Automatic actuation  
Self extinguishing  
Fixed system - Manual actuation  
Other means

Select Codes

### Type of system/equipment used

Press CTRL and select one or more codes from the list

Halon;Dry chemical (Portable)

Carbon dioxide  
Other fixed system  
Water mist  
Spray water deluge  
Foam system

Select Codes

### 3.3.2 Fire extinguishing system performance

Normal

### 3.3.3 Who extinguished successfully the fire

External fire brigade

Press CTRL and select one or more codes from the list

People available in the fire area  
Self extinguished

# Consequence

## OECD FIRE Events

Edit



OECD FIRE ID JP-20021212

### 3.4.1 Operational mode due to the fire

Shutdown mode

### 3.4.2 Heat or hot gases influence

None

### 3.4.3 Smoke influence

None

### 3.4.4 Secondary effects

None

### 3.4.5 Corrective actions

Press CTRL and select one or more codes from the list

Procedure modification  
Design modifications  
No corrective actions

Select codes

### 3.4.6 Comments on consequence and corrective actions



- Lack of data from proton accelerators and similar laboratories has pushed the importance to also display data from the nuclear industry as background information for consideration.
- An interregional exchange of information, to increase the accuracy on decision support activities for prevention of fire- and explosion accidents, is considered as the proper path for justification.
- The OECD FIRE project or equal systematic activity is recommended to also include proton accelerators and similar laboratories.
- The regulators should get involved!

# ESS- 0015358 SSM licensing conditions

- *Anticipated events (H2)*: events and circumstances outside the specified conditions and restrictions which can be expected during the facility's lifetime. The frequency range is greater than or equal to  **$10^{-2}$  per year**,
- *Unanticipated events (H3)*: events and circumstances outside the specified conditions and restrictions which are not expected to occur during the facility's lifetime. The frequency range is greater than or equal to  **$10^{-4}$  but less than  $10^{-2}$**  per year,
- *Improbable events (H4A)*: events and circumstances outside the specified conditions and restrictions which are not expected to occur. The frequency range is, excluding external hazards, greater than or equal to  **$10^{-6}$  but less than  $10^{-4}$**  per year. For external risk sources, the frequency range is greater than or equal to  $10^{-5}$  but less than  $10^{-4}$  per year,
- *Events with multiple failures (H4B)*: events and circumstances outside the specified conditions and restrictions in the frequency range greater than  $10^{-4}$  per year, analysed in combination with common cause failures in the safety group instead of a single failure,
- *Highly improbable events (H5)*: events and circumstances that can potentially lead to significant radioactive emissions to the surrounding area.