

# Overview of the Air Management System in the ESS Accelerator tunnel

Duy Phan

Accelerator Safety Engineer

Reviewed by Daniela Ene, Mikael Kelfve, Fredrik Jörud & Lali Tchelidze

[www.europeanspallationsource.se](http://www.europeanspallationsource.se)

6th October 2015




## **Main topics addressed**

- **Current design** of the Accelerator HVAC system during normal operation...
- Overview of a **concept of fire control** in the tunnel...
- Safety approach against **Oxygen Deficiency Hazard** in the tunnel...
- On-going and foreseen **safety studies**...
- **Planning** for the Accelerator HVAC system...

# Accelerator Air Management System


## Introduction - ESS Project

**Energy:** 2 GeV  
**Current:** 62.5 mA  
**Average power:** 5 MW  
**Pulse:** 2.86 ms  
**Frequency:** 14 Hz



# Accelerator Air Management System Introduction

## ESS Organization chart (simplified)



① **Specifies the Safety requirements** for the design of the HVAC system (e.g. fire control philosophy, minimum air renewal for workers, minimum air flush before access, etc.)


② **Specifies the performance requirements** for the design of the HVAC system (e.g. temperature and humidity control) and **provides support for the mitigation of the safety issues** (e.g. CFD simulations, hazard analysis, etc.)

③ **Designs the HVAC system according to the requirements** provided by the Accelerator and ES&H Divisions

# Accelerator Air Management System

## Introduction

## Overview of the Accelerator areas




# Accelerator Air Management System

## Current design




### 4 Ventilation modes

- ① « Beam mode »
- ② « Flush mode »
- ③ « Access mode »
- ④ « Fire mode »

+ Fire suppression system




### Air exhaust system



# Accelerator Air Management System

## Current Design

### ① BEAM MODE




# Accelerator Air Management System

## Current Design

## ② FLUSH MODE

31 500 m<sup>3</sup>/h




**Air inlet:** 25 200 m<sup>3</sup>/h (2 ACH)  
**Air outlet:** 31 500 m<sup>3</sup>/h (2.5 ACH)  
**Estimated air leaks:** 6300 m<sup>3</sup>/h (0.5 ACH)

**ΔP vs Klystron Gallery** = -120 Pa and -140 Pa (currently under discussion)  
**ΔP vs outdoors** = between -120 Pa and -140 Pa (currently under discussion)

Proton beam

25 200 m<sup>3</sup>/h





# Accelerator Air Management System


## Current Design

### ③ ACCESS MODE


25 200 m<sup>3</sup>/h

**Air inlet:** 25 200 m<sup>3</sup>/h (2 ACH)  
**Air outlet:** 25 200 m<sup>3</sup>/h (2 ACH)

**ΔP vs Klystron Gallery** = no under pressure required (currently under discussion)  
**ΔP vs outdoors** = no under pressure required (currently under discussion)




25 200 m<sup>3</sup>/h



# Accelerator Air Management System

## Fire control concept in the tunnel


### Preliminary design



# Accelerator Air Management System

## Fire control concept in the tunnel

### Fire event



**Step 1:** a **fire occurs** in the tunnel

**Step 2:** the **fire is detected** by the smoke detection system

**Step 3:** the **fire alarm is sent**, the **fire damper of the air supply closes**, the **proton beam stops** and the **fire suppression system triggers** (opening of the control valve) upon detection of the fire and melting of the fusible alloy (O<sub>2</sub> ↓ and dynamic confinement preserved)

**Step 4:** if the filter gets clogged or the maximum operative temperature is exceeded, the **fire damper of the air exhaust closes**

# Accelerator Air Management System

Fire control concept in the tunnel

## Pre-action system


### Main aspects:

- **No standing activated water** in the tunnel
- **Double security** regarding unwanted activation
- Very well known and **reliable system** (e.g. pipe integrity monitored (air tightness))
- **Low amount of water** in case of a fire (600 l)
- Sectioned into **8 smaller subsystems**
- **Fairly low cost** → €270.000

# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### Overview of the helium inventory in the tunnel



# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### Overview of the helium inventory in the tunnel

Component	Quantity	Maximum helium mass [kg]			
		Per item		In total	
		at nominal operation	at transient mode	at nominal operation	at transient mode
CDS	1	266 (315 <sup>*</sup> )	605 (686 <sup>*</sup> )	266 (315 <sup>*</sup> )	605 (686 <sup>*</sup> )
Elliptical CM	30 (44 <sup>**</sup> )	34	29	1014 (1488 <sup>**</sup> )	882 (1293 <sup>**</sup> )
Spoke CM	13	21	18	277	240

\* including additional distribution line


\*\* including all contingent cryomodules

# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### Preliminary design

1 ODH scanner per stub (27)



-  Fire damper
-  O2 analyzer
-  Sniffer




**No ODH probes in the accelerator tunnel**

# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### ODH event during Access Mode



If a Helium discharge occurs, **it will be partly handled by the ventilation system...**



**Lesson learnt from CERN visit (2 July 2015)**

→ air speed from the ventilation should not exceed 1 m/s to facilitate evacuation




# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### Open issue for evacuation


ACKNOWLEDGEMENT : N.GAZIS



# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### Open issue for evacuation



ACKNOWLEDGEMENT : N.GAZIS


# Accelerator Air Management System

## Oxygen Deficiency Hazard in the tunnel

### Failure scenarios (during access)

#### Scenario


Rupture of the power coupler's window or beam line



Loss of the content of 1 High-Beta\* cryomodule (28,4 kg)

Discharge of GHe through the 2 ruptured disks located on the LHe line

Max. mass flow rate = 15,2 kg/s (current)



the triggering of the fast valves in-between cryomodules

# Accelerator Air Management System

## On-going Safety studies



### ODH Control Measures

- Simple a
- Homoge atmosph
- Assessm respect t
- Lowest

ODH Class	0	1	2	In place?	
				Yes	No
<b>Technical Safety measures</b>					
Warning signs	X	X	X	<input type="checkbox"/>	<input type="checkbox"/>
Ventilation		*	*	<input type="checkbox"/>	<input type="checkbox"/>
Area (fixed) Oxygen Monitoring	*	X	X	<input type="checkbox"/>	<input type="checkbox"/>
<b>Organizational Safety measures</b>					
Medical approval as ODH qualified		*	*	<input type="checkbox"/>	<input type="checkbox"/>
ODH traning (e-learning)	X	X	X	<input type="checkbox"/>	<input type="checkbox"/>
Personal oxygen monitor		X	X	<input type="checkbox"/>	<input type="checkbox"/>
Self-rescue mask		*	*	<input type="checkbox"/>	<input type="checkbox"/>
Presence of minimum 2 persons			X	<input type="checkbox"/>	<input type="checkbox"/>
<b>Administrative Safety measures</b>					
Access restricted to authorized personnel only		X	X	<input type="checkbox"/>	<input type="checkbox"/>
Emergency procedure		X	X	<input type="checkbox"/>	<input type="checkbox"/>
Working procedure	X	X	X	<input type="checkbox"/>	<input type="checkbox"/>

\* to be evaluated case by case

$\phi =$  According to the ODH process, depending of the complexity of the case the Cryogenic Safety Committee can require a further ODH analysis (e.g. Computation Fluid Dynamics) and/or additional control measures.

EUROPEAN SPALLATION SOURCE

actor\*

Time needed to reach 18% O2

Always above 18%

31,2 s

22,3 s

11,5 s

**Objective:** Provide help to Conventional Facilities (CF) in the design of the HVAC system

**Responsibility:** Accelerator Division

**Time frame:** finalized

5	135 m	1 smoke extractor	After 30 s	50,5 s
6	135 m	2 smoke extractors	After 30 s	40,9 s

# Accelerator Air Management System

## On-going Safety studies


## CFD simulation of Helium discharge

- ① Temperature and O2 concentration need to be evaluated locally (close to the He discharge points) as well as pressure rise
- ② Assessment of human evacuation (pathway, time) in case of a helium release
- ③ Help in the decision-making to CF for the design of the ventilation system
- ④ Help in the definition of the access procedure to the LINAC (warm-up, cool-down, steady-state)

**Objective:** Provide help to Conventional Facilities (CF) in the design of the HVAC system

**Responsibility:** Accelerator & EIS Divisions

**Time frame:** first results expected end October



# Accelerator Air Management System

## On-going Safety studies

<https://ess-ics.atlassian.net/wiki/pages/viewpage.action?pageId=46137511>

## HVAC risk analysis

- Identification of the failure modes that could lead to exposure to ionizing radiation or conventional hazards (e.g. ODH, fire)
- Identification & classification of the safety functions → SSM requirement

FROM ESS GSO			FROM SSM
ESS Safety Objectives			Current
Operating conditions Initiating event likelihood	Workers limit (effective dose)	Public limit (effective dose)	Public limit
Normal operation - H1	10 mSv/year	0,05 mSv/year	0,1 mSv
Incidents – H2 $F > 10^{-2}$ <i>Ex : loss of external power or target cooling</i>	20 mSv/event	0,05 mSv/occurrence	0,1 mSv
Unexpected events - H3 $10^{-4} < F < 10^{-2}$	50 mSv/event	0,5 mSv/occurrence	1 mSv
Design Basis Accident – H4 $10^{-6} < F < 10^{-4}$	50 mSv/event	20 mSv/occurrence	20 mSv
Highly improbable events – H5 $10^{-7} < F < 10^{-6}$ <i>Ex : plane crashes, major earthquake</i>			100 mSv

**Recommendation from CERN experts during their visit on July 2nd**

**Objective:** Provide help to Conventional Facilities (CF) in the design of the HVAC system  
**Responsibility:** CF & Accelerator Divisions  
**Time frame:** final version expected December

Risk Assessment	Safety function	Failure mode Hazardous event	Phase	Causes	Consequences	Control measures (Preventive and Protective)	Severity	Further measures suggested	Remarks
01	Operational maintenance of the collecting duct	Uncontrolled release of airborne contaminants to the laboratory and adjacent areas (e.g. emergency exit)	Normal operation - H1	Human error (e.g. incorrect setting of the fan speed)	Uncontrolled release of airborne contaminants to the laboratory and adjacent areas (e.g. emergency exit)	Warning of the differential pressure between the laboratory and adjacent areas	Low	Specification of the register process needed for the collector system (not related to adjacent areas for a single person getting close of the ECR103 as a starting point) Specification of the air filter maintenance on the ducts Filter have to be checked according to the standard EN 778 Filter replacement of the supply system in case of problem with the differential pressure in the fan room (to be discussed)	
02	Operational maintenance of the collecting duct	Uncontrolled release of airborne contaminants to the laboratory and adjacent areas (e.g. emergency exit)	Normal operation - H1	Human error (e.g. incorrect setting of the fan speed)	Uncontrolled release of airborne contaminants to the laboratory and adjacent areas (e.g. emergency exit)	Warning of the differential pressure between the laboratory and adjacent areas	Low	Specification of the register process needed for the collector system (not related to adjacent areas for a single person getting close of the ECR103 as a starting point) Specification of the air filter maintenance on the ducts Filter have to be checked according to the standard EN 778 Filter replacement of the supply system in case of problem with the differential pressure in the fan room (to be discussed)	
03	Operational maintenance of the collecting duct	Uncontrolled release of airborne contaminants to the laboratory and adjacent areas (e.g. emergency exit)	Normal operation - H1	Human error (e.g. incorrect setting of the fan speed)	Uncontrolled release of airborne contaminants to the laboratory and adjacent areas (e.g. emergency exit)	Warning of the differential pressure between the laboratory and adjacent areas	Low	Specification of the register process needed for the collector system (not related to adjacent areas for a single person getting close of the ECR103 as a starting point) Specification of the air filter maintenance on the ducts Filter have to be checked according to the standard EN 778 Filter replacement of the supply system in case of problem with the differential pressure in the fan room (to be discussed)	

# Accelerator Air Management System

## On-going Safety studies


### HVAC



**Objective:** The main objective is to ensure that the necessary actions can be taken in order to prevent or mitigate the consequences of the accident scenarios in the accelerator tunnel. The study only takes into consideration the main safety interlocks.

**References:**  
- M.Kelfve - PID of the Accelerator Air Management System

\*: devices considered as secondary detection  
X: main safety interlock  
\*: devices considered as secondary detection  
X: main safety interlock  
X: primary detection device  
x: secondary detection device



### BEAM MODE

#### Failure scenarios

Loss of the dynamometer

#### Failure scenarios

Fire ignition (reference)

Accidental release of the beam

### FLUSH MODE

#### Failure scenarios

Loss of the dynamometer

Failure Scenario	ODH Detectors - Accelerator tunnel	ODH Detectors - Accelerator tunnel	Evacuation Alarm System	Evacuation Alarm System	Fire Extinguishing System	Fire Extinguishing System	Actions Triggered by Interlock	Actions Triggered by Interlock	Actions Triggered by Operation	Actions Triggered by Operation	Fire Detectors - Accelerator tunnel	Fire Detectors - Accelerator tunnel
Loss of the dynamometer			X	X					X	X		
Fire ignition (reference)	X	X	X	X					X			X
Accidental release of the beam												X
Loss of the dynamometer			X	X						X		X

Accelerator  
On-going

Calculation

Type of ventilation

I
II A
II B
III A
III B
IV

pressure  
**Responsibility:**

Type of ventilation	Foreseen radioactive contamination	Organization of the ventilation systems and filtration unit
Non-contaminated areas		
T I	Pc: Not significant Ac: Low	
T II A	Pc: Not significant Ac: Medium	
T II B	Pc: Not significant Ac: High	




EUROPEAN SPALLATION SOURCE

Report/ESS-0028010/1

Non-contaminated areas  
classification

C1
C2
C3
C4*
C4**
C4***



\* It is the amount of contamination that would result in the Annual Limit of Ingestion (ALI) or reference conversion factors




# Accelerator Air Management System

## On-going Safety studies

### Releases of activated air: Linac (5000 hr irradiation)

Rationuclide	Released activity (Bq/y)	Maximum effective dose <sup>a</sup> (Sv/y)		
		Västra Odarslöv	Hypothetical Critical Group	Östra Torn
H-3	8.18E+07	8.34E-13	1.77E-12	7.16E-13
Be-7	4.50E+05*	4.55E-13	9.68E-13	3.92E-13
Be-10	3.27E-02	1.10E-18	2.33E-18	9.42E-19
C-11	2.64E+12	1.91E-08	4.07E-08	3.78E-08
C-14	2.20E+07	1.06E-10	2.24E-10	9.13E-11
N-13	6.77E+12	4.20E-08	8.73E-08	9.27E-08
N-14	4.71E+11	1.82E-09	3.20E-09	8.62E-09
O-15	3.98E+12	9.67E-09	2.03E-08	3.49E-08
O-19	2.99E+08	2.97E-14	4.40E-14	2.53E-12
Ne-23	7.70E+08	2.86E-14	5.80E-14	3.74E-13
Ne-24	2.29E+08	4.67E-13	9.87E-13	1.25E-12
Na-22	6.22E+04	1.57E-10	3.33E-10	1.35E-10
Na-24	1.34E+08	3.03E-10	6.45E-10	2.65E-10
Na-25	1.34E+09	4.66E-13	9.73E-13	3.08E-12
Mg-27	2.08E+09	1.61E-10	3.41E-10	1.69E-10
Mg-28	1.95E+07	1.87E-10	3.98E-10	1.61E-10
Al-26	3.16E-01	1.31E-15	2.79E-15	1.13E-15
Al-28	8.95E+09	7.03E-10	1.49E-09	1.14E-09
Al-29	4.41E+09	4.30E-11	8.95E-11	8.38E-11
Si-31	1.87E+09	4.82E-11	1.03E-10	4.19E-11
Si-32	6.86E+02	1.52E-14	3.24E-14	1.31E-14
P-30	1.30E+06	6.61E-15	1.42E-14	1.51E-14
P-32	1.55E+04	4.97E-12	1.06E-11	4.29E-12
P-33	8.04E+03	3.38E-13	7.20E-13	2.92E-13
P-35	9.00E+05	2.99E-14	6.34E-14	1.30E-13
S-35	3.93E+03	1.19E-13	2.54E-13	1.03E-13
S-37	3.09E+06	4.85E-14	9.61E-14	1.03E-13
S-38	1.70E+05	2.48E-14	5.27E-14	2.38E-14
Cl-36	2.15E+01	8.86E-13	1.88E-12	7.63E-13
Cl-38	3.32E+10	1.05E-09	2.20E-09	1.28E-09
Cl-39	3.82E+10	1.40E-09	2.96E-09	1.67E-09
Cl-40	1.34E+10	8.01E-11	1.51E-10	3.38E-10
Ar-36				
Ar-38				
Ar-40				
K-39				
K-40	2.04E-04	3.92E-18	8.32E-18	3.37E-18
<b>Total</b>	<b>1.49E+13</b>	<b>8.57E-08</b>	<b>1.79E-07</b>	<b>1.97E-07</b>

\* Filter effect (0.03%) # three age groups considered (SSM 13-3285, 2014)



### HVAC parameters:

Vol<sub>tunnel</sub> = 12600 m<sup>3</sup>

Function	Vent. Rate** (m <sup>3</sup> /hr)	Stack diameter (m)	Exhaust speed (m/s)	Hepa filter	Controlled exhaust
Tunnel on-line vent	12600	1.8 - 1.9	12	On main stack	yes
Flush mode >1/2 hr cool down	31500	1.8 - 1.9	12	On main stack	yes
Tunnel access	25200	1.8 - 1.9	12	On main stack	yes

\*\* M. Kelfve, CF

Critical group	Distance <sup>+</sup> (m)	Azimuth <sup>##</sup> (°)
Västra Odarslöv	660	0
Hypothetical	650	90
Östra Torn	330	180

+ from the release point  
## degrees from North




ESS Accelerator Design objective: 0.03 mSv/y  
ESS General Safety Objective: 0.05 mSv/y

"Skyshine" (direct radiation) and water activation not considered

# Accelerator Air Management System Milestones

## HVAC timeline



**Any Questions...?**

# Back-up slides

# Accelerator Air Management System

## Fire control concept in the tunnel

## Fire load estimation

Fire load estimation					
<b>ELECTRICAL CABLES</b>					
Hypothesis:					
<input type="checkbox"/> Cable weight = 60 kg/m -> total = 60 x 602 = <b>36 120 kg</b> <input type="checkbox"/> Insulation weight (80% of the electrical cables) = 0,80 x 36120 = <b>28 896 kg</b> <input type="checkbox"/> 126 types of electrical cables (ref. ESS Approved Cable List_2015_02_02_lia.xlsx) <ul style="list-style-type: none"> <li>• PVC - 62 cables (49%)</li> <li>• PE - 42 cables (33%)</li> <li>• Teflon - 1 cable (0,8%)</li> <li>• Polyolefin - 1 cable (0,8%)</li> <li>• PVDF - 1 cable (0,8%)</li> <li>• No information about insulation - 6 cables (4,8%) --&gt; as a conservative approach, these cables will be considered as isolated with PVC</li> <li>• No insulation - 13 cables (10%)</li> </ul>					
<input type="checkbox"/> Tray + support weight = 15 kg/m -> total = 15 x 602 = <b>9030 kg</b>					
Type of material	Classification according to CERN IS 41 & ES&H requirements	Quantity	Lower heating value	Heat of combustion	Reference
PVC	Forbidden	0,49 x 28 896 = <b>14 159 kg</b>	20 MJ/kg	14 159 x 20 = <b>283 180 MJ</b>	SS-EN-1991-1-2
PE	Suitable only with fire retardant NOT containing halogen, sulphur and phosphorus	0,33 x 28 896 = <b>9536 kg</b>	40 MJ/kg	9536 x 40 = <b>381 440 MJ</b>	SS-EN-1991-1-2
Teflon	Forbidden	0,008 x 28 896 = <b>231 kg</b>	5 MJ/kg	231 x 5 = <b>1155 MJ</b>	Autocobtest
Polyolefin (PE)	Suitable only with fire retardant NOT containing halogen, sulphur and phosphorus	0,008 x 28 896 = <b>231 kg</b>	40 MJ/kg	231 x 40 = <b>9240 MJ</b>	SS-EN-1991-1-2
PVDF	Forbidden	0,008 x 28 896 = <b>231 kg</b>	20 MJ/kg	231 x 20 = <b>4620 MJ</b>	SS-EN-1991-1-2
Insulation not identified (considered as PVC)	Forbidden	0,048 x 28 896 = <b>1387 kg</b>	20 MJ/kg	1387 x 20 = <b>27 740 MJ</b>	SS-EN-1991-1-2
<b>TOTAL</b>		<b>26006 kg</b>		<b>707 375 MJ</b>	
<b>BEAM DUMP</b>					
Type of material		Quantity	Lower heating value	Heat of combustion	Reference
Graphite		<b>350 kg</b>	33 MJ/kg	350 x 33 = <b>11 550 MJ</b>	Wikipedia
<b>TOTAL HEAT OF COMBUSTION</b>					
Type of material		Heat of combustion	Ground surface	Fire load	
Electrical cables + beam dump		707 375 + 11 550 = <b>718 925 MJ</b>	3600 m <sup>2</sup>	<b>200 MJ/m<sup>2</sup></b>	

# Accelerator Air Management System


## On-going Safety studies

## CFD Project Request

**Objective:** Define the boundary conditions necessary for the CFD simulation

**Responsibility:** Accelerator Division

**Time frame:** finalized



✓ **Hazardous scenarios**

↳ Leak, abrupt rupture, discharge from safety device, etc.

✓ **Tunnel dimensions and characteristics**

↳ Length, width, height, internal volume, helium escape routes, etc.

✓ **Environmental conditions**

↳ Pressure and temperature in the tunnel

✓ **Description of the cryogenic circuit**

↳ Mass of helium, operating pressure and temperature, safety device, etc.

✓ **Description of the cryomodules**

↳ Mass of helium, operating pressure and temperature, safety device, etc.

✓ **Description of the HVAC system**

↳ Ventilation rate, location of the air inlet and outlet, etc.

## Failure scenarios (during access)

### Scenario 2

Helium leakage in the insulation vacuum of the Cryogenic Distribution System




Loss of the content of the CDS (266 kg)



Discharge of GHe through the pressure relief device on the insulation vacuum jacket




Max. mass flow rate = 32 kg/s (currently under discussion)




# ODH case-study

## Accelerator tunnel

### Smoke extraction VS normal ventilation system



OR






# ODH case-study

## Accelerator tunnel

### Case 1: full length – normal ventilation



ACKNOWLEDGEMENT : N.GAZIS (ESS)


During release:

$$C(t) = 0.21 e^{-\frac{R}{V}t}$$

After release:

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$


#### Oxygen concentration over time evolution (min)



# ODH case-study

## Accelerator tunnel

### Case 2: section between 2 exits – normal ventilation



ACKNOWLEDGEMENT : N.GAZIS (ESS)


During release:

$$C(t) = 0.21 e^{-\frac{R}{V}t}$$

After release:

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$


#### Oxygen concentration over time evolution (min)



# ODH case-study

## Accelerator tunnel

### Case 3: section between 2 exits – 1 smoke extractor\*



Volume available: 992 m<sup>3</sup>  
Ventilation rate: 18 000 m<sup>3</sup>/h (1,4 ACH)

ACKNOWLEDGEMENT : N.GAZIS (ESS)


During release:

$$C(t) = 0.21 e^{-\frac{R}{V}t}$$

After release:

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$

#### Oxygen concentration over time evolution (min)




\*considering a quasi-immediate trigger of the smoke extraction

# ODH case-study

## Accelerator tunnel

### Case 4: section between 2 exits – 2 smoke extractors\*



ACKNOWLEDGEMENT : N.GAZIS (ESS)


During release:

$$C(t) = 0.21 e^{-\frac{R}{V}t}$$

After release:

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$

#### Oxygen concentration over time evolution (min)



— Oxygen concentration


..... ODH threshold

\*considering a quasi-immediate trigger of the smoke extraction

# ODH case-study

## Accelerator tunnel

### Case 5: section between 2 exits – 1 smoke extractor\*



Volume available: 992 m<sup>3</sup>  
Ventilation rate: 18 000 m<sup>3</sup>/h (1,4 ACH)

ACKNOWLEDGEMENT : N.GAZIS (ESS)


During release:

$$C(t) = 0.21 e^{-\frac{R}{V}t}$$

After release:

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$

#### Oxygen concentration over time evolution (min)



— Oxygen concentration


..... ODH threshold

\*considering a trigger of the smoke extraction after 30 s

# ODH case-study

## Accelerator tunnel

### Case 6: section between 2 exits – 2 smoke extractors\*



ACKNOWLEDGEMENT : N.GAZIS (ESS)


During release:

$$C(t) = 0.21 e^{-\frac{R}{V}t}$$

After release:

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$

### Oxygen concentration over time evolution (min)



\*considering a trigger of the smoke extraction after 30 s

# ODH case-study

## Accelerator tunnel

### Summary table

Case	Length of the tunnel	Ventilation system	Trigger time	Time needed to reach 18% O <sub>2</sub>
1	600 m	Normal	N/A	Always above 18%
2	135 m	Normal	N/A	31,2 s
3	135 m	1 smoke extractor	immediate	22,3 s
4	135 m	2 smoke extractors	immediate	11,5 s
5	135 m	1 smoke extractor	After 30 s	50,5 s
6	135 m	2 smoke extractors	After 30 s	40,9 s

NOT REALISTIC

# ODH Safety process

## Preliminary ODH assessment

### Method n°1 (CERN approach)

**Objective:** assess in a simple way consequences of the full loss of an asphyxiant fluid in a given volume without considering any ventilation and time parameter

Room parameters

Fluid parameters

O2 concentration  
(perfect mixture)

+

Height of the gas layer  
(stratification)

ODH Level

(O2 ≥ 18% OR O2 < 18%)

EUROPEAN SPALLATION SOURCE		CERN	
<b>Oxygen Deficiency Hazard (ODH) Assessment Form</b>			
Room specifications		Safety Awareness	
Volume: 450,00 m <sup>3</sup> Height: 2,50 m Surface: 4275,00 m <sup>2</sup> Specific mass of room conditions: 1,20 kg/m <sup>3</sup>	Free volume: 80% % Temperature: 18,00 °C Pressure: 1,00 bar	Definitions   Hierarchy of controls   Bow-Tie	
		<b>ODH Levels</b> O2 ≥ 18% The installation is safe. O2 < 18% The installation is not safe, compensatory measures are highly recommended and the HSE Unit shall be contacted.	
<b>Fluid Discharge</b>			
Fluid 1		Fluid 2	
Name: Helium   Symbol: He Release characteristics: Accumulates under the ceiling when cold and when at room temperature Pressure: 20,00 bar Fluid temperature: 300,00 K Volume used: 54,00 m <sup>3</sup>		Name:   Symbol: - Release characteristics: - Pressure: bar Fluid temperature: K Volume used: m <sup>3</sup>	
Specific mass: 3,97 kg/m <sup>3</sup> Mass: 253,81 kg Specific mass at room conditions: 0,17 kg/m <sup>3</sup>		Specific mass: - kg/m <sup>3</sup> Mass: - kg Specific mass at room conditions: - kg/m <sup>3</sup>	
Perfect mixture of gas with the atmosphere Volume of gas discharged: 1534,99 m <sup>3</sup> O2 in the air after discharge: 11,57% % Height of the enriched gas layer: 3,41 m		Perfect mixture of gas with the atmosphere Volume of gas discharged: m <sup>3</sup> O2 in the air after discharge: % Height of the enriched gas layer: m	
Remark: The way released fluids mix with air is not always easy to predict as it might be influenced by the ventilation and how fluids are released (flow, speed, direction, etc.). Sometimes further tests or numerical simulations are required to better understand this phenomena.		Remark: The way the released fluid mixes with air is not always easy to predict as it might be influenced by the ventilation and how the fluid is released (flow, speed, direction, etc.). Sometimes further tests or numerical simulations are required to better understand this phenomena.	
<b>Total volume of gas discharged</b> : 1534,99 m <sup>3</sup> <b>O2 in the air after discharge</b> : 11,57% %		Prepared by: _____ Date: ____/____/____ Verified by: _____ Date: ____/____/____ Approved by: _____ Date: ____/____/____ Location: _____	
<b>ODH Level</b> : <b>The installation is not safe, compensatory measures are highly recommended and the HSE Unit shall be contacted.</b>			




# ODH Safety process

## Preliminary ODH assessment

### Method n°2 (Fermilab approach)

**Objective:** assess in a simple way the consequences of a leak of an asphyxiant fluid in a given volume considering the ventilation rate and the time evolution



**Room specifications**

Surface: 180.00 m<sup>2</sup> Free volume: 100% m<sup>3</sup>  
 Height: 10.00 m Extraction rate: 800 m<sup>3</sup>  
 Volume: 1000.00 m<sup>3</sup>

**ODH Levels**

O<sub>2</sub> ≥ 18% The installation is safe.  
 O<sub>2</sub> < 18% The installation is not safe, compensatory measures are highly recommended and the HSE Unit shall be contacted.

**Fluid Discharge**

Name: Helium Symbol: He  
 Release characteristics: Accumulates under the ceiling when cold and when at room temperature  
 Failure scenario: Rupture of pipe  
 Leak rate: 600 m<sup>3</sup>/h  
 Failure rate: 1.00E-04 events/hour (cf. failure rates table)

**Perfect mixture of gas with the atmosphere**

O<sub>2</sub> in the air at equilibrium: 5,89%

**FERMILAB Fatality Factor (Fatal./event): 1,00000E+00**

**ODH RATE (Fatal./hour): 1,00000E-04**

**ODH CLASS: ODH CLASS 2**

**Fluid Discharge Evolution of the Oxygen concentration during the fluid discharge**

t (min)	Oxygen concentration
0	21,00%
1	20,79%
2	20,59%
5	19,98%
10	19,03%
20	17,81%
30	15,81%
60	12,33%
120	8,43%
240	5,89%

**Equation:** 
$$C(t) = 0.21 \left( 1 - \frac{R}{Q} \left( 1 - e^{-\frac{Q}{V}t} \right) \right)$$

**Graph:** Oxygen concentration over time evolution (min)

**Time needed to stop the leak:** 20000.00 s  
**Corresponding O<sub>2</sub> concentration:** 5,43%

**Time needed to go down to 18% O<sub>2</sub>:** 12 min

Room parameters

Fluid + scenario characteristics

ODH parameters:  
 Fatality rate  
 Probability of fatality  
 ODH class

O<sub>2</sub> evolution during fluid discharge

$$C(t) = 0.21 \left( 1 - \frac{R}{Q} \left( 1 - e^{-\frac{Q}{V}t} \right) \right)$$

# ODH Safety process

## Preliminary ODH assessment

### Method n°2 (Fermilab approach)

**Objective:** assess in a simple way the consequences of a leak of an asphyxiant fluid in a given volume considering the ventilation rate and the time evolution


Contact persons

Contact persons	
ODH detection system - support and advice on ODH compensatory measures.	E-mail
Stuart Birch	ESS (ICS) <a href="mailto:stuart.birch@esss.se">stuart.birch@esss.se</a>
Calculation tool for Safety Protection Devices - design of SPD for the inner vessel of a cryogenic vessel.	E-mail
Andre Henriques	CERN (DGS/SEE) <a href="mailto:andre.henriques@cern.ch">andre.henriques@cern.ch</a>
ODH calculation tool - preliminary assessment of potential Oxygen Deficiency Atmosphere	E-mail
Duy Phan	ESS (AD) <a href="mailto:duy.phan@esss.se">duy.phan@esss.se</a>
Christine Darve	ESS (AD) <a href="mailto:christine.darve@esss.se">christine.darve@esss.se</a>

Evolution of the Oxygen concentration after the end of the release

t (min) after end of release	Oxygen concentration
0	5,43%
1	5,64%
2	5,84%
5	6,44%
10	7,38%
20	9,08%
30	10,57%
60	14,01%
120	17,86%
240	20,37%

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$



Time needed to go up to 18% O2: **123,48 min** after end of release

Part 2/2

O2 evolution after fluid discharge

$$C(t) = 0.21 - [0.21 - C_r(t_e)] e^{-\frac{Q}{V}(t-t_e)}$$

# ODH control measures

## Which ones are relevant?

*“If this approach is taken, the ventilation system must now be treated as a safety system with appropriate controls and redundancies” – John Weisend, January 2015*

**Simplification**  
of the approach to meet  
ESS needs...

**To be discussed**

**OK**


ODH Hazard Class	0	1	2
<b>Environment controls</b>			
Warning signs		X	X
Ventilation → PSS? IEC 61508?		X	X
Area (fixed) Oxygen Monitoring		X	X
<b>ODH-Qualified Personnel Controls</b>			
Medical approval as ODH qualified		X	X
ODH training ES&H?		X	X
Personnel oxygen monitor		X	X
Self-rescue mask Applicable?		X	X
Multiple personnel in communication			X
<b>ODH-Restricted Personnel Controls</b>			
Must not be ODH-excluded		X	X
ODH briefing or training		X	X
Personnel oxygen monitor		X	X
Self-rescue mask		X	X
One-to-one escort by ODH qualified personnel		X	X
At least 2 ODH qualified personnel			X

# ODH control measures

## Other possible solutions...

### Solution 1

ODH Hazard Class	0	1	2
<b>Environment controls</b>			
Warning signs		X	X
Ventilation		X	X
Area (fixed) Oxygen Monitoring		X	X
<b>ODH-Qualified Personnel Controls</b>			
Medical approval as ODH qualified		X	X
ODH training		X	X
Personnel oxygen monitor		X	X
Self-rescue mask		X	X
Multiple personnel in communication			X
<b>ODH-Restricted Personnel Controls</b>			
Must not be ODH-excluded		X	X
ODH briefing or training		X	X
Personnel oxygen monitor		X	X
Self-rescue mask		X	X
One-to-one escort by ODH qualified personnel		X	X
At least 2 ODH qualified personnel			X



### Solution 2

ODH Hazard Class	0	1	2
<b>Technical Safety measures</b>			
Warning signs	X	X	X
Ventilation		*	*
Area (fixed) Oxygen Monitoring	*	X	X
<b>Organizational Safety measures</b>			
Medical approval as ODH qualified		X	X
ODH training (e-learning)	X	X	X
Personnel oxygen monitor		X	X
Self-rescue mask		*	*
Presence of minimum 2 persons			X
<b>Administrative Safety measures</b>			
Access restricted to authorized personnel only		X	X
Emergency procedure		X	X
Working procedure	X	X	X

\* to be evaluated case by case

# Practical cases

## Accelerator tunnel – Method n°1



**Scenario:** Helium discharge from the safety relief device of the insulating vacuum vessel from 1 High- $\beta$  Cryomodule


**Cause:** leak from junctions/welds from the cavities

**Volume of LHe:** 1 x 4 x 0.048 m<sup>3</sup>

**Temperature of LHe:** 2K

**Pressure:** 1,9 bara

**Tunnel:** 12 600 m<sup>3</sup> x 35% (full volume)




**Volume of gas discharged:** 174 m<sup>3</sup>

**O<sub>2</sub> concentration after discharge** (homogeneous mixture): 20,17%

**Height of gas layer** (stratification): 0,05 m

**ODH level:** "SAFE"



# Practical cases

## Accelerator tunnel – Method n°1



**Scenario:** Helium discharge from the safety relief device of the insulating vacuum vessel from 1 High- $\beta$  Cryomodule


**Cause:** leak from junctions/welds from the cavities

**Volume of LHe:** 1 x 4 x 0.048 m<sup>3</sup>

**Temperature of LHe:** 2K

**Pressure:** 1,9 bara

**Tunnel:** 4200 m<sup>3</sup> x 35% (1/3 of the total volume)




**Volume of gas discharged:** 174 m<sup>3</sup>

**O<sub>2</sub> concentration after discharge** (homogeneous mixture): 18,52%

**Height of gas layer** (stratification): 0,14 m

**ODH level:** "SAFE"



# Practical cases

## Accelerator tunnel – Method n°2

**Scenario:** Helium discharge from the safety relief device of the insulating vacuum vessel from 1 High- $\beta$  Cryomodule


**Cause:** leak from junctions/welds

**Leak rate:** 475 200 m<sup>3</sup>/h (ref. [WPS\\_SafetySizing\\_nt-safety-devices-2015-01-14.docx](#))



**Duration of the leak:** infinite (not realistic)

**Ventilation rate:** 1 vol/h (12600 m<sup>3</sup>/h)

**Tunnel:** 12 600 m<sup>3</sup> x 35% (full volume)



Oxygen concentration over time evolution (min)



ACKNOWLEDGEMENT : J.FYDRYCH (ESS)

# Practical cases

## Accelerator tunnel – Method n°2

**Scenario:** Helium discharge from the safety relief device of the insulating vacuum vessel from 1 High- $\beta$  Cryomodule

**Cause:** leak from junctions/welds

**Leak rate:** 475 200 m<sup>3</sup>/h (ref. [WP5\\_SafetySizing\\_nt-safety-devices-2015-01-14.docx](#))



**Duration of the leak:** infinite (not realistic)

**Ventilation rate:** 1 vol/h (12600 m<sup>3</sup>/h)

**Tunnel:** 4200 m<sup>3</sup> x 35% (1/3 of the tunnel)



**Worst case scenario but maybe not realistic**






# Practical cases

## Compressor bldg. – Method n°2



### Alternative approach

Thanks to Philipp Arnold !!!



No constant max flow rate → average flow rate  
 95 202 m<sup>3</sup>/h → 26 270 m<sup>3</sup>/h

### Oxygen Deficiency Hazard (ODH) Assessment Form

**Room specifications**

Surface: 450,00 m<sup>2</sup>  
 Height: 9,50 m  
 Volume: 4275,00 m<sup>3</sup>

Free volume: 80%  
 Ventilation rate: 4275 m<sup>3</sup>/h

**Fluid characteristics**

Name: Helium  
 Symbol: He

Release characteristics: Accumulates under the ceiling when cold and when at room temperature

Failure scenario: Rupture of DN 50 pipe

Leak rate: 26379 m<sup>3</sup>/h

Failure rate: 1,00E-05 events/hour (cf. failure rates table)

**ODH Levels**

ODH CLASS 0 The installation is safe.

ODH CLASS 1 The installation is not safe, compensatory measures are highly recommended and the HSE Unit shall be contacted.

ODH CLASS 2 The installation is not safe. Forbidden area

### Fluid Discharge

Evolution of the Oxygen concentration during the fluid discharge

t (min)	Oxygen concentration
0	21,00%
1	18,33%
2	15,71%
3	13,15%
4	13,78%
5	13,93%
10	14,63%
20	15,82%
60	18,75%
120	20,95%

$$C(t) = 0,21 \left( 1 - \frac{R}{Q} \left( 1 - e^{-\frac{Q}{V}t} \right) \right)$$

$$C(t) = 0,21 - [0,21 - C(t)] e^{-\frac{Q}{V}t}$$

Time needed to stop the leak: 180,00 s

Corresponding O2 concentration: 13,15%

Time needed to go down to 18% O2: 1,12 min

Time needed to go up to 18% O2 after end of release: 46,18 min

Perfect mixture of gas with the atmosphere

O2 in the air at 240 min: 20,95%


FERMILAB Fatality Factor (Fatality/event): 0,00000E+00

ODH RATE (Fatality/hour): 0,00000E+00

ODH CLASS: **ODH CLASS 0**

Reference: FERM 4249 - Oxygen Deficiency Hazard (ODH)


empty the



# ODH case-study

## Where to find the ODH tools and results?

## Safety Wiki



The screenshot shows a wiki page titled "ODH Assessment Accelerator Tunnel" under the "Cryogenic Safety" category. The left sidebar contains a "PAGE TREE" with "Safety" and "Cryogenic Safety" expanded. The main content area includes a table for "Properties of the room/building", a "Scenario 1A" description, a table for "Properties of the fluid", a diagram, and another "Scenario 1B" description with a corresponding "Properties of the fluid" table. A red circle highlights the "ODH Assessment Accelerator Tunnel" link in the sidebar.

Accelerator Safety & Radioprotection

SPACE SHORTCUTS

Here you can add shortcut links to the most important content for your team or project. [Configure sidebar](#).

PAGE TREE


- Radioprotection
- Safety
  - Cryogenic Safety
    - Example of layout for requirements regarding cryogenic safety
    - **ODH Assessment Accelerator Tunnel**
    - ODH Assessment Cold Box Hall
    - ODH Assessment Compressor Station Building
    - ODH Assessment Cryogenic Transfer Line (CTL) gallery
    - ODH Assessment Test Stand 2 in Klystron Gallery
  - Fire Safety
  - Weekly reporting on Safety issues

<https://ess-ics.atlassian.net/wiki/display/ASR/Cryogenic+Safety>

# Practical cases

Where to find the ODH tools and results?

## ESSShare



**ODH Tutorial** ready...


# CERN LHC spill test

## Lessons learnt (from a Safety point of view)

1. The drop of O<sub>2</sub> content cannot be related to the visible formation of mist in the flow

2. **Exclusions zones** have been increased

	CERN LHC	ESS
Distance between rupture disks	200 m	?
Exclusion zones	Yes	Not applicable?



3. **No personnel access to the tunnel** while sectors are cooled down or warmed up or powering tests are performed of He cooled magnets


4. Access conditions for personnel redefined such that **no exposure to a MCI larger than 0,1 kg/s**

5. At kneeling height (0,5 m) **O<sub>2</sub> can drop to 11%**

6. **No safe zone available** to put on the self-rescue mask

# Open question

Is there any need for a CFD simulation at ESS...in particular in the tunnel?




# Open question

 Which Most Credible Incident (MCI) should be chosen?

**During Access  
to the tunnel**



Scenario?  
Mass Flow?



**No Access  
to the tunnel**



Beam loss?

