



CCLRC

Rutherford Appleton Laboratory


T2K Hadron Absorber (Beam Dump) simulations

Neutrino Beam and Instrumentation Workshop
August 2006

Chris Densham
Rutherford Appleton Laboratory

Hadron Absorber Challenges

- ~1 MW heat load
- No maintenance after activation
- Cooling external to core to limit water activation
- Graphite temperature should not exceed 600°C to minimise oxidation in Decay Volume
- Low tensile strength of affordable graphite blocks:
 - ~5 MPa // extrusion direction
 - ~7-8 MPa _|_ to extrusion direction



Graphite Blocks
+ cooling module
layout

1

ANSYS

JUN 20 2006
16:12:28
PLOT NO. 1

NODAL SOLUTION
STEP=1
SUB =1
TIME=1
TEMP (AVG)
RSYS=0
SMN =37.353
SMX =829.778

Thermal Model for 4
MW proton beam at 30
GeV



Realistic thermal (He)
links between blocks


Maximum temperature
829°C (too hot)

0.1 mm He gap (x)


1 mm He gap (y)

2 mm He gap (z)






Displacements (m)



Maximum thermal expansion = **8.5 mm**



Stresses in full width graphite blocks

Max. stress = 4.6 MPa

≈ Tensile strength

Hence propose to split blocks along centreline

Chosen graphite layout: horizontal cooling modules


1
ELEMENTS
MAT NUM
U
CP
ACEL

1 layer graphite blocks, 75 deg. angled cut at centre


Full length 200 mm thick cooling module

Connections to graphite block


Stainless steel water pipes cast into cooling module



1 NODAL SOLUTION
STEP=1
SUB =1
TIME=1
TEMP (AVG)
RSYS=0
SMN =37.911
SMX =135.184



ANSYS
JUN 29 2006
18:14:36
PLOT NO. 1




Cooling module temperatures

Maximum temperature = 135 C

w102c,30GeV:4pt.cons,3kW/m2K@SUS pipe;He gap x:0.1mm,y:1mm,z:2mm;2m Grph

3,000 W/m2/K
Water cooling

Cross-section through cooling module at shower maximum



1




Temperatures at cross section through shower max

(4 MW beam power)


JUN 29 2006
18:39:17
PLOT NO. 1

NODAL SOLUTION

STEP=1
SUB =1
TIME=1
TEMP (AVG)
RSYS=0
SMN =196.595
SMX =922.649




Von Mises equivalent stresses in cooling modules (Al only)
Maximum stress = 67 MPa - OK




Cross-section through cooling module at shower maximum

Structural model results:

Calculated gap between graphite block layers resulting from thermal expansion + structural loads



1
NODAL SOLUTION
STEP=2
SUB =6
TIME=20
SEQV (AVG)
DMX =.007545
SMN =128114
SMX =.754E+07
NFOR



Connection forces to cooling module ->
4 connection points
F max (x) = 5.7 Tonnes
Max. stress in graphite
= 7.5 MPa
NB 1: 4MW beam
NB2: thermal expansion permitted in plane between Al and Graphite

```

1
NODAL SOLUTION
STEP=2
SUB =7
TIME=20
SEQV      (AVG)
DMX  =.004741
SMN  =78651
CMX  =.265E+07
  
```

ANSYS
AUG 11 2006
10:41:04
PLOT NO. 1

Connection forces to cooling module →



Single connection point

F max (x) = 2 Tonnes

Max. stress in graphite

= 2.65 MPa (OK)

(NB 3 MW beam power)



w102c, 30GeV, 3MW:1pt.cons, 3kW/m2K@SUS pipe;He gap x:0.1mm, y:1mm, z:2mm; 2m

Downstream of graphite: Copper?

CJD 2006/03/23	#Run	1	2	3	4	5	6	7
Beam parameter case		w108b	w108	w108b	w108	w108b	w108	w108b
Decay Volume length	m	94	94	94	94	94	94	94
Beam energy	GeV	30	40	30	40	30	40	30
Divergence	mrad							
Beam power	MW	4		4		4		4
Beam centre posn.		centre		centre		centre		centre
Graphite thickness	m	3.15		3.15		3.15		3.15
Number of Cu blocks in (z)		5		5		5		5
Copper block length (z)	m	0.18		0.18		0.18		0.18
Number of Cu blocks high (y)		1		2		2		1
Copper block height (y)	m	4.75		2.375		2.375		4.75
Number of Cu blocks across width (x)		2		2		2		2
Copper block width (x)	m	0.95		0.95		0.95		0.95
Copper block centre cut angle	deg	45		45		45		45
Assumed vertical He gap(y) between Cu blocks	mm*	0		0		0		0
Assumed He gap(z), between blocks in Z	mm*	10		10		10		10
Cooling water temperature	C	35		35		35		35
Convection at cooling surface (= x-width)	W/m ² K	600		600		600		1200
Friction coefficient between blocks	mu	0.1		0.1		0.1		0.1
Main support location		Base		Base		Sides		Base
Results: Copper								
Max Temp	C	215	279		288	222		288
<i>Temperature Difference i-(i0)</i>	C	-	64		73	7		73
Max. Temp on cooled surface at sides	C	120	142		148	124		148
Max Von Mises stress at block centreline	MPa	95.7	140		40	?		39.7
Centreline max. displacement Ux	mm	1.2	1.5		1.9	3.2*		4
Centreline min. displacement Ux	mm	-8.9	-11.4		-12.7	1.0*		1.3
Calc. Max. Vert. Gap btw blocks(dUy)	mm	0	0			1.86*		2.28
Max. Uy Cu at top	mm	10.6	12.5		13.4	10.5*		12.4
Max. Uz	mm	1.5			1.9			0.5

Downstream of graphite: Copper?

CJD 2006/03/23	#Run	1	2	3	4	5	6	7
Beam parameter case		w108b	w108	w108b	w108	w108b	w108	w108b
Decay Volume length	m	94	94	94	94	94	94	94
Beam energy	GeV	30	40	30	40	30	40	30
Divergence	mrاد							
Beam power	MW	4		4		4		4
Beam centre posn.		centre		centre		centre		centre
Graphite thickness	m	3.15		3.15		3.15		3.15
Number of Cu blocks in (z)		5		5		5		5
Copper block length (z)	m	0.18		0.18		0.18		0.18
Number of Cu blocks high (y)		1		2		2		1
Copper block height (y)	m	4.75		2.375		2.375		4.75
Number of Cu blocks across width (x)		2		2		2		2
Copper block width (x)	m	0.95		0.95		0.95		0.95
Copper block centre cut angle	deg	45		45		45		45
Assumed vertical He gap(y) between Cu blocks	mm*	0		0		0		0
Assumed He gap(z), between blocks in Z	mm*	10		10		10		10
Cooling water temperature	C	35		35		35		35
Convection at cooling surface (= x-width)	W/m ² K	600		600		600		1200
Friction coefficient between blocks	mu	0.1		0.1		0.1		0.1
Main support location		Base		Base		Sides		Base
Results: Copper								
Max Temp	C	215	279		288	222		288
<i>Temperature Difference (C)</i>	C	-	64		73	7		73
Max. Temp on cooled surface at sides	C	120	142		148	124		148
Max Von Mises stress at block centreline	MPa	95.7	140		110	?		39.7
Centreline max. displacement Ux	mm	1.2	1.5		1.9	3.2*		4
Centreline min. displacement Ux	mm	-8.9	-11.4		-12.7	1.0*		1.3
Calc. Max. Vert. Gap btw blocks(dUy)	mm	0	0			1.86*		2.28
Max. Uy Cu at top	mm	10.6	12.5		13.4	10.5*		12.4
Max. Uz	mm	1.5			1.9			0.5

China has bought all the copper!

Quick look at copper free dump:
Iron blocks directly downstream of graphite

- 5 x 200 mm Fe plates = 1 m Fe
- Front + back surface of each Fe block cooled by 300 W/m²K
- Power input to Fe scaled from Cu data by density (Ishida-san)


JUL 5 2006
17:54:31
PLOT NO. 1

1

NODAL SOLUTION

STEP=1
SUB =1
TIME=1
/EXPANDED
TEMP (AVG)
RSYS=0
SMN =35.003
SMX =214.905



Front & back
surfaces water
cooled
(300 W/m²K
assumed on both
surfaces



35.003
54.992
74.981
94.97
114.959
134.948
154.938
174.927
194.916
214.905

w108/Fe/DV94m 40GeV Full width Fe100cm/10mm He(z) 300W/m²K@Z faces (+6W/m



1
NODAL SOLUTION
STEP=1
SUB =1
TIME=1
TEMP (AVG)
RSYS=0
SMN =35.003
SMX =214.905



**Maximum
temperature in iron
= 215 C**

1
NODAL SOLUTION
STEP=2
SUB =6
TIME=20
SEQV (AVG)
DMX =.002963
SMN =10083
SMX =.217E+09


**Maximum stress in
iron = 217 MPa**



JUN 14 2006
15:32:32
PLOT NO. 1

1
NODAL SOLUTION
STEP=2
SUB =6
TIME=20
SEQV (AVG)
DMX =.00499
SMN =1422
SMX =.191E+09

**Attempt to reduce
stresses by splitting
iron along $x = 0$ plane:
Maximum stress = 191
MPa
(small reduction in
stress – not worth it)**



Conclusions

- Graphite temperatures acceptable for up to 3 MW beam operation
 - Single point connection for each graphite block to cooling module is preferable to multi-point connections
 - Splitting graphite blocks along centreline reduces stresses to acceptable level
 - Downstream copper core planned to be replaced with iron and plate coil water cooling. More work needed to reduce stresses
-