



CERN, 3 December 2015  
Engineering Design Review



Istituto Nazionale  
di Fisica Nucleare  
Sezione di Milano

## LHCb CO<sub>2</sub> cooling EDR

**UT evaporator concept and  
performance**

**Review of the suggested evaporator  
and manifold designs and results of  
performance measurements**

**Simone Coelli  
I.N.F.N. MILANO  
For the Milano UT Group**


## SUMMARY

- UT DETECTOR THERMAL MANAGEMENT
- F.E.A. THERMAL ANALYSIS
- CO<sub>2</sub> DISTRIBUTION DESIGN PROPOSAL
- CO<sub>2</sub> COOLING TEST
- WORK IN PROGRESS


# UT DETECTOR THERMAL MANAGEMENT

## COOLING SYSTEM DESCRIPTION



### SCHEMATIC DETECTOR GEOMETRY



- THE DETECTOR CAN BE SPLIT IN TWO HALVES
- Each one is made of 4 “half planes”
- Each “half plane” is made of 8 or 9 parallel staves (8+8-9+9)
- Each “half plane” has its inlet and its outlet coolant connection




### STAVE INTERNAL STRUCTURE



This picture is 1/2 of the central stave “C” type, mounted near the beam pipe

1 of the 8 “Half-planes” showing the cooling pipes integrated into the staves

The pipe routing is designed to remove the heat where it is produced, passing underneath the read-out ASICs power sources and cooling the sensors



# STAVE COOLING PIPE

There are 2 cooling pipe geometries:

Number: 60 staves

A,B type

Pipe Length 2,82 m


Heated length =  $14 * \sim 85 \text{ mm} = 1,19 \text{ m}$

Number: 8 central staves

C type, it is required to have 2 more passages under 2 ASICs rows

Pipe Length 3 m

Heated length =  $16 * \sim 85 \text{ mm} = 1,36 \text{ m}$




Titanium C.P. 2 from HIGH-TECH U.K. Company

I.D. 2,025 mm

O.D. 2,275 mm

cooling snake pipe produced starting from a 3 .1 m long straight pipe annealed ¼ hard.


Bending radius  $R= 10 \text{ mm}$




Optimal pipe material as for:


- big radiation length
- low thermal expansion coefficient
- Big strength
- Good thermal conductivity
- Thin pipe availability

Bended pipes fit very well in the geometry mask after the bending




# DETECTOR PLANE POWER DISTRIBUTION



 = 4 ASICs

Nominal power  
0,768 WATT/ASIC

 = 8 ASICs

+ power dissipation in the cables (+10%)

Sensors self-heating is calculated to be almost negligible

## PARALLEL EVAPORATING CHANNELS

Differences:


- GEOMETRY

The "C" central stave

- 4 more 90° bends
- bit longer (+ 6 % length)

- THERMAL LOADS

The "C" central stave has 76 W nominal power, the other staves have less power, down to 50 W in the external ones (3:2 ratio between max/min powering)



# MASS AND ENERGY BALANCE

mass conservation law

$\Gamma$  = mass flow rate (g/s)

energy conservation law

H = enthalpy (J/kg)


**$\Gamma_{in} = \Gamma_{out}$**

**$Q = \Gamma * (h_{out} - h_{in})$**

(W = g/s \* J/g)

Mass flow rate

$\Rightarrow \Gamma = Q / (h_{out} - h_{in})$



- INLET CO2 LIQUID SUBCOOLED NEAR TO SATURATION  $h_{in} = \sim h_{liq}$
- $X \sim 0$

- OUTLET VAPOUR FRACTION X
- $H_{lv}$  := enthalpy difference liquid to vapour (depending slightly on the evaporation pressure: 280-300 kJ/kg in the range of interest)

- $X$  := outlet vapour fraction
  - $h_{out} = h_l + X * h_{lv}$
- $\Rightarrow (h_{out} - h_{in}) = X * h_{lv}$

- Mass flow rate
- $\Rightarrow \Gamma = Q / X * h_{lv}$

design mass flow-rate needed to extract given power Q, using evaporating fluid the from saturated liquid to a exhaust mixture with a given X fraction of the vapor phase

# STAVE ENERGY BALANCE


## DESIGN REQUIREMENTS FOR THE COOLING SYSTEM:

- INLET CO<sub>2</sub> LIQUID SUBCOOLED, NEAR TO SATURATION
- OUTLET VAPOUR FRACTION X OUT NOMINAL DESIGN 0.3, (0.5 MAX)

TO AVOID DRY-OUT WITH SOME MARGIN

TO LET IN THE EXHAUST A FRACTION OF LIQUID CO<sub>2</sub> TO CONDITION THE CO<sub>2</sub> SUPPLY EVAPORATING IN THE ESTERNAL JACKET OF THE COAXIAL CONNECTION PIPE

H<sub>lv</sub> = hentalpy difference liquid to vapour = 280 kJ/kg  
At evaporation temperature of -25 °C



## CALCULATION OF THE MASS FLOW-RATE

$$\Gamma \text{ CO}_2 = Q / X * h_{lv}$$
$$= \text{POWER} / X * \text{DELTA } H_{\text{LIQ-VAP}}$$

### CENTRAL "C" STAVE

IF X OUT = 50 %  
 $\Gamma = 75 \text{ W} / 0,5 * 280 \text{ kJ/kg} = \sim 0.5 \text{ g/s}$



IF X OUT = 30 %  
 $\Gamma = 75 \text{ W} / 0,3 * 280 \text{ kJ/kg} = \sim 0.9 \text{ g/s}$

### LATERAL "A" STAVE

IF X OUT = 50 %  
 $\Gamma = 50 \text{ W} / 0,5 * 280 \text{ kJ/kg} = \sim 0.4 \text{ g/s}$

IF X OUT = 30 %  
 $\Gamma = 50 \text{ W} / 0,3 * 280 \text{ kJ/kg} = \sim 0.6 \text{ g/s}$

# HALF PLANES ENERGY BALANCE



Half planes UTbV, UTbX  
with 9 staves

$Q = \sim 512 \text{ W}$   
 $X_{\text{outlet}} = 30 \%$   
 $H_{\text{lv}} = 280 \text{ kJ/kg}$

Coolant Mass flow rate  
 $\Gamma = Q / X * h_{\text{lv}}$   
 $\Rightarrow \Gamma = \sim 6 \text{ g/s}$

Half planes UTaX, UTaU  
with 8 staves


$Q = \sim 460 \text{ W}$   
 $X_{\text{outlet}} = 30 \%$   
 $H_{\text{lv}} = 280 \text{ kJ/kg}$

Coolant Mass flow rate  
 $\Gamma = Q / X * h_{\text{lv}}$   
 $\Rightarrow \Gamma = \sim 5,5 \text{ g/s}$



# UT DETECTOR GLOBAL ENERGY BALANCE

Estimate including a 20% margin  
used in the cooling requirements document  
to account for ambient heat pick-up




$\Gamma \text{CO}_2$

$Q = \sim 2500 \text{ W}$   
 $X \text{ outlet} = \sim 30 \%$   
 $H_{lv} = \sim 280 \text{ kJ/kg}$   
Coolant Mass flow rate  
 $\Gamma = Q / X * h_{lv}$   
 $\Rightarrow \Gamma \text{CO}_2 = \sim 30 \text{ g/s}$

$\Gamma \text{CO}_2$

$Q = \sim 2500 \text{ W}$   
 $X \text{ outlet} = \sim 30 \%$   
 $H_{lv} = \sim 280 \text{ kJ/kg}$   
Coolant Mass flow rate  
 $\Gamma = Q / X * h_{lv}$   
 $\Rightarrow \Gamma \text{CO}_2 = \sim 30 \text{ g/s}$

# DETECTOR F.E.A. ANALYSIS



UT STAVE TYPE C WITH SHORT HYBRID AND CERAMIC STIFFENER V.5


Model from Ray Mountain (Siracuse Un.)

Design version v.5

- SHORT HYBRID
- L-shaped CERAMIC STIFFENER + removable glue


MATERIALS UNDER STUDY:

- PBN (Pyrolytic Boron Nitride)  $K = 60/60/2$ ; thickness = 0.500 mm
- AlN (Aluminum Nitride)  $K = 180/180/180$ ; thickness = 0.250 mm



ANSYS model

Note copper thermal vias under the ASICs passing through the hybrid (Kapton) in a design hypothesis

 Document: EDMS 517621 v.1	LHCb UT DETECTOR UPGRADE EDR June 2015	
	Created: 2015.06.09 Modified:	Page: 1 of 25 Rev. No.: 1

## LHCb UT DETECTOR UPGRADE

### SUMMARY OF THE THERMAL AND MECHANICAL FINITE ELEMENT ANALYSIS (F.E.A.) FOR THE DESIGN AND THE OPTIMIZATION OF THE DETECTOR STAVE

This document contains background information for the EDR in June 2015 regarding the ANSYS FEM analysis made and the work in progress for the LHCb UT detector local supports, called "staves", toward an optimized design.

Simone Coelli - I.N.F.N. MILANO  
 Mauro Monti - I.N.F.N. MILANO

=> EDMS DOCUMENT:

<https://edms.cern.ch/document/1517621/1>

# DETECTOR HEAT LOADS

## A: Steady-State Thermal

Steady-State Thermal

Time: 1, s

17/12/2014 15:45

- A** Temperature COOLING PIPE: 0, °C
- B** Internal Heat Generation SENSOR.A1T1: 2,6724e-004 W/mm<sup>3</sup>
- C** Internal Heat Generation SENSOR.A1T2: 1,4187e-004 W/mm<sup>3</sup>
- D** Internal Heat Generation SENSOR.A1T3: 5,6886e-005 W/mm<sup>3</sup>
- E** Internal Heat Generation ASICs: 0,14913 W/mm<sup>3</sup>
- F** Internal Heat Generation SHORT FLEX: 1,35e-004 W/mm<sup>3</sup>
- G** Internal Heat Generation LONG FLEX: 1,26e-004 W/mm<sup>3</sup>

## Read-out chip POWER:

+ 0.768 W / ASIC

## POWER dissipated in the FLEXBUS:

+ 10 % of the transported power  
(i.e.  $8 * 0,768 = 6,14$  W)

## SENSOR SELF HEATING:

T1 = + 0.261 W

T2 = + 0.171 W

T3 = + 0.135 W

## A: Steady-State Thermal

Steady-State Thermal




Time: 1, s

17/12/2014 15:44


- A** Temperature COOLING PIPE: 0, °C
- B** Internal Heat Generation SENSOR.A1T1: 2,6724e-004 W/mm<sup>3</sup>
- C** Internal Heat Generation SENSOR.A1T2: 1,4187e-004 W/mm<sup>3</sup>
- D** Internal Heat Generation SENSOR.A1T3: 5,6886e-005 W/mm<sup>3</sup>
- E** Internal Heat Generation ASICs: 0,14913 W/mm<sup>3</sup>
- F** Internal Heat Generation SHORT FLEX: 1,35e-004 W/mm<sup>3</sup>
- G** Internal Heat Generation LONG FLEX: 1,26e-004 W/mm<sup>3</sup>

BOUNDARY CONDITION FOR THERMAL F.E.A.  
COOLING PIPE TEMPERATURE  
external wall SET TO 0 °C  
=> CALCULATED TEMPERATURES  
ARE A DELTA T REFERRED TO THIS  
TEMPERATURE


ANSYS  
R15.0  
Academic



# F.E.A. ANALYSIS



ANSYS F.E. MODEL



STIFFENER WITH SLITS - Material PBN (Pyrolytic Boron Nitride)  
Thermal conductivity  $k = 60/60/2$  - Ceramic thickness = 0.500 mm

SENSOR A1.T1  
MAX DELTA T = 2.2 °C

SENSOR A1.T3  
MAX DELTA T = 5.1 °C


⇒ FOR BOTH CERAMIC MATERIALS (PBN/AIN):

SENSOR T1: MIN TEMP ~ + 0,2 °C, REF TO COOLING PIPE TEMP  
SENSOR T2: MIN TEMP ~ + 0,5 °C, REF TO COOLING PIPE TEMP  
BOTH SENSOR T1 AND T2: MAX TEMP ESCURSION OVER THE SILICON SENSOR  
DELTA T ~ 2- 2.2 °C

SENSOR T3: MIN TEMPERATURE ~ + 0,6-0,8 °C, REF TO COOLING PIPE TEMP  
MAX TEMPERATURE ~ + 5,8 °C, REF TO COOLING PIPE TEMP


MAXIMUM TEMPERATURE ESCURSION OVER THE SILICON SENSOR  
DELTA T ~ 5°C

# F.E.A. ANALYSIS



=> FOR BOTH CERAMIC MATERIALS (PBN/AIN):

ASICs TEMPERATURE  
IN THE RANGE + 17-21 °C, REFERRED TO COOLING PIPE TEMP



FOR BOTH CERAMIC MATERIALS (PBN/AIN):  
SENSOR T3:


MIN TEMP ~ + 0,7 °C, REF TO COOLING PIPE TEMP  
MAX TEMPERATURE ~ + 4,3-4,9 °C, REF TO COOLING PIPE TEMP

MAXIMUM TEMP ESCURSION OVER THE SILICON SENSOR  
DELTA T ~ 3,6-4,2 °C


=> CERAMIC STIFFENER WITHOUT SLITS COULD BE USED FOR  
THE 4 ASICs SENSORS

# F.E.A. ANALYSIS

## DESIGN WITH THERMAL OPTIMIZATION



- HOT SPOT on the sensor (A1.T3)
- ⇒ Driving the sensor  $\Delta T$
- ⇒ GOAL: MINIMIZE THIS EFFECT



extension of the carbon foam high conductive material (gray) under the T3 sensor

- using a snake pipe design the temperature difference across the sensor is mainly due to the hot spot (maximum) temperature in the silicon sensor, located on the side of the sensor not glued on the stave.
- The coolest points of the sensor are almost at the same temperature, few degrees above the cooling pipe temperature
- ⇒ An effective way to reduce delta T over the sensor is to reduce the local hot spots

# CALCULATED LOCAL THERMAL PERFORMANCES for the «C» central stave, sensors T1, T2, T3

## SUMMARY TABLE

STIFFENER TYPE	STIFFENER MATERIAL	SENSOR A1.T1 MAX DELTA T [°C]	SENSOR A1.T2 MAX DELTA T [°C]	SENSOR A1.T3 MAX DELTA T [°C]	ASICs MAX DELTA T OVER THE PIPE [°C]
CERAMIC STIFFENER WITH SLITS	PBN - THICKNESS 500 µm	2.2	2.1	5.1	21
	AIN- THICKNESS 250 µm	2.2	2.0	5.0	17
CERAMIC STIFFENER WITHOUT SLITS	PBN - THICKNESS 500 µm	2.8	2.7	6.7	20
	AIN- THICKNESS 250 µm	2.5	2.4	5.9	17
CERAMIC STIFFENER SEPARATED INTO TWO PARTS	PBN - THICKNESS 500 µm	2.0	1.9	3.0	23
	AIN- THICKNESS 250 µm	1.8	1.8	2.2	19

- THE TEMPERATURE DIFFERENCE ACROSS THE SENSORS IS ALWAYS ACCEPTABLE FOR THE INNERMOST SENSORS T1 AND T2 (around 2 °C)
  - THE TEMPERATURE DIFFERENCE ACROSS THE SENSOR T3 (in the central stave) ACCEPTABLE FOR BOTH THE CERAMIC MATERIALS IN THE DESIGN GEOMETRY WITH SLITS (around 5 °C)
- => Both PBN and AIN solutions provide efficient heat transfer
- ASICs TEMPERATURE ARE ALWAYS WITHIN SPECIFICATION. Operative temp. cooling pipe will be ~ -15 °C, ASICs ~ +5 °C, with a large margin against the limit of 40 °C.

# CO<sub>2</sub> DISTRIBUTION LINES AND MANIFOLDING

Sum-up of the requirements for the staves CO<sub>2</sub> coolant connection lines:

## OUTLET CONNECTIONS

- Transport the exhaust CO<sub>2</sub> coolant flow, leaving the staves, to the detector outlet
- Mixture of CO<sub>2</sub> liquid + vapour, evaporated fraction 30%, max 50%, according to the design nominal operational conditions
- Inner diameter I.D.  $\geq$  I.D. stave titanium cooling pipe = 2 mm, to **minimize pressure drop downstream of the evaporator** (that could be detrimental for thermo-hydraulic stability)
- Design with an even pressure drops on all the parallel lines, using the same geometry for all the outlet connections
- AISI 316L stainless steel
- More flexible as possible to facilitate mounting and demounting the 1/8" VCR connection stave interface
- Choice: commercially available AISI 316L, I.D.= 2.00 mm, O.D.= 2.50 mm
- "coil" design + annealing after bending to enhance the pipe flexibility
- Pipes welded to the outlet manifold, to save space
- 8 or 9 pipes non detachable on the manifold side
- Need tools space to tighten the VCR joints only on the stave side

## INLET CONNECTIONS

- Distribute the liquid CO<sub>2</sub> coolant flow, arriving from the cooling plant, to the staves inlets
- Slightly subcooled near saturation fluid
- **Supplying parallel evaporating channels, these connection lines must have a pressure drop bigger (> 5 times i.e.) than the evaporation channels pressure drop**
- **thermo-hydraulic stability could be assured using passive elements in the inlet distribution system.**
- Two options are under investigation:
  - **calibrated orifices:** concentrated inlet pressure drops, inserted before the stave inlet. The same piping connection design used on the outlet could be replicated on the inlet. Every detector half-plane has 2 manifolds on each side, 1 on top and 1 on bottom.
  - **capillaries:** distributed inlet pressure drops. Can be coiled and connection to a manifold, or used to route the lines from the staves to the detector outside. Manifold could be placed in any convenient place, inside or outside the detector cold box.



## UPSTREAM FLOW

- inlet liquid cooling supplied from the bottom to the staves, 1/8" VCR SWAGELOK FITTING
- exhaust collected from the staves, 1/8" VCR SWAGELOK FITTING, toward a manifold on the top




# OUTLET CONNECTIONS

DESIGN STUDY WITH 3 COILS TO CHECK INTERFERENCES  
NUMBER OF COILS IS UNDER INVESTIGATION: MAY BE 1, 2 OR 3



DETECTOR 3D MODEL WITH THE COOLING CONNECTION LINES





LATERAL VIEW OF TWO HALF PLANES  
THIS MODULE IS REPEATED 4 TIMES IN THE DETECTOR  
EACH HALF BOX IMPLEMENTING MODULES ALMOST  
SPECULAR, HAVING 8/9 STAVES CONNECTED

ORDER PLACED TO A COMPANY TO PRODUCE THE  
CONNECTION PIPES SAMPLES FOR QUALIFICATION, AND  
ELASTIC FORCE ON STAVE FITTING WILL BE MEASURED

# INLET CONNECTIONS




Option **with calibrated orifices**: concentrated inlet pressure drops, inserted before the stave inlet




The required stave inlet pressure drop obtained with a **compact design** component incorporated in the inlet connection line, here shown under the stave pipe inlet fitting

AISI 316L SWAGELOK FLOW RESTRICTOR  
USED IN THE TEST SET-UP  
CHARACTERIZATION TEST IN PROGRESS

Micro-TIG, or laser welded, joint




Option **with capillaries**: distributed inlet pressure drops



ORDER PLACED TO A COMPANY TO PRODUCE INLET CONNECTION SAMPLES WITH 1/16" PIPE WELDED TO 1/8" SWAGELOK FITTINGS

# CO<sub>2</sub> COOLING TEST SET-UP DESCRIPTION

The test system is using a 2 P.A.C.L. refrigeration unit TRACI V.1, and a 1:1 test stave prototype, with the real cooling pipe. Power heat load is simulated using heaters. Cooling condition applied with accurate CO<sub>2</sub> mass flow-rate, CO<sub>2</sub> temperature and pressure measured at the stave inlet and outlet. Temperatures of all the circuit are followed with temperature measurements probes attached externally to the pipe.



COOLING LINE WITH FLUID P, T TRANSMITTERS




TRACI V.1  
2 P.A.C.L.  
COOLING  
PLANT


COLD BOX

LOCAL  
BOX


DUMMY STAVE PROTOTYPE  
UNDER TEST



«C» DUMMY STAVE  
WITH 16 HEATERS



LHCb UT STAVE PROTOTYPES CHARACTERIZATION CIRCUIT WITH "C" CENTRAL SNAKE DUMMY STAVE MOUNTED



**TEMPERATURE SENSORS INSTALLED**

**TF<sub>x</sub> = FLUID TEMPERATURE Transmitter  
position x**


**MODEL:**

**RODAX**

**PT100**

**OD 4 mm; length 80 mm**

**4 wire connection**




**PIPE TEMPERATURE SENSORS INSTALLED**

**T<sub>x</sub> = TEMPERATURE position x = 1 to 20**

**MODEL: Thermocouple "T" type 2 wires**

Type Thermocouple Grade	Material		Color Code	Range (°C)	
	Positive Wire	Negative Wire		Minimum	Maximum
J	Iron	Constantan		0	750
K	Chromel	Alumel		-200	1250
<b>T</b>	Copper	Constantan		-200	350
E	Chromel	Constantan		-200	900



Power supply  
WIENER-12 channels regulation  
With MUSE software to control

- Heaters Voltage and POWER


DAQ test measurement:

- CO<sub>2</sub> Fluid pressures
- CO<sub>2</sub> Fluid temperatures
- Termocouples 'T' attached along the line


+ TRACI DAQ

- CO<sub>2</sub> mass flow-rate
- TRACI cooling plant Pressures and Temperatures





TRACI V1  
DAQ  
Data acquisition




TRACI Mass flowrate measurement  
Coriolis flowmeter

# DUMMY STAVE POWERING SCHEME

				INPUT									
				CENTRAL STAVE		25%	50%	75%	100%	125%	150%	175%	200%
HEATER NUMBER	HEATER NOMINAL POWER	ONLY CHIP Watt tot	CHIP+DISSIP Watt tot	WATT	WATT	WATT	WATT	WATT	WATT	WATT	WATT	WATT	WATT
				NOMINAL									
U 6 GROUP	5 rows * 4 ASIC	15	18	4,5	9	13,5	18	22,5	27	31,5	36		
U 0	8 ASIC	6,1	6,5	1,625	3,25	4,875	6,5	8,125	9,75	11,375	13		
U 1	8 ASIC	6,1	6,5	1,625	3,25	4,875	6,5	8,125	9,75	11,375	13		
U 2	8 ASIC	6,1	6,5	1,625	3,25	4,875	6,5	8,125	9,75	11,375	13		
U 3	8 ASIC	6,1	6,5	1,625	3,25	4,875	6,5	8,125	9,75	11,375	13		
U 4	8 ASIC	6,1	6,5	1,625	3,25	4,875	6,5	8,125	9,75	11,375	13		
U 5	8 ASIC	6,1	6,5	1,625	3,25	4,875	6,5	8,125	9,75	11,375	13		
U 7 GROUP	5 rows * 4 ASIC	15	18	4,5	9	13,5	18	22,5	27	31,5	36		
		66,6	75	18,75	37,5	56,25	75	93,75	112,5	131,25	150		
				TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER	TOTAL POWER

## DUMMY STAVE




# COOLING TEST

## THERMO-HYDRAULIC CHARACTERIZATION OF THE BOILING CHANNEL


### GENERAL EXPERIMENTAL CONDITIONS

- CO2 refrigeration UNIT: TRACI v.1
- STAVE under test: TIPE CENTRAL «C» TYPE
- dummy stave with 16 heaters mounted on aluminum plates in contact with the titanium snake pipe, using thermal paste
- FLOW DIRECTION: bottom-up, upward flow
- INSULATION: Cold box closed with 3\* 25mm Armaflex layers each side

### MASS FLOW-RATE VARIATION IN TIME DURING A TYPICAL CHARACTERIZATION MEASUREMENT





WAITING STEADY-STATE CONDITION BEFORE TO SAVE MEASURED DATA



THE CHANNEL IS NEAR ISOTHERMAL CONDITIONS AND THE TEMP. ARE CONSTANT IN TIME, WITH CONSTANT FLOW

THE TEMPERATURES MEASURED ARE AFFECTED BY INSTRUMENTAL ERROR, CALIBRATION NEED TO BE REFINED (PT100 CALIBRATED WILL BE INSTALLED)

MEASURED TEMPERATURES VS TIME IN **COLD NOMINAL OPERATIONAL CONDITIONS** WHEN EXHAUST VAPOUR FRACTION IS LESS THAN ~ 90 %






STAVE TEMPERATURES VS TIME WHEN THE MASS FLOW-RATE IS TOO LOW AND THE CHANNEL HAS A **DRY-OUT CONDITION** OSCILLATING TEMP. ARE OBSERVED AT A CERTAIN POINT IN THE STAVE (PIPE WETTED/DRYED NER DRY-OUT REGION) FROM THAT POINT CO<sub>2</sub> VAPOUR TEMPERATURE, WITHOUT LIQUID EVAPORATING, INCREASES. EXPERIMENT IS THEN STOPPED BECAUSE THIS IS NOT A DESIRED OPERATIVE SITUATION, BUT JUST A VERIFICATION.

«C» stove TEST transients  
at nominal flowrate: power from 0 to 100% and viceversa

Initial Mass flowrate  $F$  fixed = 0,9 g/s


1. OFF Power = 0
2. ON Power = 75 w
3. OFF Power = 0



when power is switched on  
Flow-rate decreases from  $\sim 0,9$  to  $\sim 0,8$  g/s


Increase in the channel pressure drop due to evaporation

Viceversa the flow come back to initial value when switched off



# Typical data taken in a steady-state cold working point

2015-10-02-16BAR-38W-05GS-P.txt




TF1	TF2	T1	T4	T5	T6	T7	T8	T9	T10	T11	T12	T13	T14	T15	T16	T17	T18	T19	T20
-26.105	-26.242	-25.810	-24.095	-24.618	-24.882	-22.428	-24.792	-25.268	-25.027	-24.174	-23.832	-25.413	-25.019	-24.021	-25.388	-24.111	-22.940	-25.692	-26.004
-26.108	-26.240	-25.826	-24.073	-24.615	-24.889	-22.442	-24.799	-25.275	-25.025	-24.170	-23.830	-25.427	-25.014	-24.023	-25.397	-24.114	-22.945	-25.707	-26.001
-26.106	-26.240	-25.826	-24.073	-24.615	-24.889	-22.442	-24.799	-25.275	-25.025	-24.170	-23.830	-25.427	-25.014	-24.023	-25.397	-24.114	-22.945	-25.707	-26.001
-26.103	-26.241	-25.818	-24.077	-24.605	-24.891	-22.448	-24.795	-25.269	-25.029	-24.180	-23.835	-25.421	-25.006	-24.019	-25.385	-24.116	-22.952	-25.713	-26.025
-26.104	-26.242	-25.818	-24.077	-24.605	-24.891	-22.448	-24.795	-25.269	-25.029	-24.180	-23.835	-25.421	-25.006	-24.019	-25.385	-24.116	-22.952	-25.713	-26.025
-26.105	-26.242	-25.808	-24.072	-24.620	-24.881	-22.438	-24.796	-25.269	-25.027	-24.177	-23.832	-25.426	-25.005	-24.013	-25.388	-24.110	-22.939	-25.711	-26.031
-26.113	-26.241	-25.808	-24.072	-24.620	-24.881	-22.438	-24.796	-25.269	-25.027	-24.177	-23.832	-25.426	-25.005	-24.013	-25.388	-24.110	-22.939	-25.711	-26.031
-26.109	-26.241	-25.822	-24.110	-24.616	-24.891	-22.442	-24.798	-25.282	-25.034	-24.174	-23.834	-25.430	-25.025	-24.027	-25.400	-24.112	-22.940	-25.703	-26.017
-26.113	-26.240	-25.822	-24.110	-24.616	-24.891	-22.442	-24.798	-25.282	-25.034	-24.174	-23.834	-25.430	-25.025	-24.027	-25.400	-24.112	-22.940	-25.703	-26.017
-26.112	-26.239	-25.817	-24.072	-24.615	-24.873	-22.437	-24.792	-25.275	-25.021	-24.165	-23.830	-25.429	-25.010	-24.013	-25.383	-24.120	-22.932	-25.706	-26.035
-26.107	-26.239	-25.817	-24.072	-24.615	-24.873	-22.437	-24.792	-25.275	-25.021	-24.165	-23.830	-25.429	-25.010	-24.013	-25.383	-24.120	-22.932	-25.706	-26.035
-26.106	-26.238	-25.828	-24.093	-24.609	-24.882	-22.439	-24.793	-25.273	-25.024	-24.173	-23.824	-25.416	-25.005	-24.019	-25.388	-24.116	-22.946	-25.706	-26.027
-26.106	-26.239	-25.828	-24.093	-24.609	-24.882	-22.439	-24.793	-25.273	-25.024	-24.173	-23.824	-25.416	-25.005	-24.019	-25.388	-24.116	-22.946	-25.706	-26.027
-26.105	-26.239	-25.813	-24.070	-24.623	-24.889	-22.440	-24.794	-25.285	-25.040	-24.168	-23.830	-25.418	-25.012	-24.021	-25.376	-24.097	-22.924	-25.684	-26.003
-26.108	-26.238	-25.813	-24.070	-24.623	-24.889	-22.440	-24.794	-25.285	-25.040	-24.168	-23.830	-25.418	-25.012	-24.021	-25.376	-24.097	-22.924	-25.684	-26.003
-26.114	-26.240	-25.819	-24.108	-24.613	-24.896	-22.443	-24.790	-25.285	-25.037	-24.176	-23.839	-25.416	-24.998	-24.034	-25.390	-24.120	-22.943	-25.712	-26.005

# «C» stave pressure drop vs flow relation at given powers

Psetpoint= 15 barA				
Mass flowrate	Pressure drop	Pressure drop	Pressure drop	
g/s	mbar	mbar	mbar	
Power heaters	0 W	38 W	75 W	Xout 75 W
0,21	241	254		
0,27		251	277	93% NEAR DRY-OUT
0,4		277	318	63%
0,5		295	355	50%
0,57	302			
0,6		314	381	42%
0,7		333	405	36%
<b>0,8</b>		357	<b>434</b>	
<b>0,9</b>	403	371	<b>451</b>	<b>28%</b> Design point
0,95	305	344	392	26%
1	384	409	491	25%
1,1		434		
1,2		452		
1,5	448			
2	525			
2,5	592			

**CENTRAL STAVE  
PRESSURE DROP VS MASS FLOWRATE  
FOR 0-50%-100% NOMINAL POWER**

**CENTRAL STAVE  
PRESSURE  
DROP [mbar]**




**MASS FLOWRATE [g/s]**

design point

# «C» stove pressure drop vs power relation at given flux

"C" channel pressure drop vs power				
mass flowrate= 0,95 g/s; Pset= 16 bar				
Power heaters W	0	38	75	112
0,95	305	344	392	433





# COBRA simulation for 100% power and nominal 0,9 g/s flux

Note: available only model with horizontal straight pipe

Using full length 3 m (more correct for friction calculation)

**CO2 Branch Model-CoBra**

**OnlyEvaporator**

Fluid: CO2

Saturation Temp. [oC]: -26.6

DetectorPower [W]: 75

Tude Diameter[mm]: 2

Tube Length [m]: 3

Tube Material[W/mK]: 14.5

Tube Thickness[mm]: 0.1

Enviroment HeatLeak[W]: 0

Angle of Tube: 0

FlowRate [g/s]: 0.9

Stepsize [mm]: 5

**Capillary+Inlet+Evaporator+Outlet**

Capillary Diameter[mm]: 1

Capillary Length [m]: 1

Temperature [°C] vs Length [m]

Vapor Quality vs Length [m]

Consistent with the Calculated Xout=28%

Mass Velocity vs Length [m]

Flow Pattern vs Vapor quality

g/s	Xout	Flow Pattern
1	25%	Intermittent
<b>0,9</b>	<b>28%</b>	Intermittent
0,8	31%	Annular
0,7	36%	Annular
0,6	42%	Annular
0,5	50%	Annular
0,4	63%	Annular
0,27	93%	dry-out

design point

CO2 Cooling, V1 Z.Zhang B.Verlaet@CERN, June, 2014

central "C" stave	Power heaters = 75 Watt	Mass flowrate	Xout	Flow Pattern
		1	25%	Intermittent
		<b>0,9</b>	<b>28%</b>	Intermittent
		0,8	31%	Annular
		0,7	36%	Annular
		0,6	42%	Annular
		0,5	50%	Annular
		0,4	63%	Annular
		0,27	93%	dry-out

design point


ST, dP, VaporQuality and FlowPattern

Save as

# COBRA simulation for 100% power and nominal 0,9 g/s flux


Note: available only model with horizontal straight pipe

Using heated length 1,36 m, more correct for heat exchange




## THERMO-HYDRAULIC CHARACTERIZATION OF CIRCUIT COMPONENTS UNDER STUDY

- 1/16 "CAPILLARY INLET PIPE, 0.88 mm ID
- 6 METER AND 1 METER LENGTH
- MEASUREMENTS DONE IN OPERATIVE CONDITION -20 °C AND -30 ° SEVERAL MASS FLOW-RATE POINT TESTED



6 METERS INLET CAPILLARY MOUNTED  
AND MEASURED



### MEASUREMENT

- CO<sub>2</sub> UPWARD FLOW
- FULL POWER (75 W)
- SET P 16 BAR
- EVAP. - 28 °C

6m CAPILLARY  
MEASURED PRESSURE  
DROP AT 0,45 G/S  
~ 3 BAR


## COOLING TEST WITH TRACI

### 1 METER INLET CAPILLARY MOUNTED

LENGTH CALCULATED WITH Darcy–Weisbach equation  
VALID FOR MONOPHASE CO<sub>2</sub> LIQUID FLO  
THE LENGTH TO HAVE I.E. «2 BAR INLET PRESSURE DROP»  
AT NOMINAL MASS FLOWRATE 0,9 G/S  
=> IS ~ 1 METER WITH 1/16 INCH SWAGELOK PIPE

Darcy–Weisbach equation

$$h_f = f \cdot \frac{L}{D} \cdot \frac{V^2}{2g}$$



1 METER INLET CAPILLARY 1/16 INCH  
MOUNTED AND MEASURED

CONFIRMATION

With 0.9 g/s measured pressure drop is 2 bar/ on 1  
meter



A 3 °C DECREASE IN TEMP INTO THE CAPILLARY  
MEANS THAT SOME BOILING STARTS AND THIS NEED  
TO BE INVESTIGATED

BOILING BEFORE THE STAVE INLET IS NOT  
ACCEPTABLE BECAUSE A SEPARATION OF VAPOUR  
(BUBBLES) CAN HAPPEN , EMPTYING SOME  
EVAPORATOR CHANNEL

# COOLING TEST WITH TRACI

## 1 METER INLET CAPILLARY MOUNTED AND MEASURED

SET P 15 BAR  
 T EVAPORATION =  $-28^{\circ}\text{C}$   
 POWER 75 W



MEASURED FLUID TEMPERATURES  $^{\circ}\text{C}$  =  $-28^{\circ}\text{C}$

DELTA T CHANNEL IN-OUT  
 = LESS THAN  $0,5^{\circ}\text{C}$

## WORK IN PROGRESS

- measurement work is in progress for the Inlet concentrated pressure drop using calibrated orifices (Swagelok components)
  - stave measured in the actual cooling test is the “C” central stave, snake pipe type A, B will follow, to measure the differences
  - warm test at +15 °C to measure flow and delta pressure
  - Changing from Armaflex insulation and using a cold box similar to the UT box, with polystyrene insulator surrounding a plastic air-tight box, dry-air controlled volume to have dew-point <- 40 °C
- TO VALIDATE THE PROPOSED TECHNOLOGY PRODUCTION for the INLET and OUTLET piping:  
Production in progress with company Real-vacuum  
WELDED JUNCTIONS OF THE CHOSEN PIPE AND THE SWAGELOK «VCR» CHOSEN FITTINGS

### TEST:

- HELIUM LEAK-RATE
- PRESSURIZATION
- HELIUM LEAK-RATE AFTER PRESSURIZATION
- MOUNTING INTO TRACI COOLING TEST

MEASUREMENT AND QUALIFICATION USING THE COOLING SYSTEM OPERATIONAL CONDITIONS (REAL PRESSURES, AMBIENT TO COLD OPERATION)

# CONCLUSION

- THE DETECTOR CONCEPT IMPLEMENTING A CO<sub>2</sub> BOILING EVAPORATIVE CHANNEL WITH A «SNAKE GEOMETRY » SERPENTINE COOLING PIPE, MOUNTED INTO A VERTICAL STAVE, HAS BEEN DEMOSTRATED TO WORK IN BOILING CONTROLLED CONDITIONS AT EVAPORATION TEMPERATURES OF - 30 °C AND - 20 °C
- THE CENTRAL STAVE THERMO-HYDRAULIC CHARACTERIZATION IN OPERATIVE CONDITION HAS BEEN DONE
- CONNECTION COMPONENTS PROPOSED FOR THE DESIGN ARE UNDER INVESTIGATION AND MEASURED IN OPERATIVE CONDITIONS

THANKS FOR THE ATTENTION


Back-up slides



# PURE CO<sub>2</sub> SATURATION CURVE

## TEMPERATURE AND PRESSURE INSIDE THE EVAPORATION CHANNEL

=> 15 TO 20 bar  
COOLING FLUID  
OPER. PRESSURE




- 20 °C TO - 30 °C COOLING FLUID  
OPER. TEMP.

THE LATENT HEAT OF VAPORIZATION FOR CO2 CAN BE KNOWN FROM THE CO2 PRESSURE-ENTHALPY DIAGRAM

IN THE RANGE OF INTEREST

**DELTA H liq.=> vap. = 280 kJ/kg**



# CO2 physical properties

Set point on TRAClv1:

Accumulator pressure P = 15 bar ABS / T saturation= - 28,5 °C

at 15 bar ABS

Enthalpy liquid (X=0)

Enthalpy vapour (X=100%)

1. General Properties    2. Saturation Properties    3. CO2 Turbine    4. Flash Evaporator    5. P-H Diagram    6. P-H Diagram (large)

**Input Data**

Select function:

1. Pressure (absolute):  bar

2. Quality:  %

Property name	Property ID	Results (Liquid)	Results	Results (Vapor)	Units (SI)
<b>1. Thermodynamic Properties - Main</b>					
1 Pressure (absolute)	p	15.0000000000	15.0000000000	15.0000000000	bar
2 Temperature	t	-28.5199041122	-28.5199041122	-28.5199041122	°C
3 Density	d	1069.3872426404	1069.3872426404	39.0557745757	kg/m³
4 Specific volume	v	0.0009351150	0.0009351150	0.0256044083	m³/kg
5 Specific enthalpy	h	-370.2278554471	-370.2278554471	-70.1517506628	kJ/kg

delta h L-V @15 bar ABS      300 J/g

calculated exhaust vapour fraction Xout

$$X_{out} = (h_{out} - h_{in}) / \Delta h_{L-V}$$

$$(h_{out} - h_{in}) = \text{Power} / F$$

F = mass flowrate

g/s

Power = electrical heaters power

W

$$\Rightarrow X_{out} = (\text{Power} / F) / \Delta h_{L-V}$$

delta h L-V @15 bar ABS	300 J/g
-------------------------	---------

$$X_{out} = 75 / (300 * F)$$

W / (J/g \* g/s)

= 1

# Materials Properties Database for F.E.A.

## LHCb UT STAVE - MATERIAL PROPERTIES DATABASE

rev. 2 09/06/2014

Orthotropic Material / Type			Thickness [µm]	E <sub>x</sub> [GPa]	E <sub>y</sub> [GPa]	E <sub>z</sub> [GPa]	G <sub>xy</sub> [GPa]	G <sub>yz</sub> [GPa]	G <sub>xz</sub> [GPa]	PR <sub>xy</sub>	PR <sub>yz</sub>	PR <sub>xz</sub>	ρ [Kg/m <sup>3</sup> ]	CTE <sub>x</sub> [ppm/K]	CTE <sub>y</sub> [ppm/K]	CTE <sub>z</sub> [ppm/K]	K <sub>x</sub> [W/m K]	K <sub>y</sub> [W/m K]	K <sub>z</sub> [W/m K]	Fiber Vol. Ratio
CFRP STAVE FACEPLATE HYBRID STIFFENER	Fiber K13C Resin Polycyanate RS3	Prepreg K13C/RS3	65	410	5,6	5,6	4,1	4,1	4,1	0,39	0,39		1731	-0,765	15					60%
	LAMINATE	Lay-up (0/90/0)	175	276	141		4,1			0,0156			1731	0,933	1,21	64	32	0,5		

Isotropic Material / Type			Thickness [µm]	E [GPa]	Poisson Ratio PR	ρ [Kg/m <sup>3</sup> ]	CTE [ppm/K]	K [W/m K]
CARBON FOAM	ALLCOMP CARBON FOAM			0,7	0,25	200	3,5	35
ROHACELL	ROHACELL 51 IG			0,07	0,40	52,1	33 @20°C 24 @-100°C	0,029
COOLING PIPE I.D. 2,0 mm O.D. 2,2 mm	BASELINE TITANIUM CP grade 2		100	105	0,34	4510	8,6	16,4
	2 <sup>nd</sup> OPTION STAINLESS STEEL AISI 316		100	193	0,30	8000	16,0	16,3
SIGNAL/POWER FLEX	KAPTON		230	2,5	0,34	1400	27	0,23
HYBRID FLEX	KAPTON		250	2,5	0,34	1400	27	0,23
SENSOR	SILICON		250	110	0,28	2400	2,5	124
ASIC			100					
GLUE	HYSOL 9396+35%BN		50	2,75	0,33 guess	1140	39,1 @ 20°C 27,1 @ -40°C	1,4
	COMPLIANT EPOXY (SENSOR GLUE)		50	0,005	0,49	2360	200	1,34
	LOW CONDUCTIVE COMPLIANT EPOXY (SENSOR GLUE)		50	same	same	same	same	0,60
THERMAL VIAS	COPPER		250	110	0,34	8930	16,4	385
WIREBONDS	ALUMINUM			68	0,36	2700	24,0	210

# DETECTOR TEMPERATURE FIELD

## F.E.A. SIMULATION

- SENSOR 8 ASICS (T3)

COOLING PIPE TEMPERATURE SET TO 0 °C


=> TO SEE THE DETECTOR DISTRIBUTION OF TEMPERATURE

- VERSION V.5
- L-SHAPED SENSOR SUPPORT
- CERAMIC MATERIAL PBN /PYROLITIC BORON NITRIDE

REQUIREMENT MAX

SENSOR TEMP < -5 °C

DELTA T ACROSS SENSOR AROUND 5-10 °C




- ⇒ DETECTOR FACEPLATE AND STRUCTURE IS ALWAYS 1-6 °C OVER THE COOLING PIPE TEMPERATURE
- ⇒ SENSOR TEMPERATURE IS 1-7 °C OVER THE COOLING PIPE TEMPERATURE

TO RESPECT REQUIREMENT WITH MARGINS AND TAKING IN ACCOUNT CO2 INTERNAL PIPE H.T.C. => COOLING PIPE <45 °C

# STAVE INLET CO2 CONNECTION

## Calibrated orifices option




### Flow Restrictors

This product can be used in liquid or gas delivery systems where repeatable flow reduction or limiting is required.



- One piece, compact design saves space
- Standard orifice sizes drilled through a 1/4 in. male VCR union
- No dead volume for clean operation
- Identification of orifice and heat code marked clearly on the body
- Electropolished, cleaned, and packaged in accordance with Swagelok *Ultrahigh-Purity Process Specification (SC-01)*, MS-06-61
- Working pressure 10 000 psig (689 bar)


### Ordering Information and Dimensions



VCR components with fixed threads must remain stationary during normal installation. These fitting connections should be assembled only to glands with rotating female nuts.

Ex, in. (mm)	Ordering Number
0.010 (0.254)	6LV-4-VCR-6-DM-010P
0.012 (0.305)	6LV-4-VCR-6-DM-012P
0.015 (0.381)	6LV-4-VCR-6-DM-015P
0.017 (0.432)	6LV-4-VCR-6-DM-017P
0.020 (0.508)	6LV-4-VCR-6-DM-020P
0.023 (0.584)	6LV-4-VCR-6-DM-023P
0.025 (0.635)	6LV-4-VCR-6-DM-025P
0.026 (0.660)	6LV-4-VCR-6-DM-026P
0.027 (0.686)	6LV-4-VCR-6-DM-027P
0.030 (0.762)	6LV-4-VCR-6-DM-030P
0.035 (0.889)	6LV-4-VCR-6-DM-035P
0.040 (1.016)	6LV-4-VCR-6-DM-040P
0.045 (1.143)	6LV-4-VCR-6-DM-045P

Ex, in. (mm)	Ordering Number
0.050 (1.270)	6LV-4-VCR-6-DM-050P
0.055 (1.397)	6LV-4-VCR-6-DM-055P
0.060 (1.529)	6LV-4-VCR-6-DM-060P
0.065 (1.651)	6LV-4-VCR-6-DM-065P
0.070 (1.778)	6LV-4-VCR-6-DM-070P
0.075 (1.905)	6LV-4-VCR-6-DM-075P
0.080 (2.032)	6LV-4-VCR-6-DM-080P
0.085 (2.159)	6LV-4-VCR-6-DM-085P
0.090 (2.286)	6LV-4-VCR-6-DM-090P
0.093 (2.362)	6LV-4-VCR-6-DM-093P
0.095 (2.413)	6LV-4-VCR-6-DM-095P
0.100 (2.540)	6LV-4-VCR-6-DM-100P



ONE INLET  
FLOW RESTRICTION  
FOR EACH STAVE


# INLET CONNECTION

## COMPONENT PRODUCTION QUALIFICATION: 2 SAMPLES

**1/16"**  
**COMMERCIAL**  
**Swagelok pipe**

**ID 0,88 mm**  
**OD 1,59 mm**  
**Th 0,35 mm**


**AISI 316 L**  
**MICROTIG/LASER**  
**WELDING**



# OUTLET CONNECTION

## COMPONENT PRODUCTION QUALIFICATION: 2 SAMPLES

**ID 2,0 mm**  
**OD 2.5 mm**  
**Th 0.25 mm**



NOTA: Le due flange di estremita' dovranno avere un foro passante corrispondente al  $\varnothing$  interno del tubo principale ( $\varnothing$  2 mm)

**AISI 316 L**  
**MICROTIG/LASER**  
**WELDING**

PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	Pipe_2x2.5x160	AISI 316L/304
2	1	SS-1-VCR-3	Swagelok
3	1	SS-2-VCR-4	Swagelok
4	1	SS-4-VCR-3_BL	Swagelok
5	1	SS-4-VCR-4	Swagelok
Designed by Carlo Gesmundo	Checked by	Approved by	Date 05/10/2015
Prototipo tubazione saldata Linea outlet raffreddamento		TRACI - INFN Milano	
		Edition STAVE 00.01.11	Sheet 1 / 1



# ORDER PLACED TO A COMPANY TO PRODUCE INLET AND OTLET CONNECTION SAMPLES

## THE GOAL IS

- TO PRODUCE THE INLET AND OUTLET PIPING SAMPLES
- REAL PIPE /REAL FITTING WELDED JOINTS

## TESTING

- LEAK-RATE AFTER PRESSURIZATION
- TRACI TEST IN REAL CONDITIONS (MOUNT-DEMOUNT VCR FITTINGS, COLD OPERATION)
- MEASURE THE RIGIDITY OF THE 2/2,5mm OUTLET PIPE, AFTER COILING AND POST-ANNEALING

**IF POSITIVELY QUALIFIED,**  
THE COMPANY COULD BE A CANDIDATE FOR THE PRODUCTION OF  
THE MANIFOLDS, PIPING CONNECTIONS ETC FOR THE UT DETECTOR.

**Rodofil**  
tecnologie di elettroerosione  
edm filo e tufo - microforatura - fresatura e tornitura cnc - elettrodi grafiti - retifica - saldatura laser

**From: Marco Canetti**  
RIAL VACUUM RESEARCH  
Via Tito ed Ettore Manzini 7/a  
43126 Parma ITALIA  
tel : +39 0521 949314  
e-mail: [marco.canetti@rialvacuum.com](mailto:marco.canetti@rialvacuum.com)

**To: Carlo Gesmundo**  
I.N.F.N. Sez. Milano  
Via Giovanni Celoria, 16  
20133 Milano  
tel: 02 50317681  
e-mail: [carlo.gesmundo@mi.infn.it](mailto:carlo.gesmundo@mi.infn.it)

## OFFERTA

N. 15/420b      Pag: 1/1      Data: 15.10.2015

Gent.mo Carlo,

a seguito della vostra gradita richiesta, Vi inviamo l'offerta per la realizzazione delle linee di raffreddamento.  
Tubi in AISI 316L.  
Dimensioni dei tubi e i raccordi di estremità come da vostri disegni.  
Nella presente quotazione viene considerato di unire i raccordi ai tubi mediante tecniche di saldatura TIG e LASER.  
Controllo visivo, controllo dimensionale e test di tenuta con cercafughe He inclusi.

Pos.	Disegno	Descrizione	Q.tà	Prezzo tot
1	STAVE 00.01.11	LINEA OUTLET RAFFREDDAMENTO	2	1.160,00 €
2	STAVE 00.01.12	LINEA INTLET RAFFREDDAMENTO L=500	1	580,00 €
3	STAVE 00.01.12	LINEA INLET RAFFREDDAMENTO L=2500	1	610,00 €
4	-	Trasporto	1	60,00 €

Imballaggio incluso  
Tempo di esecuzione: 3 settimane da ricevimento ordine

Restiamo a disposizione per ogni richiesta di chiarimento.  
Cordiali saluti,

**RIAL VACUUM RESEARCH**  
Marco Canetti  
*Marco Canetti*

**RIAL VACUUM RESEARCH**

RODOFIL s.n.c. di Alessandro Zanichelli & C. - Strada di Chizzola 29 - 43058 Chizzola di Sorbolo - Parma - tel. +39.0521.804366-7 - fax +39.0521.804368  
e-mail: [info@rodofil.com](mailto:info@rodofil.com) - [www.rodofil.com](http://www.rodofil.com) - C.F. e P. IVA 01702180348 - Iscr. trib. di Parma N.20315 - R.E.A. N.122730

# SENSORS FOR THE TEST



5 CO2 pressure sensors

Piezoresistive  
Pressure Transmitters  
KELLER Series 21 Y  
Type PAA-21Y / 80bar  
/ 81555.33  
4-20 mA  
0-80 bar abs.



5 CO2 temperature sensors

Resistance temperature detectors PT100  
RODAX  
OD 4 mm; length 80 mm;  
4 wire connection



30 external temperature  
Termocouples T type

TERSID S.r.l.  
Centro SIT n.169 - TEMPERATURA  
20128 MILANO - Via Demostene, 15  
Tel. 02 27001002 (r.a.) - Fax 02 2575313  
e-mail: tersid@tersid.it - www.tersid.it

Cavo di termocoppia  
 Cavo compensato  
 Termocoppia  
 Termoresistenza


Mod DA NN-26-TT  
- GIUNTO CALDO A SPILLO  
- TERMINALI (BER)  
Lunghezza m. 5  
Quantità N° 30  
Norma ANA  
N. Ordine cliente 3/15  
Rif. Tersid 180/15

ASSENZA CON SISTEMI QUALITÀ  
CERTIFICATO DA UNI  
- UNI EN ISO 9001/2000 -

## COOLING TEST WITH TRACI

Many data have been collected

But output need to be elaborated and made presentable



### POWER:

- 0 W
- 50% = 38 W
- 100% = 75 W
- 150% = 113 W

### MASS FLOW-RATE:

- NOMINAL = TO HAVE 30 % CO<sub>2</sub> EXHAUST FRACTION
- DECREASING UNTIL DRY-OUT
- INCREASING TO MAX POSSIBLE
- 0,1 - 2 g/s RANGE

### PRESSURE SET POINT:

- 20 BAR (T EVA ~ -20 °C)
- 15 BAR (T EVA ~ -28 °C)

### STUDY OF TRANSIENTS AND FINAL STEADY -STATES


- SETTING FLOWRATE AT NOMINAL POWER
- POWER FROM 0 - 100% - 0
- 0-50-100-150-100-0

# PRESSURE SENSOR SETTING


2015-10-13 TARATURA PF

PF1	PF2	PF3
22,72	22,84	22,869
22,712	22,826	22,856
22,713	22,824	22,852
22,709	22,823	22,851

**FLOW = 0**




PF1	PF2	PF3	PF2-PF1	PF3-PF1
20,612	20,721	20,752	0,109	0,140
20,618	20,721	20,748	0,103	0,130
20,6	20,696	20,727	0,096	0,127
20,593	20,698	20,726	0,105	0,133
20,604	20,708	20,726	0,104	0,122
20,59	20,69	20,719	0,100	0,129
20,576	20,675	20,701	0,099	0,125
20,583	20,675	20,706	0,092	0,123
20,562	20,665	20,696	0,103	0,134
20,569	20,665	20,691	0,096	0,122
20,556	20,655	20,684	0,099	0,128
20,558	20,654	20,682	0,096	0,124
20,552	20,651	20,676	0,099	0,124
20,529	20,631	20,655	0,102	0,126
20,539	20,638	20,661	0,099	0,122
20,526	20,627	20,648	0,101	0,122
20,514	20,62	20,643	0,106	0,129
20,517	20,619	20,648	0,102	0,131
20,512	20,604	20,629	0,092	0,117
20,5	20,599	20,628	0,099	0,128



## Fluid Data

Isobaric Data for P = 20.000 bar



## Auxiliary Data

Reference States

## Fluid Data

Isobaric Data for P = 20.000 bar

