



Contribution ID: 36

Type: Oral Presentation

## Investigation of model transformer insulation behavior during PD activity in Di-Benzo-Di-Sulfide Sulphur contaminated transformer oil using online $\tan\delta$ measurement

*Friday 8 July 2016 10:45 (15 minutes)*

Sulphur can be present in mineral insulating oil and can manifest in stable, highly reactive and corrosive form. The corrosive sulphur reacts with the copper conductor in transformer and forms semi conductive copper sulphide at the surface of the copper conductor. The paper insulation used on the copper conductor may get damaged due to copper sulfide deposits which also affect the partial discharge activities prevalent in the transformer paper-oil insulation. The affect of Sulphur on model transformer paper-oil insulation is studied with online measurement of Dissipation factor ( $\tan\delta$ ) and partial discharges (PD). The paper presents results of the investigatory work carried out with on-line  $\tan\delta$  and PD measurements made during experiments with Paper covered copper conductor (PCCC) in presence of Di-Benzo-Di-Sulfide contamination in transformer oil.

**Primary author:** Prof. KUMAR, sanjeev (Sri Siddhartha Institute of Technology)

**Co-authors:** Dr BALAIAH, Ramachandra (P.E.S.College of Engineering); Dr KUMAR, senthil (ABB)

**Presenters:** Dr BALAIAH, Ramachandra (P.E.S.College of Engineering); Prof. KUMAR, sanjeev (Sri Siddhartha Institute of Technology)

**Session Classification:** Oral 10

**Track Classification:** Dielectrics, Insulation, and Breakdown