

AIDA

2020


Transport System for Large objects at Ljubljana JSI TRIGA Reactor (part of WP15.5)

V. Radulović, L. Snoj, V. Cindro,
Marko Mikuž


J. Stefan Inst. & Univ. Ljubljana, Slovenia



AIDA2020 Annual Meeting, DESY, June 14, 2016


TRIGA Mark II Reactor Ljubljana




- 1st criticality:
 - 31st May, 1966
- P_{\max}
 - 250 kW (steady state)
 - 1 GW (pulse)
- Fuel
 - UZrH (12 wt. % U)
 - $E = 20\%$








Proposed irradiation facility



TRIGA Irradiation Channels




Goal

- Develop and install a large sample irradiation ($2R < 15$ cm) facility in the tangential channel of the JSI TRIGA reactor

Tangential Channel Characteristics

- Inner diameter: 15 cm
- Neutron flux characterisation:
 - L. Snoj et al., Appl. Rad. Isot. 70 (2012) 483–488
- Neutron flux: $1.3e12$ n/cm²s
 - Thermal ($E < 0.625$ eV): 58 %
 - Epithermal (0.625 eV $< E < 100$ keV): 25 %
 - Fast ($E > 100$ keV): 17 % -> $2.2 E11$ n/cm²s
 - $1e15$ n_{eq}/cm² in 1 ½ hours

Neutron Spectra




Milestone for M12

- MS15.9 (MS17): Design of a transport system for neutron irradiations of large samples:
 - *The design of a transport system for large objects of a diameter of up to 12cm into the Ljubljana reactor irradiation position including the possibility for electrical and cooling connections to the samples has been documented.*
- Report to StCom – submitted to WP15 management 27/04

Tangential channel




Measurement of internal dimensions



Channel interior


Dose rate measurements with a neutron / gamma shield mockup:

- 75 cm, \varnothing 20 cm neutron shield (borated paraffin)
- 15 cm lead gamma shield
- Measurements at 0.1% and 1% of full reactor power
- Scaled neutron doses (to full power, 250kW) very low ($40 \mu\text{Sv/h}$), scaled gamma dose rates smaller than 1mSv/h




Shielding Design

- Based on test measurements with the current channel configuration
- Neutrons shielded ok by borated (5% B) parafine plug
 - $\Phi = 20$ cm, $l = 75$ cm
- Need to shield gammas
 - additional attenuation 10^{-3} sought for $E_\gamma = 1-10$ MeV
 - Pb and concrete evaluated
 - 30 cm Pb chosen
- Concrete blocks as backup if measurements reveal more than $10 \mu\text{Sv/h}$ at full reactor power



Conceptual design

- 1) Internal aluminium liner, inner diameter 14.6 mm
- 2) Outer neutron / gamma shield + concrete shielding, to reduce dose rate from $\sim 1\text{mSv/h}$ to under $10\mu\text{Sv/h}$ (acceptance criterion).
- 3) Samples fitted into polyethylene caddies, fastened by a rod to the neutron shield.



Towards the Deliverable

- D15.9: JSI TRIGA Reactor Transport system:
 - *The transport system for large objects of a diameter of up to 12cm into the reactor irradiation position including the possibility for electrical and cooling connections to the samples has been installed and commissioned. (Task 15.5)*
 - Deliverable for M18

Status

- Design report submitted to Reactor Safety Committee – in evaluation
- System produced at Institute's workshop
 - lead time 30-45 days
- Installation and commissioning
 - irradiate a couple of own devices first to gain operational experience
- Could make it by late fall, in time for M18