

# Vacuum system MEDICIS

Jose A. Ferreira

# MEDICIS Vacuum WP

## Scope:

- Vacuum system of MEDICIS facility including (design, procurement and installation):
  - ❑ Gas recuperation system
  - ❑ Pumping system (turbo and primaries)
  - ❑ Ancillary lines
  - ❑ Controls
- Excluded:
  - ❑ Vacuum chambers, 3D integration and compressed air supply

# MEDICIS Vacuum Specification

## Pressure requirement:

$\approx 10^{-6}$  mbar frontend

$\approx 10^{-7}$  mbar in separator and experiment

Primary vacuum tightness  $< 2 \cdot 10^{-10}$  mbar·l/s

## Maximum gas loads:

-  $10^{-4}$  mbar·l/s frontend (24h)

-  $10^{-5}$  mbar·l/s separator (24h)


## Radioactive gas recovery system:

All ancillary lines leak tight  $< 10^{-5}$  mbar·l/s (including backing lines and exhaust)

# Proposed layout


- ❑ Reduced: number of components (two turbos and two primaries to pump three vacuum sectors)
- ❑ Redundancy: Operation even if one turbo or primary
- ❑ Vacuum sector 1 and 3 frequently vented
- ❑ Elastomeric seals (Viton / EPDM)

Layout compatible with integration??



# Gas recuperation system

- ❑ All ancillary lines under vacuum except accumulation tank
- ❑ Design for 30 venting/year
- ❑ Backing and roughing pumps dry or oil?
  - ❑ Oil → Filters radioactive contamination, but no treated waste and spill risk
  - ❑ Dry → No maintenance but higher radiation on exhaust
- ❑ Emptying should be interlocked by ventilation system



# Equipment (Turbopumps)



## TURBOVAC 1000

- ↑ Good experience in ISOLDE frontend with no maintenance
- ↑ Air cooled
- ↑ Mechanical bearings (no affected by magnetic fields)
- ↓ Recent experience in LINAC2 no satisfactory. Sensible to backing pressure



## HiPace 700

- ↑ Good experience at CERN
- ↑ Air cooled
- ↓ Hybrid bearings (affected by magnetic fields  $>6\text{mT}$ )
- ↓ Maintenance required each 4 years

# Equipment (Primary pumping)



## DuoLine 35M


- ↑ Hermetic pump (tightness  $1e-6$  mbar·l/s)
- ↑ Magnetic motor coupling (reduced risk of oil spill)
- ↑ Very good ultimate pressure  $<2e-3$  mbar
- ↓ Oil needs to be replaced each year (contamination risk and waste)



## ACP28


- ↑ Hermetic pump (tightness  $5e-7$  mbar·l/s)
- ↑ No oil in contact with vacuum
- ↑ Reduced maintenance
- ↓ Ultimate pressure  $<3e-2$  mbar
- ↓ No contamination “filter”

# Integration: First drawings





# Integration: 3D



# Open questions

- ❖ Type, size and number of flanges available
  - ❖ 3D integration of vacuum system (sector valves, volumes, etc.)
  - ❖ Oil primary pumps / dry pumps (waste vs exhaust dose rate)
  - ❖ VSC alarms supplied and received
    - ➔ Fix final layout (before procurement)
- Procurement before end of June 2016  
(installation end 2016)

# Cost estimate

## Vacuum system

Item	#	Cost/each (CHF)	Cost sum (CHF)
Turbo-pump (Leybold 1000)	2	18858	37716
Roughing Pump (Dry ACP28)	2	10000	20000
Sector valve (S10 Elastomer Gate Valves)	4	5000	20000
DN63 Angle valve KF	1	1000	10000
DN160 S10 Gate valve (O-ring)	2	7000	14000
Venting valve (DN16 KF)	9	500	4500
Pirani gauge	7	1000	7000
Penning gauge	7	1000	7000
TPG300	3	5000	15000
<b><u>Total Material cost</u></b>	-	-	<b><u>135216</u></b>

# Cost estimate

## Exhaust system

Item	#	Cost/each (CHF)	Cost sum (CHF)
Roughing pump	1	10000	10000
Membrane pump	1	10000	10000
Angle valve (DN63 KF)	6	1000	6000
By-pass valve	1	1000	10000
Piezo gauge	1	1000	1000
Pressostat	1	1000	1000
Thermocouple	1	1000	1000
Filter (0.5m3)	1	5000	5000
Tank (St.St 304 3m3 Dia:1700 H:3040)	1	5000	5000
<b><u>Total Material cost</u></b>	-		<b><u>40000</u></b>

# Cost estimate

## Vacuum controls

Item	Cost (CHF)
Material (controllers, etc.)	85800
Cabling	20600
FSU	21000
PJAS	39600
<u>Total cost</u>	<u>167000</u>

**Total cost 345 kCHF (better estimate when layout frozen)**

# Future operational needs

- ❑ Dedicated leak detector (contaminated) with modified exhaust for leak testing
- ❑ Spares: one turbopump, one primary pump, one diaphragm pump.
- ❑ Training of MEDICIS operators (regular venting and pumping operations) → ISOLDE op?
- ❑ VSC Piquet Service required?

# Conclusion

- ❑ Open questions to be solved end of June 2016
- ❑ Procurement installation end 2016 beginning 2017.
- ❑ Total cost vacuum system: 345 kCHF
- ❑ Manpower 0,5 FTE
- ❑ Not included in vacuum WP: vacuum chambers and integration