

# Development of a 1 GS/s high-resolution transient recorder

S. Bartknecht, H. Fischer, F. Herrmann, K. Königsmann,  
L. Lauser, C. Schill, S. Schopferer, H. Wollny

Universität Freiburg, Physikalisches Institut, Freiburg, Germany

[sebastian.schopferer@cern.ch](mailto:sebastian.schopferer@cern.ch)

## Abstract

With present-day detectors in high energy physics one is often faced with short analog pulses of a few nanoseconds length which may cover large dynamic ranges. In many experiments both amplitude and timing information have to be measured with high accuracy. Additionally, the data rate per readout channel can reach several MHz, which makes high demands on the separation of pile-up pulses.

For such applications we have built the GANDALF transient recorder with a resolution of 12bit@1GS/s and an analog bandwidth of 500 MHz. Signals are digitized and processed by fast algorithms to extract pulse arrival times and amplitudes in real-time and to generate experiment trigger signals. With up to 16 analog channels, deep memories and a high data rate interface, this 6U-VME64x/VXS module is not only a dead-time free digitization unit but also has huge numerical capabilities provided by the implementation of a Virtex5-SXT FPGA. Fast algorithms implemented in the FPGA may be used to disentangle possible pile-up pulses and determine timing information from sampled pulse shapes with a time resolution in the picosecond range.

Recently the application spectrum has been extended by implementing a 128-channel time-to-digital converter inside the FPGA and an appropriate input mezzanine card.

## I. INTRODUCTION

The Common Muon and Proton Apparatus for Structure and Spectroscopy (COMPASS) at the CERN SPS [1] is a state-of-the-art two stage magnetic spectrometer [2] with a flexible setup to allow for a rich variety of physics programs to be performed with secondary muon or hadron beams. Common to all measurements is the requirement for highest beam intensity and interaction rates with the needs of a high readout speed. Recently interest has been expressed for pursuing a dedicated measurement of Generalized Parton Distributions (GPD) [3]. For these measurements the existing COMPASS spectrometer will be extended by a new 2.4 m long liquid hydrogen target, which will be surrounded by a new recoil detector based on scintillating counters. The background induced by the passage of the beam through the target will yield rates of the order of a few MHz in the recoil detector counters. This imposes great demands on the digitization units and on a hardware trigger based on the recoil particle. For this purpose we have developed within the GANDALF framework [4] a modular high speed and high resolution transient recorder system.

## II. THE GANDALF FRAMEWORK

GANDALF (Fig. 1) is a 6U-VME64x/VXS carrier board which can host two mezzanine cards. It has been designed to cope with a variety of readout tasks in high energy and nuclear physics experiments. Two exchangeable mezzanine cards allow an employment of the system in very different applications such as analog-to-digital or time-to-digital conversions, coincidence matrix formation, fast pattern recognition or fast trigger generation. A schematic overview of the carrier board as transient recorder is provided in Figure 2. The heart of the board is a VIRTEX5-SXT FPGA which is connected to the mezzanine cards by several single ended and more than 110 differential signal interconnections. The data processing FPGA can perform complex calculations on data which have been sampled on the mezzanine cards.




Figure 1: Picture of the GANDALF carrier board equipped with two ADC mezzanine cards. The center mezzanine card hosts an optical receiver for the COMPASS trigger and clock distribution system.






Figure 5: Signal-to-noise ratio (full-scale) and effective resolution of the 12-bit and 14-bit digitization units. Values from the ADC datasheets are given for comparison.




Figure 6: With our 12-bit, 1GS/s sampling ADC module a timing resolution of 17 ps can be achieved for pulses exceeding 10% of the dynamic range of the input signals.

## V. CONCLUSION AND OUTLOOK

A low cost VME64x system aimed at digitizing and processing detector signals has been designed and implemented to our full satisfaction. The design is modular, consisting of a carrier board on which two mezzanine boards with either analog or digital inputs can be plugged. The ADC mezzanine cards have been characterized and show excellent performance over a wide input frequency range. Recently an additional type of mezzanine card with 64 digital inputs has been designed, which accepts LVDS and LVPECL signals over a VHDCI connector. An optional high-speed serial VXS backplane offers inter-module communication for sophisticated trigger processing possibly using a large number of detector channels.

The GANDALF transient recorder has been installed at the COMPASS experiment during a two-week DVCS pilot run in September 2009. Extensive data have been recorded in order to verify the performance of the hardware and the signal processing algorithms.

In a forthcoming paper we will describe the realization of GANDALF as a 128-channel time-to-digital converter module with 100 ps digitization units, comparable to the F1-TDC chip [9]. The TDC design is implemented inside the main FPGA which can host 128 channels of 500-MHz scalars at the same time.

## VI. REFERENCES

- [1] The COMPASS Collaboration, Proposal, CERN/SPSLC/96-14, SPSLC/P297 (1996)
- [2] P. Abbon et al., COMPASS Collaboration, Nucl. Instr. and Meth. A 577 (2007) 455
- [3] The COMPASS Collaboration, Medium and Long Term Plans, CERN-SPSC-2009-003, SPSC-I-238
- [4] S. Bartknecht et al., accepted for publication in Nucl. Instr. and Meth. A
- [5] H.C. van der Bij, et al., IEEE Trans. Nucl. Sci. NS-44 (1997) 398
- [6] L. Lauser, Diploma Thesis, Universität Freiburg (2009)
- [7] S. Schopferer, Diploma Thesis, Universität Freiburg (2009)
- [8] S. Bartknecht, Research Thesis, Universität Freiburg (2009)
- [9] H. Fischer et al., Nucl. Instr. and Meth. A 461 (2001) 507