



FCC Week 2017, Berlin

# Towards a conceptual design for FCC cryogenics



Laurent Tavian,  
CERN, ATS-DO

On behalf of the FCC  
cryogenics study  
collaboration

1<sup>st</sup> June 2017




# Content



- Introduction: FCC cryogenic study organization
- FCC-hh cryogenics overview
- FCC-ee cryogenics overview
- HE-LHC cryogenics overview
- Conclusion



# FCC cryogenics studies







# Content



- Introduction: FCC cryogenic study organization
- **FCC-hh cryogenics overview**
- FCC-ee cryogenics overview
- HE-LHC cryogenics overview
- Conclusion




# FCC-hh: tunnel cryogenics



Vacuum vessel  
 Bayonet heat exchanger, 1.85 K saturated  
 Cold mass, 1.9 K (1.3 bar)

Beam screen, 40-60 K (50 bar)  
 Magnet thermal shield 60 K (44 bar)  
 Support post




40 K supply header (50 bar)  
 60 K return header (44 bar)  
 4 K VLP pumping line (15 mbar)  
 Quench buffer, 40 K (1.3 bar)  
 4.6 K SHE header (3 bar)

Temperature level	Static [W/m]	Dynamic [W/m]	Total [W/m]
1.9 K	0.5	0.9	1.4
40-60 K	9	62	71



# FCC-hh cryogenic layout and architecture




WCS: Warm Compressor Station  
UCB: Upper Cold Box  
LCB: Lower Cold Box  
SIB: Sector Interconnection Box

Cryoplant	40-60 K [kW]	1.9 K [kW]	40-300 K [g/s]
	592	11*	85
	618	12*	85

Without operational margin !

\*: Outside State-of-the-Art




**Ne-He  
300-40 K  
cryoplant**


- Beam screen (40-60 K)
- Thermal shield (40-60 K)
- Current leads (40-300 K)
- Precooling of 1.9 K cryoplant

**He 1.9 K  
cryoplant**

- SC magnet cold mass

Contributions of TU Dresden and CEA/SBT






— He cycle  
— Ne-He cycle

BS cooling with cold circulator  
(+130 kW @ 40-60 K)

BS cooling with warm circulator  
+140 kW @ 40-60 K and +500 kW @ 300 K  
→ Less efficient but good for redundancy  
and needed for cool-down and warm-up  
operation



### Nominal loads

Beam screen	Q <sub>bs</sub>	530 kW
Thermal shield	2 Q <sub>ts</sub>	90 kW
Cold-mass	Q <sub>cm</sub>	12 kW
Pumping line	Q <sub>b</sub>	2 kW
Cuurent leads	Q <sub>cl</sub>	85 g/s








Cool-down capacity produced by the Ne-He cycle:  
No need of LN2 cool-down unit with its huge LN2 storage and logistics

Cold mass: 2.8 t/m i.e.  
23 kt per sector  
230 kt for FCC

15 days of cool-down time from 300 to 40 K (10 days (on paper) with LN2).

Cost (only energy)  
Full FCC CD → 2.3 MCHF  
(To be compared with the cost of a CD using LN2 → 45000 t, i.e. ~4 MCHF)







SR absorbers: 61 W per dipole and per beam, i.e.  $\sim 60$  kW per long-sector  
 Without radiation absorbers  $\rightarrow 616$  kW between 40 and 59.5 K ( $m = 5.8$  kg/s)  
 With radiation absorbers  $\rightarrow 616$  kW between 40 and 62 K ( $m = 5.2$  kg/s)

C. Garion

Variable	Unit	LHC	FCC
Unit cooling length	m	106.9	107.1
Sector cooling length	m	2900	8400
Average heat load nominal (installed) capacity	W/m	0.40 (0.83)	1.38 (2.44)
Bayonet HX inner diameter	mm	53.4	83.1
Feeder pipe inner diameter	mm	10.0	15.0
Thickness bayonet HX pipe wall	mm	2.3	5.0
Joule-Thomson valve inlet temperature	K	2.18	2.18
Free longitudinal cross-section area	cm <sup>2</sup>	60	156
DT max Pressurized-saturated Hell	mK	50	50
Cold mass operating pressure	bar	1.3	1.3
Header B diameter	mm	270	500 (630)
Heat load on header B	W/m	0.11	0.24
Pumping pressure at cryoplant interface	mbar	15	15
Maximum cold-mass helium temperature	K	1.9	1.98 (1.9)



- Helium I (4.6 K / 3 bar)
- Helium II vapour saturated or overheated
- Helium I / II non-stratified two-phase flow
- Helium II pressurized bath (1.3 bar)
- Helium II liquid saturated or sub-cooled



C. Kotnig



# FCC-hh Beam-screen cooling loop parameters





## Transient modes


- Working at constant nominal flow to handle the severe transient during energy ramp-up
- Working at constant He inventory to avoid big mass release and refill (i.e. pressure increase during energy ramp)

Large inertia of the distribution system  
 → time constant of ~ 4 h  
 → OK with the capacity adaptation of the cryoplants  
 → In high luminosity operation (4 h of stable beams), the cryoplants will be never in steady-state

C. Kotnig  
H. Rodrigues

Main parameter	Unit	LHC	FCC
Unit cooling length	m	53.4	107.1
Sector cooling length	m	2900	8400
Average BS nominal dynamic capacity	W/m	1.6	62
Supply pressure	bar	3	50
Supply helium temperature	K	5	40
Max. allowed BS temperature	K	20	60
BS helium outlet temperature (nominal)	K	20	57
Minimum BS temperature (nominal)	K	5	43
BS pressure drop (nominal)	bar	0.5	3
ΔP control valve (nominal)	bar	0.8	1
ΔP supply and return header (nominal)	bar	0.4	2
Total cooling loop pressure drop	bar	1.7	6
Supply/return header diameter	mm	100/150	250/250
Exergetic efficiency (distribution only)	%	76	86
Total exergetic eff. (with cold circulator)	%	N/A	82
Total exergetic eff. (with warm circulator)	%	?	74





**RH:** resistive heating

**BGS:** beam-gas scattering

**BS:** beam screen

**CM:** cold mass heat-inleaks

**CL:** current lead

**BS cir.:** Beam screen circulator (warm)

**TS:** thermal shield

**IC:** image current

**SR:** synchrotron radiation

Carnot efficiency:

- Ne-He plants: 40 %

- Helium plants: 28.8 %

Isentropic efficiency

- cold compressors: 75 % per stage







- Warm circulator: 83 %



# FCC-hh Main cryogenic distribution



	DN mm
B	500
C	80
D	200
E	250
F	250
F'	50
HP	100
LP	250
VLP	300
QL	400



Main distribution based on INVAR technology  
 Contribution of WUST





# FCC-hh He inventory




Cold mass He inventory : 33 l/m (scaled from LHC)



Distribution inventory dominated by the beam-screen supply and return headers



**FCC He inventory: ~800 t ! (~6 LHC He inventory)**



- GHe storage - 60 (250 m3, 20 bar)
- Quench buffer - 156 (250 m3, 20 bar)
- GHe storage - 10 (250 m3, 50 bar)
- Ne-He storage - 10 (250 m3, 50 bar)
- GNe cylinders - 10 (10 m3, 200 bar)
- LHe storage - 50 (120 m3)
- LHe boil-off liquefier - 6 (150 to 300 l/h)
- LN2 storage - 6 (50 m3)







# Project breakdown structure



PBS			FCC-hh																								
			Total	A	SA-B	B	SB-C	C	SC-D	D	SD-E	E	SE-F	F	SF-G	G	SG-H	H	SH-I	I	SI-J	J	SJ-K	K	SK-L	L	SL-A
Refrigeration	Ne-He cryoplant	[nb]	10	1			2				2				1				2				2				
	Helium cryoplant	[nb]	10	1			2				2				1				2				2				
Distribution	Vertical cryogenic distribution	[m]	2218	304			514				264				354				340				442				
	Local cryogenic distribution	[m]	150	15			30				30				15				30				30				
	Tunnel cryogenic distribution	[m]	86600	100	4700		8400	100	8400		8400	100	8400		4700	100	4700		8400			8400	100	8400		4700	
	Cryoplant interconnection box	[nb]	6	1			1				1				1								1				
	Sub-cooling HX	[nb]	800		40		80		80		80		80								80		80			40	
	Quench valves	[nb]	1200		60		120		120		120									120		120		120		60	
	BS flow meter	[nb]	800		40		80		80						40				80		80		80		80	40	
	Storage	Helium gaseous storage (20 bar)	[m3]	15000	1500											1500				3000				3000			
Helium gaseous storage (50 bar)		[m3]	2500	250							250				250				500				500				
Ne-He gaseous storage (50 bar)		[m3]	2500	250							500				250				500				500				
Ne gaseous storage [200 bar]		[m3]	100	10			20				20				10				20				20				
LHe storage		[m3]	6000	600			1200				1200				600				1200				1200				
LHe storage loss liquefier		[nb]	6	1			1				1				1				1				1				
LN2 storage		[nb]	6	1			1				1				1				1				1				
Quench buffer		[m3]	39000	2000		3500	3500		3500		3500	3500		3500	2000		3500		3500		3500		3500		3500		
Infra-structure	Quench line	[m]	4411	404		366	357		372		232	492		454	368		270		415		321		360				
	He ring line	[m]	104411	404	4900	366	9600	357	10500	372	10500	232	9600	492	4900	454	4900	368	9600	270	10500	415	10500	321	9600	360	4900
	Warm recovery line	[m]	91011	504	4700	366	8400	457	8400	372	8400	332	8400	492	4700	554	4700	368	8400	370	8400	415	8400	421	8400	360	4700
	Other infrastructure	[%]	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	
Instrumentation & controls		[%]	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	
First helium inventory		[t]	800	1	43		78	1	78		78	1	78		43	1	43		78	1	78		78	1	78	43	

Ready for cost estimate



# Content



- Introduction: FCC cryogenic study organization
- FCC-hh cryogenics overview
- **FCC-ee cryogenics overview**
- HE-LHC cryogenics overview
- Conclusion





# FCC-ee RF data



		Z			W			ZH			ttbar	
		1 cell, 400 MHz, 4.5 K			2 cell, 400 MHz, 4.5 K			2 cell, 400 MHz, 4.5 K			2 cell, 400 MHz, 4.5 K	
		Beam 1	Beam 2	Booster	Beam 1	Beam 2	Booster	Beam 1	Beam 2	Booster	Beam 1 & 2	Booster
RF voltage	[MV]	80	80	80	800	800	800	3000	3000	3000	10000	10000
Frequency	[MHz]	400	400	400	400	400	400	400	400	400	400	400
# cell per cavity	[-]	1	1	1	2	2	2	2	2	2	2	2
E acc	[MV/m]	2.15	2.15	2.15	10	10	10	10	10	10	10	10
V cav	[MV]	0.81	0.81	0.81	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
# cav	[-]	99	99	99	107	107	107	400	400	400	1333	1333
RF system length	[m]	176	176	176	229	229	229	860	860	860	2866	2866
Cav length	[m]	1.78	1.78	1.78	2.15	2.15	2.15	2.15	2.15	2.15	2.15	2.15
Q Dyn / cav @ 4.5 K	[W]	2.4	2.4	0.24	105.2	105.2	10.52	105.2	105.2	10.52	105.2	10.52
T operation	[K]	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
Q stat	[W/m]	5	5	5	5	5	5	5	5	5	5	5
Q Dyn	[W/m]	1.4	1.4	0.14	49	49	4.9	49	49	4.9	49	4.9

O. Brunner

- 75 K return header (20 bar)
- 4.5 K GHe return(1.3 bar)
- 4.6 K SHe supply (3 bar)
- 50 K supply header (20 bar)




WW, ZH, tbar	Temp. level	Static [W/m]	Dynamic [W/m]
Main rings	4.5 K	5	49
	50-75 K	3.1	0
Booster ring	4.5 K	5	4.9
	50-75 K	3.1	0
Distribution	4.5 K	0.5	0
	50-75 K	1.3	0

3 Linacs in the tunnel  
 → 2 for the main rings  
 → 1 for the booster ring

LHe vessel 4.5 K, 1.3 bar  
 RF cavity cell



# FCC-ee cryogenic capacity (2 main + 1 booster rings)



Machine	Q stat [kW]	Q dyn [kW]	Qtot [kW]	Cryoplant #	Cryoplant size [kW@4.5 K]
Z	2.9	0.5	3.4	2	1.7
WW	3.7	24	27	2	14
ZH	14	88	102	4	26
ttbar	31	154	185	4 (8)	46* (23)

Without operational margin !

\*: Outside State-of-the-Art




# FCC-ee: Cryogenic layout




~ 10 m-long cryo-modules with cold-warm transitions

## FCC Point D and J (each)


Z machine




WW machine



ZH machine




ttbar machine




Staging scenario of cryogenics not define yet.





# FCC-ee: Cryogenics electrical consumption



ttbar machine → 35 MW for the 2 main rings



- Z & WW machine
- Add for ZH machine
- Add for ttbar machine



- Specific helium inventory
- RF cryomodule: 34 l/m
  - Distribution 8 l/m






# Content



- Introduction: FCC cryogenic study organization
- FCC-hh cryogenics overview
- FCC-ee cryogenics overview
- **HE-LHC cryogenics overview**
- Conclusion



# HE-LHC beam screen operating temperature



## summary of beam-induced heat loads

mW/m per aperture	LHC	HE-LHC		
	nominal	nominal/ult.*	nominal/ult.*	nominal/ult.*
		LHC bs at 20 K	LHC bs at 50 K	FCC bs at 50 K
synchrotron radiation	165	4000/5500	4000/5500	4000/5500
image current	160	1140	2160	2230
electron cl.**	445	1100	1100	100
total at bs $T$	770	6240/7740	7260/8760	6330/7830
beam-gas scattering (heat at 1.9 K)***	24	88/95	88/95	88/95

\*the only difference between ultimate and nominal is the beam energy (13.5 vs 12.5 TeV)

\*\*for SEY=1.4 and 25 ns spacing \*\*\*for 100 h lifetime and uniform gas pressure

40-60 K temperature range is the best for HE-LHC





# HE-LHC BS pressure drop



2 circular cooling channels per BS (LHC like)

For exergetic efficiency:  $DP < \sim 5\%$  of the operating pressure



Use the FCC-hh design which is compatible with a 20 bar operating pressure



# HE-LHC specific heat loads



Temperature level		FCC-hh [W/m]		HE-LHC [W/m]	
		40-60 K	1.9 K	40-60 K	1.9 K
Static heat inleaks	CM supporting system	2	0.13	2	0.13
	Radiative insulation		0.13		0.13
	Thermal shield	3.1		3.1	
	Feedthrough & vac. barrier	0.2	0.1	0.2	0.1
	Distribution	4	0.1	3	0.1
	Total static	9.3	0.46	8.3	0.46
Dynamic heat loads	Synchrotron radiation	57	0.2	8	0.2
	Image current	5.4		4.46	
	Resistive heating		0.3		0.3
	e-clouds			0.2	
	Beam-gas scattering		0.45		0.18
	Total dynamic	62	0.95	13	0.68
Total		72	1.4	21.0	1.1

1.8 K LHC refrigeration units to be replaced (Existing units limited to 2.4 kW)

Upgrade of existing LHC 4.5 K cryoplants to be studied

→ present capacity:

Temperature level	LHC Sector cooling capacity: HL/LL
50-75 K	33/31 kW
4.6-20 K	20.6/17.5 kW
4.5-290 K	41/27 g/s

Temperature level	HE-LHC Sector cooling capacity
40-60 K	61 kW
1.9 K	3.3 kW
40-290 K	54 g/s


Equivalent to  
~18 kW @ 4.5 K  
(Without operational margin)



# HE-LHC: Reuse of the existing tunnel cryo distribution (QRL)?



- Cooling of HE-LHC sectors with the existing QRL seems difficult:
  - Header D (quench buffer) could be too small to buffer the CM inventory discharge during quench.
  - BS cooling 40-60 K instead of 4.6-20 K → Modification of internal circuits could be quite invasive
  - Existing hardware (valves, HX...) are undersized
  - Cell length is different → existing QRL service modules are shifted with respect to the position of the new Quad → invasive cryo-extensions are required.
- HE-LHC design requires larger pipe diameter (D, E, F) → i.e. will not ease the tunnel integration exercise.



Space reservation for flanges, bellows and welding/cutting machines

Header	DN [mm]
B	270
C	100
D	200
E	100
F	100



# Content




- Introduction: FCC cryogenic study organization
- FCC-hh cryogenics overview
- FCC-ee cryogenics overview
- HE-LHC cryogenics overview
- **Conclusion**




# WP2 – Cryogenic challenges

## CDR skeleton



~20 to 40 pages

# Conclusion: schedule



Substantial progress in various domains.

Next important steps:

- FCC-hh: Complete the engineering studies with our industrial partners (Air Liquide and Linde)
- FCC-hh & HE-LHC: Cryogenic transients during resistive transitions → impact on quench valve size & number, on cold-mass design pressure and on header D diameter.
- FCC-hh & HE-LHC: Energy buffering during magnet current ramp-up and fast ramp-down → impact on helium inventory (is 33 l/m (400 t) sufficient ?)
- FCC-ee: Refine the staging scenario with 400 MHz (4.5 K) and/or 800 MHz (2 K).
- All: Operational margin discussion/definition → impact on capital and operation cost