

DMS steering with BPM scale error  
- Trial of a New Optics -

Kiyoshi Kubo

2009.06

# Problem of DMS (Dispersion Matching Steering) with BPM scale error

ILC Main Linac is curved, following earth's curvature (For L. He supply system.)

- Cryo-modules are aligned along the curvature
- In present (ILC RDR) optics
  - Orbit goes through center of every quadrupole magnet (~ attached BPM)
  - Finite dispersion at all quadrupole magnets (and attached BPM)
  - DMS adjust the dispersion, finite orbit difference due to energy difference
  - BPM scale error affects DMS


# New Optics for DMS with BPM scale error

- Orbit goes through center of every vertically defocus quadrupole magnet (~ attached BPM)
- Zero dispersion at v-defocus quadrupole magnet (and attached BPM)
- Finite offset and finite dispersion at v-focus quadrupole magnets
- Scale error of BPM attached to v-defocus quads does not affect DMS


# Vertical Orbit and Dispersion

## Two optics of curved linac


orbit



dispersion



# Alignment and Beam Orbit in Curved Linac, Following earth curvature



# Simulation

- “Standard” error set + BPM scale error
- DMS steering.
  - Change energy by 10% for dispersion measurement
  - Minimize

$$\begin{aligned} & w_1 \sum_{\text{BPM at QD}} \left( y_0 - y_{\Delta E} - (\Delta E / E) \eta_{y,\text{design}} \right)^2 \\ & + w_2 \sum_{\text{BPM at QF}} \left( y_0 - y_{\Delta E} - (\Delta E / E) \eta_{y,\text{design}} \right)^2 \\ & + \sum_{\text{all BPM}} \left( y_0 - y_{\text{design}} \right)^2 \end{aligned} \quad (\text{QD: defocus in vertical plane})$$


$y_{\Delta E}$  : BPM read with energy change  $\Delta E$

$y_{\text{design}}$  : Design beam position at BPM

$\eta_{y,\text{design}}$  : Design dispersion at BPM


$w_1$  and  $w_2$  : Weight factors

## “standard” set of errors (RMS)

	“standard”	Used in this study (approximation)
Quad Offset ( $\mu\text{m}$ )	300	360
Cavity Offset ( $\mu\text{m}$ )	300	640
Cavity Pitch ( $\mu\text{rad}$ )	300	300
BPM Offset ( $\mu\text{m}$ )	300	360
Cryomodule offset ( $\mu\text{m}$ )	200	0
Cryomodule pitch ( $\mu\text{m}$ )	20	0
Quad and BPM roll ( $\mu\text{rad}$ )	300	0
Horizontal	Vertical x 3	0
BPM resolution ( $\mu\text{m}$ )	1	1

All errors are random and independent.  
No roll errors, no horizontal errors.

# Vertical emittance (average of 40 random seeds) vs. BPM scale error



**New optics is less sensitive to BPM scale error.  
But scale error > 10% will still cause a problem.**

# SUMMARY

- DMS was simulated in curved ILC linac with BPM scale error for a new optics, compared with old (RDR) optics.
  - New: Zero dispersion at V-defocus quad magnets
  - Old: Finite dispersion at all quad magnets
- New optics is less sensitive to BPM scale error.
  - Tolerance may be increase from “a few%” to “about 10%”. But not 20 % (which was suggested by some BPM experts.).
- Dependence on fitting weights should be studied.