

PT-meeting 06.11.2017


# Outline

- LH2 target
  - silicon diode voltage drop
  - annealing by fast empty mode
  - dismount of the target
- Polarized target preparation
  - target platform
  - schedule
  - man power
  - target cell and NMR coils location
  - magnet preparation
  - PLC CPU movement


# Outline

- LH2 target
  - silicon diode voltage drop
  - annealing by fast empty mode
  - dismount of the target
- Polarized target preparation
  - target platform
  - schedule
  - man power
  - target cell and NMR coils location
  - magnet preparation
  - PLC CPU movement

# Sketch of LH2 target







# May 5

**Blue : Isolation vacuum**


**Red H2 gas pressure**

**Green : Return pipe temperature**

**Dark brown : reservoir bottom diode**

**Light brown : target cell bottom diode**


**Pink : target cell top diode**



ffer_Level V	3.71
wer_Cell_Level V	9.14
per_Cell_Level V	9.97

3/5

20/7



20/07/2017 10:35:34

Target\_Hydrogen\_Pressure (Atm) 1.17898

Target\_Isolatio 3.71


Target\_Return 7.67

Target\_Isolatio 8.28

Diode voltage: Top at target cell      Return pipe temperature

Diode voltage : Bottom at target cell    Hydrogen pressure

Diode voltage : Bottom at buffer



X Target\_Hydro Diode voltage: Top at target cell      Return pipe temperature  
X Target\_Isolati Diode voltage : Bottom at target cell      Hydrogen pressure  
X Target\_Return Diode voltage : Bottom at buffer  
X Target\_Isolati

3.65  
 10.64  
 11.03

# Silicon diode voltage

	May 5	Oct. 20	After Fast empty
Bottom at target cell	9.5 [V]	7.3	10.6
Top at target cell	10.5	7.8	11.0
Bottom at buffer	3.7	3.6	3.6

After annealing the voltages were back to the beginning.

## Activities after the end of the run

- The target compressor stopped on 21/10.
- Helium is filled in the buffer tanks
- The target was removed and transported to the clean room.

# Outline

- LH2 target
  - silicon diode voltage drop
  - annealing by fast empty mode
  - dismount of the target
- Polarized target preparation
  - target platform
  - schedule
  - man power
  - target cell and NMR coils location
  - magnet preparation
  - PLC CPU movement





CHAMP MAGNETIQUE  
DANGER  
MAGNETIC FIELD

SALEVE



# Next steps around platform

- Evacuation pumps for He3 line
- Rotary pump for Isolation vacuum
- NMR rack
  
- Electrical line → hope to be connected in this week
- Cooling row water line → available until the end of Dec.
- Compressed air line
  
- Cable tray
- Cables, Pipes

# Change over schedule ~key date~

- 23/10 Beam stop
- 31/10 Target platform rotation (loading platform installation )
- 6,7/11 Concrete blocks for absorber basement (Didier)
- 8/11 Magnet cables installation
- 8/11 He3 pumping pipes installation
- 8/11 Diffusion pump cable installation
- 13/11 DR cables installation
- 13/11 Waveguide installation
- 13/11 NMR rack installation
- - 20/11 Isolation vacuum leak check (DCS??)
- 20/11 Hadron absorber installation
- 20/11 Leak check
- Cooling water line intervention (Jan – 23.Feb) → meeting (7/11)
- 22/01 Magnet precooling  
→ magnet commissioning, target commissioning
- 09/04 Beam time starts
- 11/11 Beam stops






# Target cell

- NMR coils location changed
- Support rings for two coils inside cells (coil 3, 8)
  - PCTFE material
  - Fixing coils to the support
  - easy to install inside cell
- Contact to Bochum workshop (Gerhard. R) → no more material at Bochum
- Additional microwave stopper
  - carbon paint
- Protection sheets

NMR coils installation : December


# NMR coils location in 2015



 Inside

 Outside

# Proposed NMR coils location in 2018



NMR coil



Inside



Outside

# Magnet preparation


- Floor modification for new power convertor -- done
- PLC CPU movement – on going
- Cables installation : from 8.11
  - Scaffold needed
  - Cable tray on Jura side needed
- Signal tests : Alexey Dudarev (EP-ADO)
  - EP-DT : not responsible
- Calculation code for trim coils corrections : Fabrice

# New power converter floor support



# Radiation protection meeting

- Meeting with Rubén Alia (EN-STI-FDA) Oct.17
- COMPASS (4), EP-DT(2), TE-CRG-CE(2)
- PLC in 2015
  - Cold box PLC : Twice failures
  - Magnet PLC : Three times failures
  - Isolation vacuum PLC : Four times failures
- Concrete : 80 cm → 1/10 high energy radiation
- Polyethylene : efficient to lower neutron
- Boron carbide : very efficient to thermal neutron







Bunker place










Cold Box PLC





**First option for new place for cold box PLC CPU**




# Cold Box PLC CPU protection




Materials for further discussions



In 2015







Back up

# He3 line

- Installation of He3 pumping line on Nov. 8 (TE-CRG)
  - confirmation to Laura
  - one O-ring not arrived yet
- Installation of He3 inlet and access tube lines
- Installation and connection of evacuation pumps
- Change of pumps oil
- Safety valves

# He4 pump preparation

- Moreno (TE-CRG)
  - check pumps
- SERCO : visited last week
  - maintenance of control and safety system
- Oil Filter
  - Not yet progressed
- PLC
- Installation of He4 evaporator and cavity line (8 Nov.)

# Isolation vacuum pump

- Set up the system as the 2015 run
- Installation
  - Cables on Saleve side
  - Row water and compressed air connections
  - Rotary pump
- Commissioning with the 2015 run set up
- Isolation vacuum leak check
- Modification
  - PLC CPU movement
  - Tap water for cooling water
    - safety system modification (row water pressure in the distribution of the row water outlet line)

# Microwave

- Cooling water exchange : later (March)
- Microwave guide installation
- Set-up in 2017
  - high radiation in downstream in 2015 (coil 10)
    - shift microwave frequency
  - set-up in 2015
    - Up: moderate power with modulation
    - Dwn: high power without modulation

# Slow control and DCS

- Data transfer from na58pc057 to DCS
- Na58pc057 on NOT COMPASS network
  - change to COMPASS network
- Isolation vacuum information for leak check

# Shopping list

- PC
  - Jaakko → Gerhard accepts to buy normal PC
  - Magnet operation : Yamagata
  - NMR : Yamagata
- Leak detector
  - Arriving soon
- O-ring
  - He3 pumping pipe at DR side : finally ordered on Oct. 18
  - contact person of Angst-Pfister : Séverin Crochemore  
(severin.crochemore@angst-pfister.com)
- He3 pumps oil
  - ordered on Oct. 18
  - arriving soon
- Demineralized water : enough?
- Cooling water hose for microwave EIO : still fine? (EIOs cleaned last March)