



COOLING & VENTILATION INFRASTRUCTURE

Mauro Nonis
Alejandro Méjica



ENGINEERING
DEPARTMENT

CLIC CEIS Working Group Meeting 25/08/2017

Index

Cooling infrastructure

- CDR Baseline
- Proposed modifications

Ventilation infrastructure

- CDR Baseline
- Issues & possible solutions


Conclusions

Cooling CDR Baseline


Facilities divided into 5 cooling sectors according to:

- Functional and operational requirements
- Thermal loads
- Dimensions & geographical distribution
 - Facilities (Drive beam injector building)
 - HVAC and cooling plants (keep reasonable size)
 - Environmental impact: no cooling towers on surface points -> centralised in Prévessin


Sector 3
Accelerating structure



Sector 4
UTRs, dumps, loops



Sector 5
Detector premises




Cooling CDR Baseline



DRIVE BEAM TUNNEL

	Accel. Heat loads	Cooling plant
Sector 1	199 MW	217 MW
Sector 2	63 MW	71 MW
Sector 3	69 MW/side	138 MW
Sector 4	52 MW/side	113 MW
Sector 5	65 MW	72,2 MW
Total	569 MW	611 MW



Parameters	
Flow rate	28'641 m ³ /h
Temperature difference	20 °C
Make-up water*	860 m ³ /h

* Average water consumption at CERN: 750 m³/h

Cooling heat loads

3TeV
CDR values

			Power (kW)
Sector 1			198 960
a	Drive beam injectors building		142 560
b	Drive beam injectors tunnel		15 840
c	Frequency multiplication		15 581
d	Transfer lines		8 028
e	Chilled water production		16 951
Sector 2			62 922
a	Main beam injectors building		14 215
b	Main beam injectors tunnel		1 465
c	Surface damping rings		21 634
d	Tunnel damping rings		16 717
e	Booster tunnel		1 066
f	Booster building		5 364
g	Chilled water production		2 461
Sector 3 (Drive Beam Machine)			138 000
a	Tunnel e-		69 000
b	Tunnel e+		69 000
Sector 4 (UTRs, dumps, loops,...)			104 374
a	Tunnel e-		52 187
b	Tunnel e+		52 187
Sector 5			65 329
a	Detector premises		17 000
b	Accelerator tunnel		41 760
c	Chilled water production		6 569

New 3 TeV

Sector 3 Drive Beam Machine			115'000 kW
a	Tunnel e-		57'500
b	Tunnel e+		57'500

Updating/confirmation of other values needed


Cooling Issues

Missing items:

- Fire fighting water
- Compressed air
- Chilled water

Open issues

- Bypass inlet/outlet
- Connections between distribution pieps and manifolds, valves
- Connections to drains
- Need & space for booster pumps





Cooling: proposed modification

Cooling towers in surface points: Pt 4, 5, 8, 9

Advantages:

- Smaller pipe diameters in tunnel
- Lower electrical power requested (25%)
- No need for booster pumps
- Bypass, connection to drain: simpler if still needed
- Easier operation (balancing of circuit, ...)




Disadvantages:

- Stronger environmental impact (outside CERN)
- Bigger surface needed for installation
- Impact on shaft dimensions?

However: manifold issue still present

Cooling: possible solutions

Cooling towers in surface points: Pt 4, 5, 8, 9





Ventilation CDR

Indoor conditions

Location	Summer conditions [°C]	Winter conditions [°C]
Underground installations	21±1	21±1
Surface buildings with controlled temperature	25±1	18±1

- **Ventilation of main beam tunnel:** supply & extraction located at each surface point
- **Ventilation of UTRC, UTRA, roundabouts, dumps:** dedicated AHUs installed in UTRA or UTRC caverns. Chilled water from surface points
- **Damping rings, delay loops, frequency multiplication, transfer lines:** one AHU for supply and one for extraction per ring or sector. Relay fans for dead end tunnels.
- **Drive beam injectors tunnel:** supply and extraction located on surface
- **All others:** one dedicated unit per facility



Ventilation heat loads

Updating/confirmation of other values needed

3TeV
Old values
(CDR)

Equipment heat load	[kW]
Tunnel Drive Beam injector	1760
Tunnel Main Beam injector	380
Damping rings	950
Tunnel booster LINAC	100
Transfer line to JP, SP	450
Loop	230
Transfer line e ⁻	0
Transfer line e ⁺	0
Frequency multiplication	405
Main tunnel* e ⁺	528
Main tunnel* e ⁻	528
Turnaround e ⁻ and tunnel	35
Bunch compressor e ⁻	35
Turnaround e ⁺	35
Bunch compressor e ⁺	35
UTRC	95
UTRA	95
Drive Beam dump caverns/ post decelerators	5
Loop	10
BDS - intersection point	1560
Detector halls	650
Main beam dump cavern	140
Service halls cavern (pt 2.2 and 3.2)	150
BC2 caverns	20
Bypass tunnel	0
Escape tunnel	0
Pressurized area shaft	0

* per sector, between two surface points

Surface building	Equipment heat load
	[kW]
Drive beam Linac	15 840
Main Beam Linac Hall	608
Linac 1 and 2 target halls	0
Compton ring	0
Damping rings area (5 buildings)	0
Booster linac	0
Injection hall	170
Combiner ring 1 & 2	380
Cryo building	n.a.
Gas building	n.a.

3TeV
New values

No new values except for power dissipation to air by the accelerating structures.

	W/m	Total sector
CDR	144	528 kW
New	538	11,5 MW


Duct size [m ²]	Q [m ³ /h]	ΔT [°K]	Cooling power/sector [kW]	Heat load [W/m]
1	72'000	10	250	47

Ventilation main tunnel: heat load

- Technical loads not compatibles with achievable flow rate for the tunnel (duct size)
- Semi-transversal ventilation does not act directly on the source of the heat
- Smoke extraction to be taken into account

T max in tunnel [°C]	ΔT [°K]	Q [m ³ /h]	Φ duct [m]
21	4	886'000	4,0
26	9	838'000	3,5
30	13	580'000	3



LHC sector: 36'000 m³/h



Ventilation: possible solutions

A possible solution would be a combination of:

1. Increasing the allowable temperature in the tunnel to reduce the heat load to air e.g. to 30°C. → **working environment**
2. Supplying fresh air through a duct coming from each surface point, dissipating part of the heat load. The air would return through the tunnel and the shafts. → **gradient of temperature along the tunnel**
3. Cool the air locally and not discharge the heat in the tunnel:
 - a) Encapsulating the modules:
 1. Installing heat exchangers with an additional cooling circuit to reduce the load on the air/become neutral to the tunnel ambient,
 2. Installing fans inside the “box” forcing the air inside it through small heat exchangers connected to an additional (chilled) water network
 - b) Additional units all along the tunnel → **issues with space, air direction, effectiveness of the solution**



Separate the tunnel ventilation from the heat load removal f

Conclusions

Cooling infrastructure

- The CDR solution of centralising all cooling towers in the center results in huge pipes and need of booster pumps plus other technical problems.
- Best solution would be to install cooling towers in some surface point for the main tunnel.
- Updates of heat loads from all users is needed.
- Don't forget other services (compressed air, fire fighting water, etc.) for the definition of the cross-section.

Ventilation infrastructure

- A tunnel ventilation only (as in the CDR) is not adapted for the huge air loads inside the main tunnel.
- Different solutions to be evaluated in order to increase acceptable loads:
 1. Increase the allowable temperature in the tunnel
 2. Insulate the CLIC modules
 3. Encapsulate the CLIC modules
 4. Install AHU machines to tackle the heat load more locally
- The final solution would include a combination of the previous.
- The smoke extraction and radiation protection systems need to be taken into account.
- Updates of heat loads from all users is needed.



**THANKS FOR
YOUR ATTENTION**